SEPTEBER
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
SEPTEBER 10, 1993
M30825



ALASKAN COPPER WORKS
3200 FACILITY
SEPTEBER 28, 1993
M31102

VISUAL REPRESENTATION OF LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.8	0.38	0.6	0.08
LIMITS	2.77	3	3.98	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	1.5	0.67	1.3	0.62
LIMITS	2.77	3	3.98	2.61

AKC-0013517

SEPTEMBER
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
SEPTEMBER 2, 1993
M30702 COMPOSITE



ALASKAN COPPER WORKS
3200 FACILITY
SEPTMEBER 7, 1993
M30746 COMPOSITE

VISUAL REPRESENTATION LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	3.9	3.1	3.6	0.23
LIMITS	2.77	3	3.98	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.8	0.35	0.5	0.05
LIMITS	2.77	3	3.98	2.61

AKC-0013534

SEPTEMBER METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
SEPTEMBER 1, 1993
M30825 COMPOSITE



ALASKAN COPPER WORKS
3200 FACILITY
SEPTEMBER 28, 1993
M31102 COMPOSITE

VISUAL REPRESENTATION OF LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.8	0.38	0.6	0.08
LIMITS	2.77	3	3.98	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	1.5	0.67	1.3	0.62
LIMITS	2.77	3	3.98	2.61

AKC-0013535