AUGUST METRO LIMIT



ALASKAN COPPER WORKS
3200 FACILITY
AUGUST 13, 1993
M30413 COMPOSITE



ALASKAN COPPER WORKS
3200 FACILITY
AUGUST 30, 1993
M30614 COMPOSITE

VISUAL REPRESENTATION OF LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.09	0.18	0.58	0.02
LIMITS	2.77	3	3.98	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.5	0.3	0.5	0.2
LIMITS	2.77	3	3.98	2.61

AKC-0013563

AUGUST METRO LIMIT



ALASKAN COPPER WORKS
3200 FACILITY
AUGUST 13, 1993
M30413 COMPOSITE



ALASKAN COPPER WORKS
3200 FACILITY
AUGUST 30, 1993
M30614 COMPOSITE

VISUAL REPRESENTATION OF LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.09	0.18	0.58	0.02
LIMITS	2.77	3	3.98	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.5	0.3	0.5	0.2
LIMITS	2.77	3	3.98	2.61

AKC-0013564