APRIL
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
APRIL 3, 1997
COMPOSITE M56763



ALASKAN COPPER WORKS
3200 FACILITY
APRIL 10, 1997
COMPOSITE M74165

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.95	0.76	1.10	0.08
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.43	0.31	0.31	0.05
LIMITS	2.75	3.00	2.50	2.61

AKC-0011630

APRIL
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
APRIL 17, 1997
GRAB M74214



ALASKAN COPPER WORKS
3200 FACILITY
APRIL 18, 1997
GRAB M60612

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.55	0.49	0.44	0.05
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.38	0.27	0.23	0.05
LIMITS	2.75	3.00	2.50	2.61

AKC-0011631

APRIL
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
APRIL 21, 1997
GRAB M56926



ALASKAN COPPER WORKS
3200 FACILITY
APRIL 24, 1997
COMPOSITE M56987

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.29	0.36	0.36	0.06
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.68	0.70	0.86	0.08
LIMITS	2.75	3.00	2.50	2.61

AKC-0011632