REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° DAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS, PROBLEMS, & REMARKS (W/O#)
MONDAY	3/31	7 AM	22	14	10.63	10.35	—	10	1620	38	120°	125°	97				
		3 PM	22	12	12.2	10.27	—	—	431	17	120°	125°	121°				
		11PM	21	9	10.20	9.63	—	—	1263	77	120	130	129				
TUESDAY	4/1	7 AM	20	8	12.53	9.65	—	—	2054	66	115°	125°	122°				MADE FLOC
		3 PM	20	7	11.79	9.81	—	—	789	19	125°	125°	125°				
		11PM	18	17	9.52	10.19	—	—	1709	47	120	130	133				
WEDNESDAY	4/2	7 AM	17	15	11.95	10.13	—	10	2171	67	120°	120°	126°				Replaced the Heat exchanger for Small Tank
		3 PM	16	14	11.43	10.22	—	—	612	20	125°	110°	128°				EMPTIED PACPRESS
		11PM	16	10	9.91	10.76	—	—	1914	50	120	130	128				
THURSDAY	4/3	7 AM	15	7	11.82	10.30	—	—	2758	73	120	130	121				
		3 PM	14	7	11.72	10.77	—	—	457	14	120	130	130				
		11PM	14	19	12.29	10.65	—	—	1290	31	120	125	125				
FRIDAY	4/4	7 AM	13	18	9.81	10.57	—	—	1798	52	120	125°	126°				
		3 PM	14	16	9.58	10.43	—	—	740	13	120	125	128				
		11PM	14	14	10.58	9.94	—	—	1137	40	120	125	129				
SATURDAY	4/5	5 AM	13	13	11.30	9.89	—	10	2475	57	125°	120°	101°				
		11PM	13	10	12.00	9.88	—	—	696	18	125°	125°	55				
		PM															
SUNDAY		AM															
		PM															
		PM															

AKC-0011633