REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP °F LARGE TANK	TEMP °F SMALL TANK	TEMP °F DAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS, PROBLEMS, & REMARKS (W/O#)
MONDAY	4-21	7 AM	27	9	9.77	9.78	—	—	2421	89	130	130	77				
		3 PM	26	7	11.58	9.72	·	—	1031	22	125	130	129				
		11PM	26	5	9.87	9.78	—	—	1772	43	125	130	126				
TUESDAY	4/22	7 AM	25	5	10.85	10.08	—	10	2168	54	130	130	120				Emptied PAC PRESS
		3 PM	25	21	11.50	10.38	—	—	587	19	130	130	125				
		11PM	23	17	11.22	10.43	—	—	1401	62	125	130	126				
WEDNESDAY	4/23	7 AM	23	17	10.35	10.00	—	—	2068	75	130	130	127				
		3 PM	22	15	12.01	10.34	—	—	1174	32	125	125	123				
		11PM	21	13	11.34	10.05	—	—	2074	59	125°	130	121				
THURSDAY	4/24	7 AM	21	12	10.68	9.57	—	10	2378	70	130°	125°	121°				Emptied PAC PRESS
		3 PM	20	11	11.27	9.97	—	—	571	33	130°	130°	121°				
		11PM	15	7	10.92	9.57	—	—	1331	76	125	130	128				
FRIDAY	4/25	7 AM	15	7	9.65	10.57	—	—	1955	77	125°	125°	122°				Emptied and Pressure Washed PAC PRESS
		3 PM	17	5	11.66	9.92	—	—	1068	43	130°	130°	127				
		11PM	15	16	11.74	9.43	—	—	2157	101	130	130	127				
SATURDAY		AM															
		PM															
		PM															
SUNDAY		AM															
		PM															HEAVY Rains Caused Output Alarm to Actuate PH 8.95 Alarm Set 9.5 no Signs of Industrial discharge
		PM															

AKC-0011636


Yellow
stop