MARCH
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
MARCH 5, 1997
GRAB M56450



ALASKAN COPPER WORKS
3200 FACILITY
MARCH 6, 1997
GRAB M56459

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.60	0.42	0.53	0.05
LIMITS	2.75	3.00	2.5	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.95	0.89	1.10	0.05
LIMITS	2.75	3.00	2.5	2.61

AKC-0011687

MARCH

METRO LIMITS



ALASKAN COPPER WORKS

3200 FACILITY

MARCH 6, 1997

COMPOSITE M56460



ALASKAN COPPER WORKS

3200 FACILITY

MARCH 7, 1997

COMPOSITE M56473

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.58	0.51	0.58	0.05
LIMITS	2.75	3.00	2.5	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.58	0.70	0.67	0.05
LIMITS	2.75	3.00	2.5	2.61

AKC-0011688

MARCH

METRO LIMITS



ALASKAN COPPER WORKS

3200 FACILITY

MARCH 13, 1997

COMPOSITE M56543



ALASKAN COPPER WORKS

3200 FACILITY

MARCH 18, 1997

GRAB M56568

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.36	0.30	0.26	0.05
LIMITS	2.75	3.00	2.5	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.46	0.49	0.44	0.05
LIMITS	2.75	3.00	2.5	2.61

AKC-0011689

MARCH

METRO LIMITS



ALASKAN COPPER WORKS

3200 FACILITY

MARCH 19, 1997

GRAB M56595



ALASKAN COPPER WORKS

3200 FACILITY

MARCH 20, 1997

COMPOSITE M56614

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.61	0.58	0.68	0.07
LIMITS	2.75	3.00	2.5	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.37	0.28	0.26	0.05
LIMITS	2.75	3.00	2.5	2.61

AKC-0011690



	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.94	0.74	0.99	0.08
LIMITS	2.75	3.00	2.5	2.61

AKC-0011691