REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° OAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS, PROBLEMS, & REMARKS (W/D#)
MONDAY	3/24	7 AM	2	15	12.3	11.92			1221	25	120	130	126				Cleaned sump
		3 PM	23	13	11.32	11.38			410	16	130	130	126				
		11PM	1	8	11.023	10.47	–	·	1724	41	120	125	125				
TUESDAY	3/25	7 AM	1	5	10.6	10.3			2900	55	120	125	122				
		3 PM	33	5	11.50	11.4			69	19	120	125	123				
		11PM	32	14	10.20	10.50	–	–	1541	44	120	130	124				
WEDNESDAY	3/26	7 AM	31	13	9.74	10.39	–	–	2217	65	120	120	128				Acid wash started 9:20
		3 PM	30	10	10.18	10.53	–	–	871	15	120°	120°	121°				
		11PM	29	8	11.46	10.43	–	–	1624	38	120	125	121				
THURSDAY	3/27	7 AM	28	5	11.05	10.09	–		2736	66	120°	125°	125°				MADE FLOC
		3 PM	28	5	11.31	10.02	–	–	588	17	125	125	125				
		11PM	27	14	11.36	10.77	–	–	1736	44	120	125	128				
FRIDAY	3/28	7 AM	26	14	12.53	10.17	–	10	2057	66	125°	120°	125°				
		3 PM	15	10	12.15	9.86	–	–	1194	20	120	125	124				
		11PM	24	7	11.77	9.81	–	–	1822	40	120	130	124				
SATURDAY	3/29	5AM	24	5	9.78	10.47	–	–	2342	52	120	125	119				
		11 PM	23	3	10.49	10.55	–	–	482	21	125	130°	113°				
		PM															
SUNDAY		AM															
		PM															
		PM															

AKC-0011692