JUNE
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
JUNE 11, 1993
M29364 COMPOSITE



ALASKAN COPPER WORKS
3200 FACILITY
JUNE 18, 1993
M29372 COMPOSITE

VISUAL REPRESENTATION OF LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	1.2	0.41	0.91	0.18
LIMITS	2.77	3	3.98	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	3.4	1.2	2.8	1.3
LIMITS	2.77	3	3.98	2.61

AKC-0013593



	CHROME	COPPER	NICKEL	ZINC
RESULTS	1.4	0.42	0.68	0.16
LIMITS	2.77	3	3.98	2.61

AKC-0013594