JULY
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
JULY 9, 1993
M29801 COMPOSITE



ALASKAN COPPER WORKS
3200 FACILITY
JULY 16, 1993
M30073 GRAB

VISUAL REPRESENTATION OF LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	1.9	1.1	3.7	3.9
LIMITS	2.77	3	3.98	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.71	0.17	0.38	0.12
LINITS	2.77	3	3.98	2.61

AKC-0013618



	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.73	0.17	0.39	0.12
LIMITS	2.77	3	3.98	2.61

AKC-0013619