REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° DAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS, PROBLEMS, & REMARKS (W/O#)
MONDAY	2/24	7 AM	34	5	9.74	9.96	–	10	2163	34	130°	125°	82				
		3 PM	33	18	11.41	9.68	–	–	1132	17	125°	130°	123°				
		11PM	33	14	9.61	10.3	–	–	2377	35	128°	Err	126				
TUESDAY	2/25	7 AM	33	13	10.65	9.91	–	10	2640	38	125°	100°	107°				
		3 PM	32	10	11.60	10.09	–	–	788	27	125°	Err	120°				
		11PM	31	5	11.14	11.45	–	–	1938	50	125	Err	121				
WEDNESDAY	2/26	7 AM	31	4	11.55	10.29	–	–	2087	55	125°	Err	131				Small Acid Tank Probe Acting Erratic will Repair 2/29
		3 PM	30	14	9.95	10.58	–	–	1176	19	130	?	122				
		11PM	30	11	9.90	10.55	–	–	2349	27	125	ERR	127				Samples ?
THURSDAY	2/27	7 AM	30	10	9.79	10.43	–	–	2547	29	125	Err	126				Caustic Gravity flow down 6" in 8 hrs.
		3 PM	24	10	11.30	10.35			411	13	125	?	124				
		11PM	24	5		10.75	–	–	250	15	130	125	121				
FRIDAY	2/28	7 AM	24	5	9.99	10.27	–	–	1062	26	125°	125°	127°				Replaced 2 ~~[illegible]~~ Caustic Line Red Hat valves
		3 PM	21		10.19	9.73			585	46	130	125	127				
		11PM	21	13		16.10			1485	74	130	130	126				
SATURDAY		AM															
		PM															
		PM															
SUNDAY		AM															
		PM															
		PM															

AKC-0011701