FEBRUARY
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
FEBRUARY 6, 1997
COMPOSITE M56105



ALASKAN COPPER WORKS
3200 FACILITY
FEBRUARY 11, 1997
GRAB M56159

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.69	0.65	0.67	0.05
LIMITS	2.75	3.0	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.49	0.64	0.68	0.55
LIMITS	2.75	3.0	2.50	2.61

AKC-0011745

FEBRUARY
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
FEBRUARY 13, 1997
COMPOSITE M56206



ALASKAN COPPER WORKS
3200 FACILITY
FEBRUARY 26, 1997
COMPOSITE M56303

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.47	0.48	0.48	0.05
LIMITS	2.75	3.0	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.95	0.77	0.87	0.08
LIMITS	2.75	3.0	2.50	2.61

AKC-0011746

FEBRUARY
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
FEBRUARY 24, 1997
GRAB M56328



ALASKAN COPPER WORKS
3200 FACILITY
FEBRUARY 27, 1997
COMPOSITE M56384

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.37	0.28	0.34	0.05
LIMITS	2.75	3.0	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.60	0.49	0.37	0.14
LIMITS	2.75	3.0	2.50	2.61

AKC-0011747