JANUARY
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
JANUARY 2, 1997
M55653 COMPOSITE



ALASKAN COPPER WORKS
3200 FACILITY
JANUARY 9, 1997
COMPOSITE M55671

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.46	0.74	0.46	0.50
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.33	0.25	0.37	0.05
LIMITS	2.75	3.00	2.50	2.61

AKC-0011750

JANUARY
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
JANUARY 14, 1997
GRAB M55793



ALASKAN COPPER WORKS
3200 FACILITY
JANUARY 17, 1997
COMPOSITE M55855

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.39	0.52	0.43	0.07
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.87	1.30	0.90	0.23
LIMITS	2.75	3.00	2.50	2.61

AKC-0011751

JANUARY
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
JANUARY 23, 1997
COMPOSITE M55933



ALASKAN COPPER WORKS
3200 FACILITY
JANUARY 30 1997
COMPOSITE M56001

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.69	0.71	0.70	0.06
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.77	1.00	0.80	0.11
LIMITS	2.75	3.00	2.50	2.61

AKC-0011752