REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° OAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS, PROBLEMS, & REMARKS (W/O#)
MONDAY	1-20	7 AM	23	6	10.10	10.02			7		125	129	126				
		3 PM	23	5	10.60	9.89			7		130	129	126				
		11PM	22	18	11.80	9.98	—	-	2110	135	120°	120°	127°				
TUESDAY	1/21	7 AM	22	15	10.67	10.01			2900	136	110	120	123				Cleaned sump
		3 PM	22	14	11.20	9.96	—	—	360	22	110	120	120				Calibrated Probe
		11PM	21	14	10.57	10.04	—	—	1390	72	115	115	122°				EMPTIED DAS PRESS
WEDNESDAY	1/22	7 AM	21	13	9.90	11.01	—	-	1518	81	110	120	125				Calibrated Probe
		3 PM	20	11	11:20	10.80			739	26	100	120	123				WATER TURNED OFF AT TIMER PLEASE
		11PM	20	7	11.48	10.06	—	✓	1704	45	115	120°	121°				MAKE SURE BOOTH 1 AND 2 LIGHTS ARE ON
THURSDAY	1/23	7 AM	19	7	9.72	10.04			2197	49	130	130	127				
		3 PM	19	4	9.62	10.5			810	5	120	130	121				
		11PM	18	15	10.86	11.3	—	—	1585	78	130°	140°	130°				
FRIDAY	1/24	7 AM	17	14	9.90	10.80	—	—	1475	71	130	130	123				
		3 PM	18	12	10.8	11.1	—	—	—	—	130	120	126				
		11PM	17	11	10.87	10.83	—	—	635	17	130°	140°	129°				
SATURDAY		AM															
		PM															
		PM															
SUNDAY		AM															
		PM															
		PM															

AKC-0011757