REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° OAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS,PROBLEMS,& REMARKS (W/O#)
MONDAY	12/30	7 AM	6	14	10.64	10.82	–	–	1904	44	105°	125°	60				Emptied pre press
		3 PM	34	10	12.10	10.60	–	–	1243	16	120°	130°	116°				
		11PM	34	7	10.34	10.66	–	–	2514	37	125°	130°	127°				
TUESDAY	12/31	7 AM	34	7	10.35	10.63	–	–	3000	52	130°	130°	128°				
		3 PM	34	5	11.54	10.67	–	–	513	14	125°	125°	125°				
		11PM	33	17	9.93	10.93	–	–	1173	32	125	130	127				
WEDNESDAY	1/1	7 AM	33														Holiday
		3 PM															
		11PM															
THURSDAY	1/2	7 AM	33	16	11.62	10.31	–	10	1368	38	105°	110°	107°				Boiler was off due to Timer not being Programmed
		3 PM	33	14	11.89	10.55	–	–	707	56?	105°	105°	123°				Need to Manually turn off Function #1 Boiler H_2O Supply from Timer Box
		11PM	32	9	11.34	10.69	–	–	2041	94	115°	120	130°				
FRIDAY	1/3	7 AM	32	8	11.51	10.52	–	10+	2342	110	130°	130°	108°				Please Shut off The H_2O At the Locked Box Do Not Let Flow Reach 3000 Gallons.
		3 PM	30	20	9.97	10.81	–	–	734	88	130°	130°	125°				
		11PM	28	15	10.38	9.87	–	–	1505	112	130°	130°	124°				
SATURDAY	1/4	7AM	27	13	9.86	9.78			2358	131	130°	130°	115°				
		3 PM	24	10	11.66	9.81			767	97	130°	130°	101°				
		PM															
SUNDAY		AM															
		PM															
		PM															

AKC-0011758