FEBRUARY METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
FEBARUARY 5, 1993
M27589 COMPOSITE



ALASKAN COPPER WORKS
3200 FACILITY
FEBRUARY 19, 1993
M27782 COMPOSITE

VISUAL REPRESENTATION OF LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	2	0.4	1.8	1
LIMITS	2.77	3	3.98	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.84	0.23	0.59	0.11
LIMITS	2.77	3	3.98	2.61

AKC-0013751