REF. DWG NO. 500-0007

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOW LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP °F LARGE TANK	TEMP °F SMALL TANK	COMMENTS, PROBLEMS, & REMARKS
MONDAY	4/1	7:30	04	03	9.3	10.8	—	—	1923	53	145	180	
		3:00	04	03	9.9	10.2	10	10	850	07	138°	140°	
		11:30	03	05	8.9	10.2	—	—	1626	18	140°	152°	
TUESDAY	4/2	7:30	03	05	10.9	10.3	—	—	1887	19	135°	135°	SAMPLE TODAY (0830, 1100, 1530,)
		3:00	03	03	9.1	11.2	9	11	1216	07	140°	135°	- PLEASE ADD TO CONE ON TOP OF BOILER
		11:30	03	03	9.1	10.9	9	11	1588	15	144°	124°	Sluge mach - Racing RPM - STUTT - DOWN SAMPLE TAKEN FROM METRO AT 23:45
WEDNESDAY	4/3	7:30	02	02	9.4	10.4	—	—	1901	23	140°	125°	FLOW GUAGE NOT FUNCTIONING PROPERLY
		3:00	33	35	12.1	11.8	—	—	1909	01	145°	135°	
		11:30	33	35	8.4	10.1	~	—	6314	01	140	125°	FLOW METER NOT WORKING
THURSDAY	4/4	7:30											
		3:00											
		11:30	38	35	10.2	10.2	10	10	2994	15	134°	122°	
FRIDAY	4/5	7:30							2996				Sump pump may have a blown dyaftram (1)
		3:00											Repaired - METRO output line IN sump. INSTALLED STRAINER on input sumpline
		11:30	29	34	10.9	12.9			1494	33	142°	122°	Repaired CONTROLL Valve to Hopper
SATURDAY	4/6								1539				
SUNDAY	4/7												

AKC-0014348

REF. DWG NO. 500-0007

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOW LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP °F LARGE TANK	TEMP °F SMALL TANK	COMMENTS, PROBLEMS, & REMARKS
MONDAY	4/8	7:30	29	32	12.5	10.1	—	—	34~~7~~5	33	130°	130°	* SUBTRACT 1500 FROM SAT.
		3:00											
		11:30	29	32.5	4.5	12.7	—	—	1184	01	120°	134°	
TUESDAY	4/9	7:30	29	32	11.3	11.9	11	12	1276	04	120°	145°	
		3:00	28	32	9.7	11.8	—	—	974	06	122°	150°	
		11:30	28	32	9.2	11.7	—	—	1548	14	132°	144°	
WEDNESDAY	4/10	7:30	28	32	9.5	11.7	—	—	1695	15	130	130	PUT NEW CHECK VALVE BALLS
		3:00	27	32	8.8	12.5	—	—	1276	03	120°	120°	* ~~RESET~~ IN PAC-PRESS
		11:30	27	31.5	10.1	12.	—	—	1962	07	128°	142°	2 hrs.
THURSDAY	4/11	7:30	26	31	10.0	11.8			2174	8	130	150	
		3:00											
		11:30	26	30	9.5	11.5	—	—	1836	13	120°	120°	
FRIDAY	4/12	7:30	26	30	9.2	11.4			2046	15			FLOW NOT ~~RESET~~
		3:00											
		11:30	25	30	10.0	11.8			5121	09	134°	140°	
SATURDAY	4/13												
SUNDAY	4/14												

AKC-0014349

REF. DWG NO. 500-0007

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOW LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP °F LARGE TANK	TEMP °F SMALL TANK	COMMENTS, PROBLEMS, & REMARKS
MONDAY	4/15	7:30	25	28	~~11.4~~	11.1	—	—	6967	9	110	110	FAULTY pH PROBE NOT RESET FROM 7:00 HRS
		3:00	25	28	10.5	10.8	—	—	658	06	110	110	
		11:30	24	27	8.2	10.9	—	—	1719	10	126°	130°	
TUESDAY	4/16	7:30	24	27	10.1	10.8	—	—	1993	10	120°	140°	
		3:00	24	26	9.0	11.0	—	—	944	07	132°	143°	
		11:30	23	26	11.6	11.2			1930	16	136°	140°	
WEDNESDAY	4/17	7:30	23	26	9.3	11.2	9	11	2166	18	136	142	
		2:30 ~~3:00~~	23	26	10.3	10.8	—	—	1200	05	130°	135°	
		11:30	22	25	10.3	11.2			2037	12	124	122°	
THURSDAY	4/18	7:30	22	25	9.2	11.2	—	—	2266	15	120	135	
		3:00	21	24	11.4	10.6	—	—	817	10	125	140	
		11:30	21	22	10.4	10.2	—	—	1583	20	128°	130°	
FRIDAY	4/19	7:30	21	21	8.9	10.2	—	—	1739	26	125	120	
		3:00	21	21	11.7	10.2	—	—	736	7	130°	125°	
		11:30	20	21	11.6	10.7	—	—	1147	13	120	118	
SATURDAY	4/20												
SUNDAY	4/21												

KSAB

AKC-0014350

REF. DWG NO. 500-0007

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOW LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP °F LARGE TANK	TEMP °F SMALL TANK	COMMENTS, PROBLEMS, & REMARKS
MONDAY	4/22	7:30	20	21	8.8	10.4	9	10	1548	14	80°	75°	
		3:00	19	20	9.4	9.9	—	—	1654	08	95°	120°	
		11:30	19	19	11.6	10.4	—	—	3441	14	130°	120°	
TUESDAY	4/23	7:30	19	19	10.9	10.8	—	—	3441	14	135°	130°	
		3:00	19	18	11.8	10.9	12	11	1641	06	140°	140°	
		11:30	19	18	9.5	10.9	—	—	2374	09	142°	138°	
WEDNESDAY	4/24	7:30	19	17	11.6	10.9	—	—	2461	10	140	140°	
		3:00	18	17	9.9	11.0	—	—	2013	03	150°	120°	
		11:30	18	16	10.6	11.2	∅	∅	2515	11	142°	142°	
THURSDAY	4/25	7:30	18	16	9.4	11.1	—	—	2075 ~~2515~~	11	145°	145°	
		3:00											
		11:30	18	17	8.5	11.7	∅	∅	2512	13	140°	140°	
FRIDAY	4/26	7:30	16	10	10.0	11.5	0	0	2745	15	140	160	
		3:00	16	10	11.9	11.1	—	—	1301	10	150°	135°	
		11:30	16	9	9.3	11.0	—	—	1700	17	134°	148°	
SATURDAY	4/27												
SUNDAY	4/28												

AKC-0014351