REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° OAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS, PROBLEMS, & REMARKS (W/O#)
MONDAY	12/2	7 AM	11	15	11.5	9.60	—	9+	2537	103	115°	120°	59°				Heater See Oakite Tank not working See Hag. work order
		3 PM	10	14	9.96	9.69	—	—	735	56	120°	120°	57°				REPAIRED OAKITE TANK HEATER
		11PM	9	10	10.69	9.97	—	—	2081	86	125°	130°	88				
TUESDAY	12/3	7 AM	25	8	10.9	9.70	—	9+	2557	103	130°	130°	117°				MADE FLOC
		3 PM	25	6	12.1	10.05	—	—	891	30	130°	130°	125°				
		11PM	24	17	12.04	10.39	—	—	1999	72	125°	130°	121°				
WEDNESDAY	12/4	7 AM	24	17	10.49	10.08	—	—	2323	80	125°	130°	116°				
		3 PM	27	15	13.48	9.85	—	—	506	21	125°	125°	123°				
		11PM	27	13	11.67	10.08	—	—	1495	65	125°	130°	126°				
THURSDAY	12/5	7 AM	27	11	10.27	9.87	—	10	2184	73	130°	130°	119°				
		3 PM	27	9	10.71	9.83	—	—	819	25	130°	130°	125°				
		11PM	26	6	10.94	11.02	—	—	1614	61	130°	130°	128°				
FRIDAY	12/6	7 AM	26	5	9.75	10.87	—	—	1897	69	130°	130°	119°				SLUDGE BOX IS FULL
		3 PM	25	15	11.72	10.75	—	—	1051	44	125°	125°	124°				
		11PM	24	12	12.88	9.66	—	—	1974	88	125°	130°	122°				
SATURDAY		AM															
		PM															
		PM															
SUNDAY		AM															
		PM															
		PM															

AKC-0011859