NOVEMBER
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
NOVEMBER 6, 1996
M55173 GRAB



ALASKAN COPPER WORKS
3200 FACILITY
NOVEMBER 7, 1996
M55193 COMPOSITE

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.19	0.16	0.20	0.05
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.22	0.18	0.17	0.05
LIMITS	2.75	3.00	2.50	2.61

AKC-0011870

NOVEMBER
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
NOVEMBER 7, 1996
M55191 COMPOSITE



ALASKAN COPPER WORKS
3200 FACILITY
NOVEMBER 14, 1996
M55259 COMPOSITE

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.22	0.19	0.21	0.05
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.12	0.12	0.14	0.05
LIMITS	2.75	3.00	2.50	2.61

AKC-0011871

NOVEMBER
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
NOVEMBER 21, 1996
M55337 COMPOSITE



ALASKAN COPPER WORKS
3200 FACILITY
NOVEMBER 27, 1996
M55365 COMPOSITE

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.26	0.15	0.28	0.08
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	1.10	2.00	1.60	0.30
LIMITS	2.75	3.00	2.50	2.61

AKC-0011872