REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° OAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS, PROBLEMS, & REMARKS (W/O#)
MONDAY	11/4	7 AM	26	2	10.43	10.00	–	10	2402	75	125°	120°	108°				make floc
		3 PM	26	19	10.52	10.22	–	–	700	17	130°	125°	127°				
		11PM	25	5	10.46	9.66	–	–	1769	39	130°	125°	125°				
TUESDAY	11/5	7 AM	26	2	9.90	9.62	–	9+	2204	44	130°	130°	133°				make floc MADE MORE FLOC
		3 PM	25	10	9.51	9.50	–	–	567	58	130°	125°	128°				
		11PM	25	15	10.26	9.40	–	–	1597	82	130°	125°	124°				
WEDNESDAY	11/6	7 AM	25	13	9.80	9.42	–	9	2049	93	135°	125°	135°				metro 24 hr. MADE FLOC
		3 PM	24	5	9.51	9.50	–	–	879	37	130°	130°	123				
		11PM	23	6	12.27	9.63	–	–	2286	73	125°	125°	121°				
THURSDAY	11/7	7 AM	23	4	10.37	9.74	–	9+	2672	76	130°	130°	132°				make floc metro's 24 hr flow (2386)
		3 PM	23	11	11.20	9.65	–	–	773	59	130°	130°	126°				
		11PM	22	13	9.67	9.71	–	–	1976	116	105°	125°	123				
FRIDAY	11/8	7 AM	22	10	10.37	9.81	–	10	2320	121	120°	125°	137				MADE FLOC
		3 PM	19	7	9.80	9.87	–	–	306	61	115°	120°	120°				
		11PM	19	11	10.15	9.72	–	–	1422	102	110	125°	121°				
SATURDAY		AM															
		PM															
		PM															
SUNDAY		AM															
		PM															
		PM															

AKC-0011915