REF. DWG NO. 500-0007 REV: A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° OAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS, PROBLEMS, & REMARKS (W/O#)
MONDAY	10/21	7 AM	14	8	10.14	10.07	–	10	1544	62	120°	125°	99				MADE FLOC
		3 PM	12	5*	10.38	9.99	–	–	837	54	120°	125°	120°				
		11PM	11	13	10.56	9.44	–	–	1640	95	120°	125°	120°				
TUESDAY	10/22	7 AM	11	10	10.29	9.50	–	9	2156	104	120°	125°	117°				
		3 PM	9	10	11.87	9.46	–	–	462	34	120°	130°	128°				
		11PM	10	5	10.61	9.20	–	–	1531	89	115°	125°	128°				
WEDNESDAY	10/23	7 AM	9	2	9.80	9.07	–		1875	100	125°	125°	125°				MADE Floc
		3 PM	8	10	9.61	9.44	–	–	884	~~115~~ 55	115°	125°	127°				
		11PM	7	4	9.70	9.68	–	–	1763	102	100°	125°	120°				
THURSDAY	10/24	7 AM	7	2	10.67	9.50	–		2259	102	120	125	122				made Floc
		3 PM	33	12	11.47	9.80	–	–	753	25	105°	125°	123°				
		11PM	33	8	10.73	10.20	–	–	1588	49	110°	125°	126°				
FRIDAY	10/25	7 AM	33	7	9.58	10.21	–	10	1859	52	110°	130°	120°				MADE FLOC
		3 PM	32	7	10.96	10.88	–	–	1137	86	110°	125°	122°				
		11PM	32	15	11.95	9.79	–	–	2140	110	100°	125°	120°				
SATURDAY		AM															
		PM															
		PM															
SUNDAY		AM															
		PM															
		PM															

AKC-0011965