REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° OAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS, PROBLEMS, & REMARKS (W/O#)
MONDAY	10/14	7 AM	21	15	11.79	5m	–	9	1688	94	95	125°	114°				Replaced the Pump OUTPUT cable seems to be tighter fit
		3 PM	21	12	9.78	10.48	–	–	693	24	95°	130°	125°				made floc
		11PM	21	8	9.96	10.29	–	–	1542	58	95°	125	126°				
TUESDAY	10/15	7 AM	20	5	11.79	9.78	–	9	1819	71	95	130°	120°				MADE FLOC
		3 PM	20	4	9.80	9.87	–	–	437	13	100°	125°	127°				
		11PM	19	14	9.72	9.44	–	–	1304	59	90°	125°	125°				
WEDNESDAY	10/16	7 AM	18	9	10.59	9.99	–	10	1849	79	90°	125°	124°				
		3 PM	18	7	10.67	10.75	–	–	312	19	100°	125°	126°				
		11PM	17	4	11.62	10.88	–	–	4031	44	110°	125°	123°				
THURSDAY	10/17	7 AM	17	15	11.84	9.42	–	9	1367	52	90°	130	124°				Forgot to Reset flow
		3 PM	17	12	9.54	10.38	–	–	1959	86	80°	110°	120°				H_2O Times Raised to 30 seconds
		11PM	16	8	10.42	10.11	–	–	2764	130	100°	125°	122°				EMPTIED PAC PRESS
FRIDAY	10/18	7 AM	15	6	11.35	10.22	–	10	1681 / 3048	56 / 148	120°	125°	121°				Relay Conduit in output sump
		3 PM	15	4	10.85	10.38	–	–	672	28	120°	130°	128°				
		11PM	14	12	10.53	10.72	–	–	1514	57	120°	130°	129°				
SATURDAY		AM															
		PM															
		PM															
SUNDAY		AM															
		PM															
		PM															

Floes
1367
1681

AKC-0011966