REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° OAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS, PROBLEMS, & REMARKS (W/O#)
MONDAY	10/7	7 AM	27	2	9.85	ERR	—	10	1413	54	100	140	108				Probe was wandering Again
		3 PM	27	11	10.33	9.85	—	—	788	54	105°	150°	126°				METRO PROBE STILL MESSED UP.
		11PM	27	7	11.35	9.42	—	—	1532	89	100°	155°	128°				RED Light 4:00 Low PH
TUESDAY	10/8	7 AM	27	5	11.07	9.50	—	—	1936	93	95	155°	128°				RED Light 5:00 Low PH RED Light 11:00 Low pH
		3 PM	27	3	9.75	10.42	—	—	554	41	80°	140°	123°				RED Light 5:30 Low PH RED Light 11:35 Low PH
		11PM	~~27~~	~~12~~	9.61	10.15	—	—	1829	77	95°	150°	126°				RED Light 6:30 Low PH RED Light 12:00 Low PH
																	RED Light 7:30 Low PH RED Light 9:30 Low PH
WEDNESDAY	10/9	7 AM	27	9	10.56	9.96	—	10	2077	90	90°	150	126				Alert Condition 2 Low PH 10:11 Am ALERT CON 2 LOW PH 10:00
		3 PM	27	5	12.11	10.43	—	—	866	28	100°	145°	124°				Alert Condition 2 Low PH 1:Am ALERT CON 2 LOW PH 11:45
		11PM	27	17	10.01	10.07	—	—	1685	58	100°	140°	126°				Alert Condition 2 Low PH 2:00 PM ALERT CON 2 LOW PH 4:15
																	ALERT CON 2 LOW PH 6:45
																	ALERT CON 2 LOW PH 8:00 MADE FLOC
THURSDAY	10/10	7 AM	27	14	11.54	9.63			1815	69	100°	135°	123°				Alert Condition 2 Low PH 8:15 Am Th In Both Clearifiers 10+ At 11:30
		3 PM	27	12	11.76	10.35	—	—	549	38	100°	130°	128°				Alert Condition 2 Low PH 10:10 Am ALERT CON 2 LOW PH 5:10
		11PM	27	7	9.03	10.23	—	—	1647	95	100°	125°	129°				Alert Condition 2 Low PH 11:30 Am ALERT CON 2 LOW PH 6:45
																	Alert Condition 2 Low PH 1:30 PM ALERT CON 2 LOW PH 8:00
																	Alert Condition 2 Low PH 3:10 PM ALERT CON 2 LOW PH 9:00
																	ALERT CON 2 LOW PH 4:15 ALERT CON 2 LOW PH 10:30
FRIDAY	10/11	7 AM	22	5	10.45	9.99	—	10	1828	100	100°	125°	129°				Alert Condition 2 Low PH 8:Am ALERT CON 2 LOW PH 11:00
		3 PM	22	15	11.56		—		731	17	100	135°	130°				Caustic times changed to 4-4-8 H2O still the same. 11:45
		11PM	21	9	11.42	—	—	—	1780	46	100°	130°	128°				
SATURDAY	5:00	AM	21	6	11.64	10.02	10.5	10.00	1903	48	86	122	130				RED LITE RAISED PH IN PROCESS PIT 530 1000
	9:15	PM	21	5	11.50	10.50	11.00	10.00	360	72	110	105	128				" " " " " 600 1030
	12:30	PM					11.00	10.00									" " " " " 830 1130
																	" " " " " 900 CAUSTIC PUMP DNF
SUNDAY		AM															
		PM															
		PM															

AKC-0011967