REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° OAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS, PROBLEMS, & REMARKS (W/O#)
MONDAY	9/30	7 AM	18	5	10.78	9.93	–	10	2041	136	110°	110°	107°				
		3 PM	13	3	9.57	9.77	–	–	593	15	90°	110°	128°				
		11PM	12	15	9.65	10.41											
TUESDAY	10/1	7 AM	12	15	11.00	10.31	–	10	1840	74	85°	115°	130°				Caustic flow (Gravity flow) to sump drained 10" in 6 hrs. Repair pH probe in the metro sewer.
		3 PM	1	14	10.50	10.41	–	–	527	5	80°	105°	125				
		11PM	3	10	9.59	9.11	–	–	668	45	80°	100°	121°				OUTPUT MONITOR PROBE MESSED UP
WEDNESDAY	10/2	7 AM	3	8	9.94	Error	–	10	935	49	75°	100°	135°				Probe Repaired (moisture in line)
		3 PM	34	7	10.00	10.20	–	–	568	101	90	100°	120°				Flo Aid
		11PM	34	15	9.70	9.57	–	✓	1886	150	95°	115°	118°				
THURSDAY	10/3	7 AM	34	13	10.25	Error	–	10	2073	156	100°	120°	134°				Repaired Probe (moisture in line)
		3 PM	33	10	9.38	9.75	–	–	654	16	100	135°	120°				
		11PM	32	5	10.07	9.57	–	–	2137	76	105°	130°	128°				
FRIDAY	10/4	7 AM	32	3	9.96	Error	–	10	1849	82	105°	130°	128°				Out Put Electrode Replaced
		3 PM	32	15	9.77	9.83	–	–	490	40	110°	125°	120°				CAUSTIC TURNED OFF AT TANK
		11PM	27	8	9.26	10.58	–	✓	1708	79	110°	120°	122°				
SATURDAY	10/5	AM	28	6	9.81	10.50	–	–	2028	82	90°	115°	108°				
		PM															
		PM															
SUNDAY		AM															
		PM															
		PM															

AKC-0011968