REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° OAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS, PROBLEMS, & REMARKS (W/O#)
MONDAY	8/5	7 AM	15	12	10.72	9.65	–	10	1769	66	95°	130°	108°				
		3 PM	15	11	10.57	9.65	–	–	248	10	95°	130°	122°				
		11PM	15	9	10.55	10.67	–	–	1038	17	100°	130	122°				
TUESDAY	8/6	7 AM	15	8	10.05	10.71	–	11	1197	17	100°	130°	135°				
		3 PM	14	7	10.40	10.77	–	–	343	46	95°	125°	130°				
		11PM	14	5	10.19	11.06	–	–	1634	46	95°	120°	128°				
WEDNESDAY	8/7	7 AM	14	5	11.11	10.89	–	11	1760	53	100°	130°	131°				Problem with sump pump not working IN Auto
		3 PM	14	3	12.2	10.80	–	–	710	16	105°	130°	130°				
		11PM	12	13	10.59	10.61	–	–	1599	23	100°	130°	122°				
THURSDAY	8/8	7 AM	12	11	10.17	10.41	–	11	2006	26	100°	125°	133°				
		3 PM	15	9	11.55	10.39	–	–	759	13	100°	130°	128°				
		11PM	15	5	9.82	10.88	–	–	1599	18	105°	130°	128°				
FRIDAY	8/9	7 AM	15	5	10.05	10.62	–	–	1712	27	100°	125°	132°				
		3 PM	15	5	10.80	10.47	–	–	505	7	105°	125°	125°				
		11PM	16	16	9.70	10.61	–	–	1210	36	115°	130°	130°				
SATURDAY		AM															
		PM															
		PM															
SUNDAY		AM															
		PM															
		PM															

AKC-001209