REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° OAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS, PROBLEMS, & REMARKS (W/O#)
MONDAY	7/5	7 AM	20	3	12.2	10.1	–	10	1515	40	100	105	111				
		3 PM	20	15	11.61	10.1	–	–	483	20	125°	130°	130°				
		11PM	20	14	10.40	10.3	–	10	941	22	130°	126°	122°				
TUESDAY	7/6	7 AM	20	13	9.69	10.48	–	10	1102	22	120°	125°	135°				
		3 PM	20	11	10.14	10.40	–	–	510	23	120°	125°	123°				
		11PM	20	8	9.53	10.42	–	10	1282	32	115°	125°	121°				
WEDNESDAY	7/7	7 AM	20	8	9.69	10.63	–	–	1412	37	105°	125°	133°				
		3 PM	20	5	10.36	10.62	–	–	535	21	105°	125°	127°				
		11PM	20	3	9.80	10.32	–	10	1387	28	95°	155°	125°				
THURSDAY	7/8	7 AM	20	3	9.75	11.11	–	11	1687	31	95	175??	135°				Forgot to Reset flow & cycles
		3 PM	20	15	9.58	10.66	–	–	2315	82	100	150°	126°				C & N Recorder Having troubles
		11PM	19	13	10.10	10.05	–	10	3176	95	100°	115°	127°				
FRIDAY	7/9	7 AM	19	13	9.92	10.09	–	10	1770 / 3457	64 / 95	100	140°	134°				3457 − 1687 = 1770
		3 PM	19	11	10.32	9.91	–	–	404	35	100	130°	128°				
		11PM	19	9	9.69	10.06	–	10	1328	87	105°	130°	126°				
SATURDAY		AM															
		PM															
		PM															
SUNDAY		AM															
		PM															
		PM															

AKC-001212