REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° OAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS, PROBLEMS, & REMARKS (W/O#)
MONDAY	6/3	7 AM	8	10	9.81	9.60	–	–	2566	92	110°	110°	102°				
		3 PM	8	8	10.47	9.56	–	–	715	29	115°	110°	128°				
		11PM	7	5	10.81	9.53	–	–	1288	81	110°	115°	130°				
TUESDAY	6/4	7 AM	7	5	11.69	9.67	–	–	1691	105	100°	120°	127°				
		3 PM	6	4	10.41	10.52	–	–	567	34	115	120	126				
		11PM	6	15	11.35	10.09	–	–	1444	74	110°	120°	121°				
WEDNESDAY	6/5	7 AM	6	15	9.83	9.90	–	10	1708	78	105°	125°	130°				
		3 PM	6	14	9.60	9.78	–	–	344	34	115°	120°	123°				
		11PM	6	12	9.68	9.83	–	–	1117	70	115°	120°	121°				
THURSDAY	6/6	7 AM	6	10	9.75	9.79	–	–	1255	77	95°	120°	128°				REPLACED THERMOCOUPLER IN OKITE TANK
		3 PM	5	10	9.68	10.05	–	–	568	30	110°	125	109				RSX RECORDER UPGRADE
		11PM	5	8	10.07	10.04	–	–	1233	70	100°	130°	114°				
FRIDAY	6/7	7 AM	5	7	9.70	9.79	–	10	1453	78	100°	130°	135°				RSX RECONFIG 10:30 AM
		3 PM	33	6	11.20	9.67	–	–	428	32	105°	130°	127°				Recharged Caustic
		11PM	33	3	11.00	10.47	–	–	1332	50	95°	130°	124°				
SATURDAY		AM															
		PM															
		PM															
SUNDAY		AM															
		PM															
		PM															

AKC-0012167