REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° OAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS, PROBLEMS, & REMARKS (W/O#)
MONDAY	4/8	4:30 AM	32	9	11.01	9.58	–	–	388	29	95°	70°	77°				
		3 PM	32	8	11.1	9.87	–	9	1112	37	97°	95°	128°				
		11PM	32	4	11.47	11.37	–	–	1993	38	100°	110°	125°				
TUESDAY	4/9	7 AM	32	3	11.06	11.56	–	11	2188	38	120°	120°	123°				@ 5:45 Lin & Great Lakes Read the Same Start Recorded test of Lin & Great Lakes mix tank Lin Hook-up Complete
		3 PM	32	15	11.40	11.31	–	–	346	22	115°	120°	122°				
		11PM	32	13	11.53	10.82	–	–	1328	33	125°	120°	127°				
WEDNESDAY	4/10	7 AM	32	13	11.18	10.77	–	–	1444	33	125°	120°	115°				Traces of Cement from CATH Project dumped into System
		3 PM	32	10	11.7	10.57	–	–	604	9	125°	125°	129°				
		11PM	32	7	9.60	10.92	–	–	1562	35	130°	115°	130°				
THURSDAY	4/11	7 AM	32	7	9.94	10.64	–	–	1882	45	130°	120°	120°				
		3 PM	31	5	10.83	10.18	–	–	494	26	130°	125°	125°				
		11PM	31	3	9.58	10.10	–	–	1532	50	125°	120°	129°				
FRIDAY	4/12	7 AM	31	3	9.70	10.03	–	10	1762	65	125°	120°	120°				
		3 PM	31	15	9.59	9.72	–	–	339	24	115°	105°	124°				
		11PM	31	14	9.56	11.61			1285	71	110°	100°	121°				
SATURDAY		AM															
		PM															
		PM															
SUNDAY		AM															
		PM															
		PM															

AKC-001225

1762
212
1974

2164

AKC-0012260