MARCH
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
MARCH 7, 1996
M52543 COMPOSITE



ALASKAN COPPER WORKS
3200 FACILITY
MARCH 14, 1996
M52618 COMPOSITE

VISUAL REPRESENTATION OF LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.39	0.36	0.25	0.13
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.92	0.36	0.82	0.08
LIMITS	2.75	3.00	2.50	2.61

AKC-0012266

MARCH
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
MARCH 21, 1996
M52694 COMPOSITE



ALASKAN COPPER WORKS
3200 FACILITY
MARCH 28, 1996
M52780 COMPOSITE

VISUAL REPRESENTATION OF LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.80	0.54	0.62	0.05
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.14	0.10	0.05	0.05
LIMITS	2.75	3.00	2.50	2.61

AKC-0012267