REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° OAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS, PROBLEMS, & REMARKS (W/O#)
MONDAY	2/12	7 AM	23	12	9.94	9.65	–	–	2385	85	115°	140°	68°				
		3 PM	23	9	11.80	10.07	–	10	692	5	120°	130°	128°				
		11PM	23	7	11.03	11.09	–	–	1147	5	120°	140°	128°				
TUESDAY	2/13	7 AM	23	6	10.71	11.08	–	11	1353	5	120°	160°	116°				Oakite Temp Unit Dead no Power
		3 PM	23	5	10.13	10.68	–	–	390	16	125°	140°	–				
		11PM	23	18	10.39	10.19	–	–	941	40	115°	130	–				
WEDNESDAY	2/14	7 AM	23	14	9.88	10.00	–	10	1187	48	100°	115°					
		3 PM	23	10	10.36	9.76	–	~~[illegible]~~	427	15	125°	125°	130				
		11PM	23	7	10.46	9.81	–	–	879	26	105°	115°	127°				
THURSDAY	2/15	7 AM	22	5	9.94	9.80	–	10	1131	35	110°	120°	129°				
		3 PM	23	5	9.68	9.75	–	–	385	16	105°	130°	128°				
		11PM	22	2	10.7	9.67	–	–	990	39	105°	130°	127°				
FRIDAY	2/16	7 AM	22	2	9.61	9.57	–	–	1149	42	95°	140°	127				
		3 PM	22	14	9.42	10.33	–	–	374	19	120°	125°	128				
		11PM	21	10	10.11	9.76	–	–	1008	63	125	110	130				
SATURDAY		5 AM	21	10	10.51	9.62	–	–	1127	68	100°	110°	125°				
		1 PM	21	10	10.10	9.97			1155	35	124	99	123				
		PM															
SUNDAY		AM															
		PM															
		PM															

12.89 #59

AKC-001235