REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° OAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS, PROBLEMS, & REMARKS (W/O#)
MONDAY	2/19	7 AM	21	7	10.83	11.15	-	11	1058	16	115°	70°	77°				Call by Sourephone @ 2:56 AM Arrived @ 3:35 The Boiler upper limit switch DNF causing Acid yard to flood over to metro output Aircator was not on so just city water flowed over (High Ph Effluent Has higher S.G. and the city H_2O did not get mixed) The Ph of discharge when I Arrived was 7.40.
		3 PM	21	5	9.61	10.70	-	-	519	1	130°	100°	121°				
		11PM	21	16	10.30	10.51	-	-	1016	5	120°	115°	111				
TUESDAY	2/20	7 AM	21	15	10.65	10.38	-	10	1114	14	120°	120°	124°				forgot to reset flow & cycles
		3 PM	21	14	10.65	10.83	-	-	1538	30	115°	125°	125°				
		11PM	21	12	10.6	10.46	-	-	2042	44	110°	135°	129°				
WEDNESDAY	2/21	7 AM	21	10	9.69	10.08	-	-	1152 / 2266	40 / 54	110°	145°	126°				
		3 PM	20	10	11.89	9.85			206	13	95°	135°	125°				
		11PM	20	7	10.27	9.95	-	-	650	18	115°	150°	127°				
THURSDAY	2/22	7 AM	20	7	9.51	10.01	-	10	852	30	120°	160°	127°				MADE FLOC
		3 PM	20	5	9.86	10.11	-	10	376	12	115°	160°	122°				
		11PM	20	14	10.37	10.20	-	-	854	32	110°	155°	121°				
FRIDAY	2/23	7 AM	20	16	9.54	10.28	-	-	100	37	120°	165°	128°				
		3 PM	20	15	10.38	10.02	-	-	458	32	120°	140°	121°				
		11PM	20	13	10.8	10.04	-	-	951	37	125°	130°	124°				
SATURDAY	2-24-16	~~5 AM~~	~~20~~	~~13~~	~~11.55~~	~~10.04~~	~~-~~	~~10~~	~~1016~~	~~43~~	~~120~~	~~120~~	~~123~~				
		PM															
		PM															
SUNDAY		AM															
		PM															
		PM															

AKC-001235