REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° DAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS, PROBLEMS, & REMARKS (W/D#)
Tue MONDAY	1/2	7 AM	27	6	8.89	11.12	–	11	1696	51	100°	150°	119°				
		3 PM	33	4	10.18	11.01	–	–	634	52	100°	160°	122°				Holiday
		11PM	32	13	9.73	9.91	–	–	1697	86	120°	135°	121°				
Wed TUESDAY	1/3	7 AM	32	12	10.01	9.99	–	10	2179	109	125°	140°	121				PAPER TESTED METRO SUMP IT WAS 9-10 pH
		3 PM	32	9	9.70	9.56	–	–	654	60	110°	ERR	128				Probe Broken
		11PM	32	7	9.80	9-10	–	–	1520	73	100°	ERR	126				
Thur WEDNESDAY	1/4	7 AM	31	5	9.63	9.77	–	10	1812	94	110°	ERR	113				MADE FLOC
		3 PM	31	3	10.98	9.83			1812	22	120	135°	126°				FLOWMETER DNF
		11PM	31	13	9.95	11.01			1813	27	120°	135°	129°				
Fri THURSDAY	1/5	7 AM	31	13	9.51	10.32	–	10	2450	42	120°	150°	117°				
		3 PM	31	10	9.64	10.59	–	–	244	23	120°	140°	129°				
		11PM	31	7	10.64	10.36	–	–	972	38	120°	160°	122°				
Sat FRIDAY	1/6	7 AM	31	7	10.64	10.36	–	–	1879	40	120	160	128°				
		3 PM	31	7													
		11PM	31	7	10.03	10.01	–	–	1069	40	120°	160°	125°				
SATURDAY		AM															
		PM															
		PM															
SUNDAY		AM															
		PM															
		PM															

AKC-0012420