DECEMBER
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
DECEMBER 7, 1995
M51573 COMPOSITE



ALASKAN COPPER WORKS
3200 FACILITY
DECEMBER 14, 1995
M71190 COMPOSITE

VISUAL REPRESENTATION OF LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.78	0.62	0.42	0.06
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.55	0.57	0.31	0.11
LIMITS	2.75	3.00	2.50	2.61

AKC-0012428

DECEMBER
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
DECEMBER 21, 1995
M71223 COMPOSITE



ALASKAN COPPER WORKS
3200 FACILITY
DECEMBER 28, 1995
M51766 COMPOSITE

VISUAL REPRESENTATION OF LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.65	0.92	0.35	0.10
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.69	0.71	0.41	0.07
LIMITS	2.75	3.00	2.50	2.61

AKC-0012429