NOVEMBER
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
NOVEMBER 2, 1995
M51223 COMPOSITE



ALASKAN COPPER WORKS
3200 FACILITY
NOVEMBER 8, 1995
M51276 COMPOSITE

VISUAL REPRESENTATION OF LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	1.10	0.91	0.99	0.05
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	1.10	0.61	1.00	0.05
LIMITS	2.75	3.00	2.50	2.61

AKC-0012517

NOVEMBER
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
NOVEMBER 16, 1995
M51367 COMPOSITE



ALASKAN COPPER WORKS
3200 FACILITY
NOVEMBER 25, 1995
M51439 COMPOSITE

VISUAL REPRESENTATION OF LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	1.10	0.71	0.89	0.07
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.96	0.54	0.57	0.09
LIMITS	2.75	3.00	2.50	2.61

AKC-0012518

NOVEMBER
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
NOVEMBER 28, 1995
M71085 GRAB



ALASKAN COPPER WORKS
3200 FACILITY
NOVEMBER 30, 1995
M51487 COMPOSITE

VISUAL REPRESENTATION OF LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	1.20	0.95	0.66	0.08
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.82	0.52	0.45	0.10
LIMITS	2.75	3.00	2.50	2.61

AKC-0012519