REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° OAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS, PROBLEMS, & REMARKS (W/D#)
MONDAY	11/13/95	7 AM	16	2	10.95	9.80			2711	85	128	150°	101°				made floc
		3 PM	16	15	10.05	9.67			515	7	120°	140°	130°				
		11PM	16	13	10.9	11.18	—	—	1371	15	130°	135°	127°				
TUESDAY	11/14	7 AM	15	12	11.73	11.36	—		1573	20	130°	130°	124°				OAKITE TEMP no working 11:00 pm
		3 PM	15	9	9.6	11.0			771	11	125°	120°	125°				
		11PM	15	5	12.17	10.10			575	20	130	140°					
WEDNESDAY	11/15	7 AM	14	5	11.29	10.10	—	—	1574	28	130°	155°	128				EMPTIED FAC PRESS
		3 PM	14	15	10.39	11.04	—	—	1313	10	130°	160°	126				
		11PM	14	12	11.41	10.06	—	—	2271	45	138	165°	127°				
THURSDAY	11/16	7 AM	13	10	11.08	9.85	—	10	2665	52	130°	160°	128°				MADE FLOC
		3 PM	13	7	12.37	10.77	—	—	672	17	130°	150°	129°				
		11PM	13	5	10.03	11.24	—	—	1310	22	130°	140°	129				
FRIDAY	11/17	7 AM	12	15	10.11	11.43	—	11	1785	30	130°	130°	118°				PROBE HOLDER going INTO TANK BROKEN
		3 PM	12	14	10.65	10.81	—	—	609	7	120°	125°	127°				
		11PM	[illegible]	10	10.03	10.42	—	—	1441	26	130	125°	125°				
SATURDAY	11/18	5 AM	11	9	10.41	10.57	—	10	1526	36	125°	125°	135°				
		PM	11	8	10.08	10.18	—	10	621	8	115°	120°	121°				
		PM	10	5	11.15	10.36	—	—	1401	29	125°	138°	125°				
SUNDAY		AM															
		PM															
		PM															

AKC-0012521