REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° OAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS, PROBLEMS, & REMARKS (W/O#)
MONDAY	9/11	3 AM	31	14	10.56	10.26	–	10	1914	72	105°	115°	117°				
		3 PM	30	13	11.83	10.29	–	–	523	15	120°	125°	121°				
		11PM	29	8	11.68	10.22	–	–	1496	36	120°	125°	121°				
TUESDAY	9/12	7 AM	28	7	11.73	10.17	–	10	1748	44	120°	125°	134°				made floc
		3 PM	28	6	11.74	11.6	–	–	613	7	130°	140°	121°				
		11PM	27	13	11.07	10.63	–	–	1162	23	120°	150°	120°				
WEDNESDAY	9/13	7 AM	26	13	11.38	10.43	–	–	1350	28	120°	160°	133°				forgot to reset flow & cycles
		3 PM	23	10	9.54	10.09	–	–	1869	67	120	150	124				
		11PM	22	5	10.41	9.69	–	–	2695	112	120°	135°	128°				
THURSDAY	9/14	7 AM	22	2	10.32	9.68	–		1595 / 2945	119	120°	140°	128°				Did not reset made Emptied Pac Press ~~[illegible]~~ floc CLEANED INLET FILTER TANK
		3 PM	21	14	11.55	10.4	–	–	3412	136	120°	155°	121°				
		11PM	20	9	10.76	9.88	–	–	4097	154	110°	165°	126°				
FRIDAY	9/15	7 AM	19	7	10.95	9.92	–	10	1593 / 4535	163	120°	165°	128				3855 / 2945 / 1593 MADE FLOC
		3 PM	19	5	9.50	10.88	–	–	517	14	120°	145°	122°				
		11PM	18	15	10.09	10.41	–	–	1107	30	120°	135°	122°				
SATURDAY	9/16	5 AM	17	14	11.52	10.26	–		1359	37	115°	130°	130°				
		1 PM	16	11	11.11	10.16	–	–	595	13	115°	140°	123				
		PM	15	8	11.73	10.36	–	–	1021	25	120°	150°	121°				
SUNDAY	9/17	AM	15	8	11.01	10.26	–		1080	26	115°	145°	115				
		PM	15	8	11.6	10.12	–	–	1250	26	110°	145	115				
		PM	15	7	10.14	10.12	–	–	1301	27	105°	140°	104				

AKC-0012587