REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° OAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS, PROBLEMS, & REMARKS (W/O#)
MONDAY	9/16	7 AM	15	5	12.6	10.3	–	–	1518	32	115	175	95				Clean sumps
		3 PM	15	1	11.89	10.27	–	–	387	11	120°	145°	129°				
		11PM	14	14	10.66	10.80	–	–	1139	20	120°	135°	124°				
TUESDAY	9/17	7 AM	13	12	10.71	10.36	–	10	1457	29	120°	130°	125°				EMPTIED PAC PRESS
		3 PM	14	10	11.46	10.21	–	–	467	13	120°	150°	121				
		11PM	13	5	11.54	9.97	–	–	1463	28	120°	155°	121°				
WEDNESDAY	9/20	7 AM	13	2	10.63	10.02	–	–	1771	33	120°	160°	125°				MADE PAC
		3 PM	13	0	11.32	10.26	–	–	543	17	120°	165°	121°				
		11PM	13	13	10.82	10.62	–	–	1030	25	115°	170°	125°				
THURSDAY	9/21	7 AM	13	12	11.44	10.48	–	10	1433	32	100°	180°	124°				
		3 PM	13	10	11.66	10.43	–	–	373	13	110°	150°	122°				
		11PM	13	5	11.42	1.8	–	–	1107	34	115°	140°	129°				
FRIDAY	9/22	7 AM	13	5	11.51	10.26	–	10	1297	35	115°	135°	123°				Surged to Reset flow
		3 PM	13	2	11.78	10.46	–	–	1969	14	115°	135°	121°				EMPTIED PAC PRESS
		11PM	13	13	10.01	10.47	–	–	2396	27	100°	145°	128°				
SATURDAY	9/23	AM	6	10	9.91	10.41	–	–	1266 / 2583	29	90°	140°	130°				Caustic flow stuck Temps Small tank turned up to 150°
		PM	5	7	11.99	10.28			309	42	120°	130°	130°				
		PM	5	5	11.66	10.2	–	–	890	54	120°	140°	121				
SUNDAY		AM															
		PM															
		PM															

2583
1297
1266

AKC-0012588