REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° OAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS, PROBLEMS, & REMARKS (W/O#)
MONDAY	9/25	7 AM	4	4	11.71	10.04	–	10	1112	59	120°	150	93				Made Floc
		3 PM	4	15	11:00	10.15	–	10	594	15	120°	140	94				
		11PM	3	12	11.84	10.6	–	–	1135	32	120°	140°	124				
TUESDAY	9/26	7 AM	3	10	11.49	10.23	–	10	1453	38	120°	145°	126				EMPTIED PAC PRESS
		3 PM	33	9	10.69	10.37	–	–	591	15	120°	135°	124				metro set-up for 24hr sample Post violation
		11PM	33	6	10.06	10.57	–	–	1244	28	115°	130°	120°				1662 308 1354 209 1563
WEDNESDAY	9/27	7 AM	32	5	11.18	10.69	–	–	1662	39	115°	130°	124°				Metro 24 hr Semi-Yearly
		3 PM	32	3	10.97	10.66	–	–	578	51	100°	115°	125°				EMPTIED PAC PRESS
		11PM	31	13	10.33	10.60	–	–	1074	67	80	110	129°				BOILER WAS OFF
THURSDAY	9/28	7 AM	30	10	9.81	10.56	–	10	1743	50	105	120°	123°				Sensor to Reset
		3 PM	29	9	11.63	10.48	–	–	2107	14	110	125°	122°				
		11PM	28	7	11.33	10.69	–	–	2777	27	120°	120°	107°				
FRIDAY	9/29	7 AM	28	5	10.95	10.53	–	10	1356 / 3099	34	120°	129°	99°				3099 1743 1356 MADE FLOC
		3 PM	22	3	11.07	10.65	–	–	887	15	120°	130°	100°				EMPTIED PAC PRESS
		11PM	26	13	10.27	10.64	–	–	1516	30	120°	140°	94				
SATURDAY	9/30	5 AM	26	12	11.25	10.47			1738	31	115°	135°	93°				
		1 PM	25	7	11.51	10.15			1163	16	120°	145°	89°				
		9 PM	24	5	11.41	10.41	–	–	1646	29	120°	150°	108°				
SUNDAY		5 AM	24	4	Err	10.20	–	10	1659	30	110°	140	129°				
		PM	23	3	Err	10.52	–	10	735	14	115°	140°	106°				
		PM															

AKC-0012589