REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° OAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS, PROBLEMS, & REMARKS (W/O#)
MONDAY	8/22	7 AM	29	11	11.71	9.78		10	2160	48	130°	130°	120				TURNED OFF PAC PRESS BECAUSE There isn't enough sludge to go through to it.
		3 PM	29	9	11.84	9.95		8	538	7	130°	150°	123°				
		11PM	28	8	10.34	10.07	–	–	964	13	130°	160°	BROKEN				
TUESDAY	8/23	7 AM	27	5	10.69	10.10	–	10	1434	23	130°	170°					
		3 PM	27	14	10.43	9.93	–	9	591	9	130°	165°	127°				
		11PM	27	12	9.90	10.03	–	–	1221	17	130°	145°	129°				
WEDNESDAY	8/24	7 AM	26	8	12.40	9.84	–	10	1688	63	130°	145°	130°				Made floc
		3 PM	25	5	10.06	9.96	–	–	485	8	130°	130°	120°				
		11PM	29	15	10.07	11.18	–	10	1109	18	125°	128°	124				
THURSDAY	8/25	7 AM	24	11	11.38	9.72	–	10	1658	28	130°	130°	126°				
		3 PM	24	10	11.91	9.85	–	–	571	10	130°	130°	120°				
		11PM	23	6	11.65	10.34	–	–	1142	23	130°	140°	121°				
FRIDAY	8/26	7 AM	22	3	11.44	10.18	–	10	1635	40	130	155	124°				
		3 PM	22	12	11.30	9.98	–	–	329	7	130°	145°	128°				
		11PM	21	8	11.90	10.07	–	–	984	18	138	138	123°				
SATURDAY	8/27	5 AM	21	6	11.14	10.10	–	10	1411	22	120°	130°	130°				Istalled new Box And wired made floc. Pumps off for 3 hrs then off for 2½ hrs.
		1 PM	20	5	11.06	9.94			138	6	115°	120°	130°				
		PM	20	17	10.2	9.9	–	–	654	22	125°	145°	124°				
SUNDAY		5 AM	20	15	9.52	9.92	–	10	729	23	120°	150°	143°				
		12PM	19	14	11.23	10.11	–	–	481	11	130°	140°	121				
		PM															

AKC-0012599