REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° OAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS, PROBLEMS, & REMARKS (W/O#)
MONDAY	8/14	7 AM	8	7	11.52	10.32	–	11	2271	41	135°	135°	131°				MADE FLOC
		3 PM	7	5	11.50	9.70	–	–	638	17	120°	135°	127°				
		11PM	7	15	11.60	9.85	–	–	1262	29	125°	125°	129°				
TUESDAY	8/15	7 AM	6	14	11.67	9.77	–	10	1776	43	125°	125°	128°				EMPTIED PAC PRESS
		3 PM	5	12	11.64	9.71	–	–	595	12	125°	125°	120°				
		11PM	4	8	10.29	9.85	–	–	1149	28	125°	125°	126°				
WEDNESDAY	8/16	7 AM	4	4	9.81	9.88	–	10	1527	38	125°	125°	125°				
		3 PM	3	15	10.78	9.91	–	–	943	7	125°	125°	121°				Please start taking Samples
		11PM	2	12	9.6	9.84	–	10	1451	24	125°	135°	122°				Please Empty PAC-Press Last thing tonight
THURSDAY	8/17	7 AM	2	10	11.00	9.42	–	–	1877	35	125°	150°	120°				And Do not USE!!!
		3 PM	33	8	11.46	9.79	–	–	504	4	125°	140°	126°				Replaced all the "O" Rings on filter Plates
		11PM	33	6	10.15	10.56	–	–	1074	24	110°	125°	125°				Metro In Taking Sample
FRIDAY	8/18	7 AM	33	5	9.81	10.02	–	10	1569	34	110°	125°	120°				Made floc Air To pac Press was off
		3 PM	32	2	10.7	9.63	–	10	536	9	115°	125°	126°				Signett Spasing out Called JT To Avise says its OK
		11PM	32	14	10.95	9.75	–	10	1014	19	110°	140°	127°				
SATURDAY	8/19	5:30 AM	31	12	ERR	9.55			1268	27	95°	130°	129°				ERR Signal on Process probe MONITOR – water inside (5:00 AM) – (all day) probe
		PM	31	10	ERR	9.47			468	7	105°	125°	125°				Made Floc
		PM	30	15	ERR	10.03	–	10	1072	21	95°	140°	122°				
SUNDAY	8/20	AM	31	15	[illegible]	9.99	–	10	1169	21	100°	135°	140°				Forgot to Reset
		PM	30	14	11.38	9.92	–	10	1573	36	100°	145°	128°				
		PM															

AKC-0012600


Acidic
BASE (Caustic)
0 1 2 3 4 5 6 7 8 9 10 11 12 13 14
Rinse
Caustic