REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° OAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS, PROBLEMS, & REMARKS (W/O#)
MONDAY	8/7	3 AM	21	14	11.3	10.28			1247	31	125°	130°	105°			32"	9:10 turned off Alarms
		3 PM	20	12	9.5	11.06	–	–	586	26	125°	120°	122°				Switched Signet & Lin ~~MADE FLOC~~
		11PM	20	10	11.6	10.62			1144	48	125°	130°	125°				
TUESDAY	8/8	7 AM	20	7	10.58	10.27	–	11	1521	70	125°	130°	128°			32"	MADE FLOC
		3 PM	18	6	11.75	10.32	–	–	534	17	125°	125°	128°				
		11PM	18	5	11.2	10.24	–	–	1249	35	125°	140	128°				
WEDNESDAY	8/9	7 AM	17	15	11.62	10.58	–	11	1643	62	125°	160°	123°			32"	Emptied PacPress
		3 PM	16	13	10.21	10.62	–	–	616	21	125°	145°	123				
		11PM	16	9	10.28	10.65	–	–	1136	46	125°	130°	125°				
THURSDAY	8/10	7 AM	16	7	11.83	10.38	–	10	1502	55	125°	125°	128°			32"	MADE FLOC
		3 PM	16	5	11.83	10.59	–	–	479	11	125°	125°	130°				
		11PM	13	2	11.11	10.71	–	–	1066	28	125°	140°	129				
FRIDAY	8/11	7 AM	13	11	10.90	10.26	–	11	1827	49	125°	125°	130°				
		3 PM	13	10	11.7	10.29			223	4	110°	160°	124°				
		11PM	11	8	11.4	10.49	–	–	886	34	100°	175°	123°				
SATURDAY	8/12	5 AM	10	5	11.13	10.64	–	11	1144	44	100°	160	121°				Pump Acid over to Lg tank
		1 PM	10	15	11.04	10.64	–	–	402	8	120°	160°	122°				fixed Eyewash
		5 PM	10	13	10.16	10.78	–	–	741	12	130°	150°	122°				Emptied & cleaned Pac-Press
SUNDAY	8/13	5 AM	10	12	11.33	10.76	–	11	951	15	120°	130°	136°				Forgot to Reset flow & Cycles
		1 PM	10	9	9.90	10.72	–	–	1868	33	130°	130°	127°				
		PM															

AKC-0012602