REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° OAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS, PROBLEMS, & REMARKS (W/O#)
MONDAY	7/31	7 AM	32	5	11.7	10.88	–	11	1035	31	135°	150°	124°			32"	6 Alert condition 4's
		3 PM	31	2	10.7	10.61	–	–	527	17	130°	135°	128				2 Alert Condition 2's
		11PM	30	1	11.3	10.57	–	–	1200	49	130°	130°	126°				Calibrated Probes Process Sump Signet (mv 23) very weak Have Replacement.
TUESDAY	8/1	5 AM	29	1	12.6	10.93	–	11	1512	62	130°	130°	122°			32"	8:00AM - alert 4 11:15 AM (approx) alert 4
		3 PM	29	10	10.0	11.28			561	17	130°	130°	130°				9:30 AM alert 4
		11PM	32?	8	9.8	10.84	–	11	1225	32	130°	130°	124°				Calibrated old signet of LAN alert 4 - 2:00 PM (approx) EMPTIED PAC Press
WEDNESDAY	8/2	7 AM	27	3	11.7	10.87	–	11	1529	41	130°	130°	121°			32	
		3 PM	27	15	11.5	10.97	–	–	616	12	130°	130°	124°				
		11PM	26	11	11.2	10.88	–	–	1787	26	130°	130°	124°				
THURSDAY	8/3	7 AM	25	7	10.3	10.64			1831	41	130°	130°	123°				EMPTIED PAC PRESS
		3 PM	25	6	11.5	10.56			380	9	130°	160°	120°				
		11PM	24	2	10.4	10.51	–	–	1005	25	130°	175°	122°				
FRIDAY	8/4	7 AM	24	1	9.5	10.79			1396	35	130°	180°	129°				
		3 PM	24	13	9.5	10.83			460	7	130°	175°	130°				
		11PM	23	10	11.4	10.50			1022	22	120°	150°	127°				
SATURDAY	8/5	6 AM	22	~~32~~ 4	10.9	10.34			1258	29	120°	135°	129°				MADE FLOC
		2 PM	22	6	10.1	10.39			517	7	125°	130°	127°				EMPTIED PAC PRESS
		7 PM	21	15	11.4	10.38			848	24	125°	120°	128°				
SUNDAY		AM															
		PM															
		PM															

AKC-0012603


Ho
Sol.
Ni
Cu
Ho
PH 7
12