REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° DAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS, PROBLEMS, & REMARKS (W/O#)
MONDAY	7-24	7 AM	11	15	11.6	10.86	–	11	1382/2382	75?	125°	110°	121°				2:30 YELLOW LITE DOES NOT WORK. PROBLEM IS MOST LIKELY A BAD CONNECTION NEAR THE FLOATS
		3 PM	11	12	9.9	10.87		11	284	10	125°	110°	126°				No Problem with Float works Fine
		11PM	11	8	10.3	10.89	–	11	992	23	125°	123°	127°				
TUESDAY	7/25	7 AM	10	5	11.4	10.65	–	11	1391	32	125°	150°	126°				
		3 PM	9	3	11.5	10.80	–	11	583	14	125°	160°	125°				
		11PM	9	14	10.9	10.86	–	11	1304	26	125°	170°	125				
WEDNESDAY	7/26	7 AM	8	10	10.7	10.77	–	11	1765	40	125°	180°	127°				6" Pipe Noticeably more Sludge
		3 PM	7	7	11.6	10.78	–	–	663	52	180°	160°	125°				800 Red Light No Reason
		11PM	6	5	11.2	10.85	–	11	1320	70	140°	144°	126°				No More Sample Bottles! (well Rinse them out!)
THURSDAY	7/27	7 AM	6	5	11.8	10.61	–	11	1687	85	140°	140°	124°				
		3 PM	8	13	11.5	10.61	–	–	512	8	140	130°	122°				
		11PM	6	10	9.9	10.85	–	11	1168	25	140	135°	129°				
FRIDAY	7/28	7 AM	5	8	11.1	10.72	–	11	1755	38	140°	155°	126°				Clarifiers Heavy Sludge (1:2) Turned off Pump until Pre-Press. Cake Dry
		3 PM	5	5	9.3	10.30	–	11	897	18	140°	165°	122°				-yellow light at noon Pre-Press Empties
		11PM	4	2	9.7	10.25		11	1507	29	145°	150	128°				
SATURDAY	7/29	5 AM	3	15	10.8	10.56	–		1633	35	130°	140°	123°				Hi Sandra!
		1 PM	33	12	11.5	10.58			336	15	120°	155°	127°				11:15 AM-yellow light - 11:30 - SIGNEY PROBES NOT MATCHING; 12:15 - SIGNEY PROBES OK (matching)
		3 PM	33	9	11.6	11.63	–	11	958	16	105°	165°	126°				
SUNDAY	7/30	5 AM	33	8	11.5	11.39	–	11	1128	16	95°	155°	127°				Refilled Acid
		1:30 PM	32	7	11.8	11.12	–	–	504	22	115	115	124°				
		PM															

AKC-0012718