REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° OAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS, PROBLEMS, & REMARKS (W/□#)
MONDAY	7/10	7 AM	7	10	12.1	10.72	—	11	1502	29	125°	135°	123°				
		3 PM	7	9	11.6	11.27	—	—	417	35	120°	150°	120°				
		11PM	6	8	11.0	11.42	—	—	923	38	100°	155°	124°				
TUESDAY	7/11	7 AM	6	5	11.6	10.93	—	11	1340	45	120	160°	122°				
		3 PM	6	17	10.0	10.66	—	—	480	6	125°	160°	123°				
		11PM	6	13	10.1	10.67	—	—	888	14	125°	160°	122°				
WEDNESDAY	7/12	7 AM	5	11	11.1	10.47	—	—	1410	24	125°	150°	122°				Rechanged Acid Tanks 2 Red Lights
		3 PM	5	9	9.5	10.50	—	—	477	10	125°	150°	128°				
		11PM	4	5	11.9	10.71	—	—	1133	21	125°	150°	120°				
THURSDAY	7/13	7 AM	3	4	11.9	9.96	—	10	1587	33	125°	150°	125°				Rechanged Caustic Barrell Rechanged Slac. Tank Empty Pac Press
		3 PM	33	15	11.3	10.67	—	—	598	13	125°	150	120°				
		11PM	33	12	10.9	10.83	—	—	1256	22	125°	150°	124°				
FRIDAY	7/14	7 AM	33	11	11.1	10.75	—	11	1594	31	125	150	124°				
		3 PM	31	10	10.2	10.90	—	11	719	20	125°	150°	127°				
		11PM	31	8	9.7	9.34	—	—	1449	34	125°	150°	125				
SATURDAY	7/15	5 AM	30	7	9.9	9.24			1449	39	115°	140°	125°				
		1 PM	30	5	11.5	11.17			560	13	125°	150°	123°				
		7 PM	29	4	11.5	11.10	—	—	949	22	125°	155°	129°				
SUNDAY	7/16	5 AM	28	3	5.9	11.18	—	11	1250	36	125	150°	123°				10:30-11:00 Ph in metro dropped due to Acid Straps Being Cleaned & Drained Into metro Ph 5.5 no discharge Connected Acid Ph 11.5
		12:30 PM	28	15	12.1	11.11	—	—	1189	15	120	150	128°				
		PM	27	14	12.0	11.8	—	—	1697	26	125°	155°	122°				

AKC-0012721

Adjustable
[illegible]
Pipt = 137.90
1 Day = 19.50

1
6:45
4:45
3:45
2:45
1:45