DAILY LOG

REF. DWG NO. 500-0007 REV. A 1594

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° OAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS
MONDAY	7-3-95	7:30 AM	14	2	12.0	11.19			1204	28	130°	155°	129°			
		3 PM	13	15	10.6	10.37	–	–	1066	23	125°	150°	120°			
		11PM	13	12	11.4	10.46	–	–	1613	30	125°	150°	123°			
TUESDAY	7-4	7 AM	~~15~~	~~11~~	~~11.0~~	~~10.70~~	~~–~~	~~10~~	~~1754~~	~~36~~	~~100°~~	~~126°~~	~~113°~~			
		3 PM														
		11PM														
WEDNESDAY	7/5	7 AM	13	11	11.0	10.20	–	10	1754	36	100°	120°	113			
		3 PM	12	10	11.7	10.81	–	–	1080	16	120°	140°	128°			
		11PM	11	8	9.7	10.80	–	10.5	1660	22	125°	150°	126°			
THURSDAY	7-6	7 AM	11	7	9.8	10.64	–	–	1929	33	125°	155°	120°			
		3 PM	11	7	12.1	10.33			1610	11	125°	155°	126°			
		11PM	10	7	10.1	10.73	–	–	1216	17	125°	155°	129°			
FRIDAY	7/7	7 AM	9	7	9.8	11.0			1804	28	125°	155°	127°			
		3 PM	9	7	12.1	10.77			348	10	125°	155°	123°			
		11PM	9	6	9.5	10.83			934	18	125°	155°	130°			
SATURDAY	7/8	AM							(934)							
		3 PM	8	5	11.6	10.87	–	11	1702	38	110°	140°	120°			
		11PM	7	4	9.7	10.62	–	–	2572	46	125°	125°	122			
SUNDAY	7/9	7:30 AM	7	2	11.3	10.50	–	11	1687 / 2621	51	120°	120°	147			
		1:30 PM	6	15	11.2	10.45	–	11	443	3	120	125°	130			
		8 PM	6	14	11.8	10.89	–	–	883	14	125	130	127°			

COMMENTS, PROBLEMS & REMARKS (W/O#)

RED LIGHT 11:00 pm

Holiday

Pre Press stalled
Empire Pre Press

9:30 FLOC RATE CHG'D TO 75ML/75SEC WAS 85ML/150 SEC.

Red Light 8:00PM

Red Light 4:00

not reset
1 5 11
8 8 81
9 3 4
1687