Station	Sample ID	Date	Analyte	Method	Result	Units	Qualifier
Effluent-Tote 1	E1	10/5/2009	Dissolved Oxygen	YSI 556	0.39	mg/L	
Effluent-Tote 1	E1	10/5/2009	Flow	Visual flow meter	3	gpm	
Effluent-Tote 1	E1	10/5/2009	ORP	YSI 556	-375	mV	
Effluent-Tote 1	E1	10/5/2009	pH	YSI 556	8.81	su	
Effluent-Tote 1	E1	10/5/2009	Specific Conductivity	YSI 556	343	uS/cm	
Effluent-Tote 1	E1	10/5/2009	Temperature	YSI 556	9.91	C	
Influent	LSS-SP-N	10/5/2009	Dissolved Oxygen	YSI 556	8.8	mg/L	
Influent	LSS-SP-N	10/5/2009	Iron, Ferrous	HACH Colorimeter	0	mg/L	
Influent	LSS-SP-N	10/5/2009	Iron, Total	HACH Colorimeter	0.06	mg/L	
Influent	LSS-SP-N	10/5/2009	ORP	YSI 556	105.4	mV	
Influent	LSS-SP-N	10/5/2009	pH	YSI 556	7.69	su	
Influent	LSS-SP-N	10/5/2009	Specific Conductivity	YSI 556	362	uS/cm	
Influent	LSS-SP-N	10/5/2009	Temperature	YSI 556	10.07	C	
Influent	LSS-SP-N	10/5/2009	Turbidity	HACH 2100P	0.53	NTU	
Pond	PD	10/5/2009	Dissolved Oxygen	YSI 556	6.06	mg/L	
Pond	PD	10/5/2009	Iron, Ferrous	HACH Colorimeter	0.09	mg/L	
Pond	PD	10/5/2009	Iron, Total	HACH Colorimeter	0.39	mg/L	
Pond	PD	10/5/2009	ORP	YSI 556	-45.1	mV	
Pond	PD	10/5/2009	pH	YSI 556	8.29	su	
Pond	PD	10/5/2009	Specific Conductivity	YSI 556	305	uS/cm	
Pond	PD	10/5/2009	Temperature	YSI 556	6.67	C	
Effluent-Tote 1	E1	10/6/2009	Dissolved Oxygen	YSI 556	0.39	mg/L	
Effluent-Tote 1	E1	10/6/2009	Flow	Visual flow meter	3	gpm	
Effluent-Tote 1	E1	10/6/2009	ORP	YSI 556	-309.4	mV	
Effluent-Tote 1	E1	10/6/2009	pH	YSI 556	8.6	su	
Effluent-Tote 1	E1	10/6/2009	Specific Conductivity	YSI 556	369	uS/cm	
Effluent-Tote 1	E1	10/6/2009	Temperature	YSI 556	9.88	C	
Influent	LSS-SP-N	10/6/2009	Dissolved Oxygen	YSI 556	9	mg/L	
Influent	LSS-SP-N	10/6/2009	Iron, Ferrous	HACH Colorimeter	0	mg/L	
Influent	LSS-SP-N	10/6/2009	Iron, Total	HACH Colorimeter	0	mg/L	
Influent	LSS-SP-N	10/6/2009	ORP	YSI 556	160.4	mV	
Influent	LSS-SP-N	10/6/2009	pH	YSI 556	7.71	su	
Influent	LSS-SP-N	10/6/2009	Specific Conductivity	YSI 556	374	uS/cm	
Influent	LSS-SP-N	10/6/2009	Temperature	YSI 556	10	C	
Influent	LSS-SP-N	10/6/2009	Turbidity	HACH 2100P	1.93	NTU	
Pond	PD	10/6/2009	Dissolved Oxygen	YSI 556	5.37	mg/L	
Pond	PD	10/6/2009	Iron, Ferrous	HACH Colorimeter	0.03	mg/L	
Pond	PD	10/6/2009	Iron, Total	HACH Colorimeter	0.29	mg/L	
Pond	PD	10/6/2009	ORP	YSI 556	-87.9	mV	
Pond	PD	10/6/2009	pH	YSI 556	8.23	su	
Pond	PD	10/6/2009	Specific Conductivity	YSI 556	335	uS/cm	
Pond	PD	10/6/2009	Temperature	YSI 556	6	C	
Pond Inlet	PI	10/6/2009	Dissolved Oxygen	YSI 556	4.94	mg/L	
Pond Inlet	PI	10/6/2009	ORP	YSI 556	-95.5	mV	
Pond Inlet	PI	10/6/2009	pH	YSI 556	8.31	su	
Pond Inlet	PI	10/6/2009	Specific Conductivity	YSI 556	345	uS/cm	
Pond Inlet	PI	10/6/2009	Temperature	YSI 556	5.97	C	
Pond Outlet	PO	10/6/2009	Dissolved Oxygen	YSI 556	5.91	mg/L	
Pond Outlet	PO	10/6/2009	ORP	YSI 556	-44.1	mV	
Pond Outlet	PO	10/6/2009	pH	YSI 556	7.95	su	
Pond Outlet	PO	10/6/2009	Specific Conductivity	YSI 556	320	uS/cm	
Pond Outlet	PO	10/6/2009	Temperature	YSI 556	5.48	C	
Effluent-Tote 1	E1	10/7/2009	Dissolved Oxygen	YSI 556	0.3	mg/L	
Effluent-Tote 1	E1	10/7/2009	Flow	Visual flow meter	3	gpm	
Effluent-Tote 1	E1	10/7/2009	ORP	YSI 556	-360.2	mV	
Effluent-Tote 1	E1	10/7/2009	pH	YSI 556	8.54	su	
Effluent-Tote 1	E1	10/7/2009	Specific Conductivity	YSI 556	387	uS/cm	
Effluent-Tote 1	E1	10/7/2009	Temperature	YSI 556	10.15	C	
Influent	LSS-SP-N	10/7/2009	Dissolved Oxygen	YSI 556	9.06	mg/L	
Influent	LSS-SP-N	10/7/2009	Iron, Ferrous	HACH Colorimeter	0.05	mg/L	

Station	Sample ID	Date	Analyte	Method	Result	Units	Qualifier
Influent	LSS-SP-N	10/7/2009	Iron, Total	HACH Colorimeter	0.1	mg/L	
Influent	LSS-SP-N	10/7/2009	ORP	YSI 556	372.1	mV	
Influent	LSS-SP-N	10/7/2009	pH	YSI 556	7.63	su	
Influent	LSS-SP-N	10/7/2009	Specific Conductivity	YSI 556	387	uS/cm	
Influent	LSS-SP-N	10/7/2009	Temperature	YSI 556	9.99	C	
Influent	LSS-SP-N	10/7/2009	Turbidity	HACH 2100P	1.69	NTU	
Pond	PD	10/7/2009	Dissolved Oxygen	YSI 556	5.73	mg/L	
Pond	PD	10/7/2009	Iron, Ferrous	HACH Colorimeter	0.02	mg/L	
Pond	PD	10/7/2009	Iron, Total	HACH Colorimeter	0.34	mg/L	
Pond	PD	10/7/2009	ORP	YSI 556	-89.4	mV	
Pond	PD	10/7/2009	pH	YSI 556	8.14	su	
Pond	PD	10/7/2009	Specific Conductivity	YSI 556	357	uS/cm	
Pond	PD	10/7/2009	Temperature	YSI 556	5.36	C	
Pond Inlet	PI	10/7/2009	Dissolved Oxygen	YSI 556	5.18	mg/L	
Pond Inlet	PI	10/7/2009	ORP	YSI 556	-105.8	mV	
Pond Inlet	PI	10/7/2009	pH	YSI 556	8.19	su	
Pond Inlet	PI	10/7/2009	Specific Conductivity	YSI 556	366	uS/cm	
Pond Inlet	PI	10/7/2009	Temperature	YSI 556	5.34	C	
Pond Outlet	PO	10/7/2009	Dissolved Oxygen	YSI 556	5.82	mg/L	
Pond Outlet	PO	10/7/2009	ORP	YSI 556	-71.1	mV	
Pond Outlet	PO	10/7/2009	pH	YSI 556	8.11	su	
Pond Outlet	PO	10/7/2009	Specific Conductivity	YSI 556	349	uS/cm	
Pond Outlet	PO	10/7/2009	Temperature	YSI 556	5.7	C	
Effluent-Tote 1	E1	10/8/2009	Dissolved Oxygen	YSI 556	0.3	mg/L	
Effluent-Tote 1	E1	10/8/2009	Flow	Visual flow meter	3	gpm	
Effluent-Tote 1	E1	10/8/2009	ORP	YSI 556	-306.2	mV	
Effluent-Tote 1	E1	10/8/2009	pH	YSI 556	8.43	su	
Effluent-Tote 1	E1	10/8/2009	Specific Conductivity	YSI 556	391	uS/cm	
Effluent-Tote 1	E1	10/8/2009	Temperature	YSI 556	10.22	C	
Effluent-Tote 1	E1	10/8/2009	Turbidity	HACH 2100P	8.58	NTU	
Influent	LSS-SP-N	10/8/2009	Dissolved Oxygen	YSI 556	8.95	mg/L	
Influent	LSS-SP-N	10/8/2009	Iron, Ferrous	HACH Colorimeter	0.06	mg/L	
Influent	LSS-SP-N	10/8/2009	Iron, Total	HACH Colorimeter	0.06	mg/L	
Influent	LSS-SP-N	10/8/2009	ORP	YSI 556	152.5	mV	
Influent	LSS-SP-N	10/8/2009	pH	YSI 556	7.65	su	
Influent	LSS-SP-N	10/8/2009	Specific Conductivity	YSI 556	388	uS/cm	
Influent	LSS-SP-N	10/8/2009	Temperature	YSI 556	10.09	C	
Influent	LSS-SP-N	10/8/2009	Turbidity	HACH 2100P	0.72	NTU	
Pond	PD	10/8/2009	Dissolved Oxygen	YSI 556	5.89	mg/L	
Pond	PD	10/8/2009	ORP	YSI 556	-83.7	mV	
Pond	PD	10/8/2009	pH	YSI 556	8.16	su	
Pond	PD	10/8/2009	Specific Conductivity	YSI 556	363	uS/cm	
Pond	PD	10/8/2009	Temperature	YSI 556	7.57	C	
Pond	PD	10/8/2009	Turbidity	HACH 2100P	12.3	NTU	
Pond Inlet	PI	10/8/2009	Dissolved Oxygen	YSI 556	5.33	mg/L	
Pond Inlet	PI	10/8/2009	ORP	YSI 556	-103.7	mV	
Pond Inlet	PI	10/8/2009	pH	YSI 556	8.11	su	
Pond Inlet	PI	10/8/2009	Specific Conductivity	YSI 556	372	uS/cm	
Pond Inlet	PI	10/8/2009	Temperature	YSI 556	7.79	C	
Pond Inlet	PI	10/8/2009	Turbidity	HACH 2100P	21	NTU	
Pond Outlet	PO	10/8/2009	Dissolved Oxygen	YSI 556	6.25	mg/L	
Pond Outlet	PO	10/8/2009	ORP	YSI 556	-76.4	mV	
Pond Outlet	PO	10/8/2009	pH	YSI 556	8.14	su	
Pond Outlet	PO	10/8/2009	Specific Conductivity	YSI 556	360	uS/cm	
Pond Outlet	PO	10/8/2009	Temperature	YSI 556	7.61	C	
Pond Outlet	PO	10/8/2009	Turbidity	HACH 2100P	6.86	NTU	
Effluent-Tote 1	E1	10/9/2009	Dissolved Oxygen	YSI 556	0.3	mg/L	
Effluent-Tote 1	E1	10/9/2009	Flow	Visual flow meter	3	gpm	
Effluent-Tote 1	E1	10/9/2009	ORP	YSI 556	-307.1	mV	
Effluent-Tote 1	E1	10/9/2009	pH	YSI 556	8.44	su	

Station	Sample ID	Date	Analyte	Method	Result	Units	Qualifier
Effluent-Tote 1	E1	10/9/2009	Specific Conductivity	YSI 556	379	uS/cm	
Effluent-Tote 1	E1	10/9/2009	Temperature	YSI 556	9.78	C	
Effluent-Tote 1	E1	10/9/2009	Turbidity	HACH 2100P	5.36	NTU	
Influent	LSS-SP-N	10/9/2009	Dissolved Oxygen	YSI 556	8.77	mg/L	
Influent	LSS-SP-N	10/9/2009	Iron, Ferrous	HACH Colorimeter	0.02	mg/L	
Influent	LSS-SP-N	10/9/2009	Iron, Total	HACH Colorimeter	0.04	mg/L	
Influent	LSS-SP-N	10/9/2009	ORP	YSI 556	155.4	mV	
Influent	LSS-SP-N	10/9/2009	pH	YSI 556	7.55	su	
Influent	LSS-SP-N	10/9/2009	Specific Conductivity	YSI 556	376	uS/cm	
Influent	LSS-SP-N	10/9/2009	Temperature	YSI 556	9.93	C	
Influent	LSS-SP-N	10/9/2009	Turbidity	HACH 2100P	1.5	NTU	
Pond	PD	10/9/2009	Dissolved Oxygen	YSI 556	5.95	mg/L	
Pond	PD	10/9/2009	ORP	YSI 556	-74.3	mV	
Pond	PD	10/9/2009	pH	YSI 556	8.16	su	
Pond	PD	10/9/2009	Specific Conductivity	YSI 556	354	uS/cm	
Pond	PD	10/9/2009	Temperature	YSI 556	6.24	C	
Pond	PD	10/9/2009	Turbidity	HACH 2100P	8.94	NTU	
Pond Inlet	PI	10/9/2009	Dissolved Oxygen	YSI 556	5.07	mg/L	
Pond Inlet	PI	10/9/2009	ORP	YSI 556	-89.5	mV	
Pond Inlet	PI	10/9/2009	pH	YSI 556	8.1	su	
Pond Inlet	PI	10/9/2009	Specific Conductivity	YSI 556	360	uS/cm	
Pond Inlet	PI	10/9/2009	Temperature	YSI 556	6.38	C	
Pond Inlet	PI	10/9/2009	Turbidity	HACH 2100P	21.7	NTU	
Pond Outlet	PO	10/9/2009	Dissolved Oxygen	YSI 556	6.88	mg/L	
Pond Outlet	PO	10/9/2009	Iron, Ferrous	HACH Colorimeter	0.01	mg/L	
Pond Outlet	PO	10/9/2009	Iron, Total	HACH Colorimeter	0.1	mg/L	
Pond Outlet	PO	10/9/2009	ORP	YSI 556	-44.7	mV	
Pond Outlet	PO	10/9/2009	pH	YSI 556	8.22	su	
Pond Outlet	PO	10/9/2009	Specific Conductivity	YSI 556	353	uS/cm	
Pond Outlet	PO	10/9/2009	Temperature	YSI 556	5.84	C	
Pond Outlet	PO	10/9/2009	Turbidity	HACH 2100P	5.96	NTU	
Effluent-Tote 1	E1	10/10/2009	Dissolved Oxygen	YSI 556	0.25	mg/L	
Effluent-Tote 1	E1	10/10/2009	Flow	Visual flow meter	3	gpm	
Effluent-Tote 1	E1	10/10/2009	ORP	YSI 556	-315.1	mV	
Effluent-Tote 1	E1	10/10/2009	pH	YSI 556	8.46	su	
Effluent-Tote 1	E1	10/10/2009	Specific Conductivity	YSI 556	388	uS/cm	
Effluent-Tote 1	E1	10/10/2009	Temperature	YSI 556	9.76	C	
Effluent-Tote 1	E1	10/10/2009	Turbidity	HACH 2100P	6.73	NTU	
Influent	LSS-SP-N	10/10/2009	Dissolved Oxygen	YSI 556	8.77	mg/L	
Influent	LSS-SP-N	10/10/2009	ORP	YSI 556	122.4	mV	
Influent	LSS-SP-N	10/10/2009	pH	YSI 556	7.64	su	
Influent	LSS-SP-N	10/10/2009	Specific Conductivity	YSI 556	386	uS/cm	
Influent	LSS-SP-N	10/10/2009	Temperature	YSI 556	9.91	C	
Influent	LSS-SP-N	10/10/2009	Turbidity	HACH 2100P	0.77	NTU	
Pond	PD	10/10/2009	Dissolved Oxygen	YSI 556	5.66	mg/L	
Pond	PD	10/10/2009	ORP	YSI 556	-82.9	mV	
Pond	PD	10/10/2009	pH	YSI 556	8.11	su	
Pond	PD	10/10/2009	Specific Conductivity	YSI 556	368	uS/cm	
Pond	PD	10/10/2009	Temperature	YSI 556	5.08	C	
Pond	PD	10/10/2009	Turbidity	HACH 2100P	12	NTU	
Pond Inlet	PI	10/10/2009	Dissolved Oxygen	YSI 556	5.15	mg/L	
Pond Inlet	PI	10/10/2009	ORP	YSI 556	-124.4	mV	
Pond Inlet	PI	10/10/2009	pH	YSI 556	8.06	su	
Pond Inlet	PI	10/10/2009	Specific Conductivity	YSI 556	372	uS/cm	
Pond Inlet	PI	10/10/2009	Temperature	YSI 556	6.03	C	
Pond Inlet	PI	10/10/2009	Turbidity	HACH 2100P	46.5	NTU	
Pond Outlet	PO	10/10/2009	Dissolved Oxygen	YSI 556	5.82	mg/L	
Pond Outlet	PO	10/10/2009	ORP	YSI 556	-59.5	mV	
Pond Outlet	PO	10/10/2009	pH	YSI 556	8.15	su	
Pond Outlet	PO	10/10/2009	Specific Conductivity	YSI 556	364	uS/cm	

Station	Sample ID	Date	Analyte	Method	Result	Units	Qualifier
Pond Outlet	PO	10/10/2009	Temperature	YSI 556	5.09	C	
Pond Outlet	PO	10/10/2009	Turbidity	HACH 2100P	8.54	NTU	
Discharge	EF	10/11/2009	Dissolved Oxygen	YSI 556	7.52	mg/L	
Discharge	EF	10/11/2009	Iron, Ferrous	HACH Colorimeter	0.03	mg/L	
Discharge	EF	10/11/2009	Iron, Total	HACH Colorimeter	0.06	mg/L	
Discharge	EF	10/11/2009	ORP	YSI 556	17	mV	
Discharge	EF	10/11/2009	pH	YSI 556	8.2	su	
Discharge	EF	10/11/2009	Specific Conductivity	YSI 556	358	uS/cm	
Discharge	EF	10/11/2009	Temperature	YSI 556	4.19	C	
Discharge	EF	10/11/2009	Turbidity	HACH 2100P	10.2	NTU	
Effluent-Tote 1	E1	10/11/2009	Dissolved Oxygen	YSI 556	0.3	mg/L	
Effluent-Tote 1	E1	10/11/2009	Flow	Visual flow meter	3	gpm	
Effluent-Tote 1	E1	10/11/2009	ORP	YSI 556	-313.7	mV	
Effluent-Tote 1	E1	10/11/2009	pH	YSI 556	8.52	su	
Effluent-Tote 1	E1	10/11/2009	Specific Conductivity	YSI 556	378	uS/cm	
Effluent-Tote 1	E1	10/11/2009	Temperature	YSI 556	9.52	C	
Effluent-Tote 1	E1	10/11/2009	Turbidity	HACH 2100P	11.3	NTU	
Influent	LSS-SP-N	10/11/2009	Dissolved Oxygen	YSI 556	8.94	mg/L	
Influent	LSS-SP-N	10/11/2009	ORP	YSI 556	138.2	mV	
Influent	LSS-SP-N	10/11/2009	pH	YSI 556	7.64	su	
Influent	LSS-SP-N	10/11/2009	Specific Conductivity	YSI 556	381	uS/cm	
Influent	LSS-SP-N	10/11/2009	Temperature	YSI 556	9.84	C	
Influent	LSS-SP-N	10/11/2009	Turbidity	HACH 2100P	0.67	NTU	
Pond	PD	10/11/2009	Dissolved Oxygen	YSI 556	5.6	mg/L	
Pond	PD	10/11/2009	Iron, Ferrous	HACH Colorimeter	0.03	mg/L	
Pond	PD	10/11/2009	Iron, Total	HACH Colorimeter	0.06	mg/L	
Pond	PD	10/11/2009	ORP	YSI 556	-12.4	mV	
Pond	PD	10/11/2009	pH	YSI 556	8.17	su	
Pond	PD	10/11/2009	Specific Conductivity	YSI 556	362	uS/cm	
Pond	PD	10/11/2009	Temperature	YSI 556	5.55	C	
Pond	PD	10/11/2009	Turbidity	HACH 2100P	8.72	NTU	
Pond Inlet	PI	10/11/2009	Dissolved Oxygen	YSI 556	4.95	mg/L	
Pond Inlet	PI	10/11/2009	Iron, Ferrous	HACH Colorimeter	0.09	mg/L	
Pond Inlet	PI	10/11/2009	Iron, Total	HACH Colorimeter	0.24	mg/L	
Pond Inlet	PI	10/11/2009	ORP	YSI 556	-55.4	mV	
Pond Inlet	PI	10/11/2009	pH	YSI 556	8.17	su	
Pond Inlet	PI	10/11/2009	Specific Conductivity	YSI 556	370	uS/cm	
Pond Inlet	PI	10/11/2009	Temperature	YSI 556	6.04	C	
Pond Inlet	PI	10/11/2009	Turbidity	HACH 2100P	17.5	NTU	
Pond Outlet	PO	10/11/2009	Dissolved Oxygen	YSI 556	6.02	mg/L	
Pond Outlet	PO	10/11/2009	Iron, Ferrous	HACH Colorimeter	0.01	mg/L	
Pond Outlet	PO	10/11/2009	Iron, Total	HACH Colorimeter	0.11	mg/L	
Pond Outlet	PO	10/11/2009	ORP	YSI 556	-0.7	mV	
Pond Outlet	PO	10/11/2009	pH	YSI 556	8.18	su	
Pond Outlet	PO	10/11/2009	Specific Conductivity	YSI 556	361	uS/cm	
Pond Outlet	PO	10/11/2009	Temperature	YSI 556	5.47	C	
Pond Outlet	PO	10/11/2009	Turbidity	HACH 2100P	7.42	NTU	
Discharge	EF	10/12/2009	Dissolved Oxygen	YSI 556	8.2	mg/L	
Discharge	EF	10/12/2009	Iron, Ferrous	HACH Colorimeter	0.02	mg/L	
Discharge	EF	10/12/2009	Iron, Total	HACH Colorimeter	0.04	mg/L	
Discharge	EF	10/12/2009	ORP	YSI 556	82.2	mV	
Discharge	EF	10/12/2009	pH	YSI 556	8.2	su	
Discharge	EF	10/12/2009	Specific Conductivity	YSI 556	361	uS/cm	
Discharge	EF	10/12/2009	Temperature	YSI 556	3.69	C	
Discharge	EF	10/12/2009	Turbidity	HACH 2100P	4.3	NTU	
Effluent-Tote 1	E1	10/12/2009	Dissolved Oxygen	YSI 556	0.19	mg/L	
Effluent-Tote 1	E1	10/12/2009	Flow	Visual flow meter	3	gpm	
Effluent-Tote 1	E1	10/12/2009	ORP	YSI 556	-190.3	mV	
Effluent-Tote 1	E1	10/12/2009	pH	YSI 556	8.47	su	
Effluent-Tote 1	E1	10/12/2009	Specific Conductivity	YSI 556	380	uS/cm	

Station	Sample ID	Date	Analyte	Method	Result	Units	Qualifier
Effluent-Tote 1	E1	10/12/2009	Temperature	YSI 556	9.74	C	
Effluent-Tote 1	E1	10/12/2009	Turbidity	HACH 2100P	7.44	NTU	
Influent	LSS-SP-N	10/12/2009	Dissolved Oxygen	YSI 556	8.7	mg/L	
Influent	LSS-SP-N	10/12/2009	ORP	YSI 556	-33.7	mV	
Influent	LSS-SP-N	10/12/2009	pH	YSI 556	7.71	su	
Influent	LSS-SP-N	10/12/2009	Specific Conductivity	YSI 556	383	uS/cm	
Influent	LSS-SP-N	10/12/2009	Temperature	YSI 556	10.02	C	
Influent	LSS-SP-N	10/12/2009	Turbidity	HACH 2100P	0.38	NTU	
Pond	PD	10/12/2009	Dissolved Oxygen	YSI 556	6.13	mg/L	
Pond	PD	10/12/2009	ORP	YSI 556	29.5	mV	
Pond	PD	10/12/2009	pH	YSI 556	8.2	su	
Pond	PD	10/12/2009	Specific Conductivity	YSI 556	364	uS/cm	
Pond	PD	10/12/2009	Temperature	YSI 556	4.35	C	
Pond	PD	10/12/2009	Turbidity	HACH 2100P	6.63	NTU	
Pond Inlet	PI	10/12/2009	Dissolved Oxygen	YSI 556	5.59	mg/L	
Pond Inlet	PI	10/12/2009	ORP	YSI 556	1.1	mV	
Pond Inlet	PI	10/12/2009	pH	YSI 556	8.21	su	
Pond Inlet	PI	10/12/2009	Specific Conductivity	YSI 556	366	uS/cm	
Pond Inlet	PI	10/12/2009	Temperature	YSI 556	4.75	C	
Pond Inlet	PI	10/12/2009	Turbidity	HACH 2100P	14.6	NTU	
Pond Outlet	PO	10/12/2009	Dissolved Oxygen	YSI 556	6.16	mg/L	
Pond Outlet	PO	10/12/2009	ORP	YSI 556	41.6	mV	
Pond Outlet	PO	10/12/2009	pH	YSI 556	8.19	su	
Pond Outlet	PO	10/12/2009	Specific Conductivity	YSI 556	363	uS/cm	
Pond Outlet	PO	10/12/2009	Temperature	YSI 556	4.38	C	
Pond Outlet	PO	10/12/2009	Turbidity	HACH 2100P	5.31	NTU	
Discharge	EF	10/13/2009	Dissolved Oxygen	YSI 556	7.71	mg/L	
Discharge	EF	10/13/2009	Iron, Ferrous	HACH Colorimeter	0.03	mg/L	
Discharge	EF	10/13/2009	Iron, Total	HACH Colorimeter	0.21	mg/L	
Discharge	EF	10/13/2009	ORP	YSI 556	80.9	mV	
Discharge	EF	10/13/2009	pH	YSI 556	8.23	su	
Discharge	EF	10/13/2009	Specific Conductivity	YSI 556	368	uS/cm	
Discharge	EF	10/13/2009	Temperature	YSI 556	11.75	C	
Discharge	EF	10/13/2009	Turbidity	HACH 2100P	6.5	NTU	
Effluent-Tote 1	E1	10/13/2009	Dissolved Oxygen	YSI 556	0.4	mg/L	
Effluent-Tote 1	E1	10/13/2009	Flow	Visual flow meter	3	gpm	
Effluent-Tote 1	E1	10/13/2009	ORP	YSI 556	-267.7	mV	
Effluent-Tote 1	E1	10/13/2009	pH	YSI 556	8.4	su	
Effluent-Tote 1	E1	10/13/2009	Specific Conductivity	YSI 556	383	uS/cm	
Effluent-Tote 1	E1	10/13/2009	Temperature	YSI 556	10.7	C	
Effluent-Tote 1	E1	10/13/2009	Turbidity	HACH 2100P	8.42	NTU	
Effluent-Tote 2	E2	10/13/2009	Flow	Visual flow meter	3	gpm	
Influent	LSS-SP-N	10/13/2009	Dissolved Oxygen	YSI 556	8.82	mg/L	
Influent	LSS-SP-N	10/13/2009	ORP	YSI 556	-17.9	mV	
Influent	LSS-SP-N	10/13/2009	pH	YSI 556	7.71	su	
Influent	LSS-SP-N	10/13/2009	Specific Conductivity	YSI 556	383	uS/cm	
Influent	LSS-SP-N	10/13/2009	Temperature	YSI 556	10.22	C	
Influent	LSS-SP-N	10/13/2009	Turbidity	HACH 2100P	0.52	NTU	
Pond	PD	10/13/2009	Dissolved Oxygen	YSI 556	6.33	mg/L	
Pond	PD	10/13/2009	ORP	YSI 556	9.8	mV	
Pond	PD	10/13/2009	pH	YSI 556	8.21	su	
Pond	PD	10/13/2009	Specific Conductivity	YSI 556	366	uS/cm	
Pond	PD	10/13/2009	Temperature	YSI 556	7.51	C	
Pond	PD	10/13/2009	Turbidity	HACH 2100P	11.2	NTU	
Pond Inlet	PI	10/13/2009	Dissolved Oxygen	YSI 556	5.79	mg/L	
Pond Inlet	PI	10/13/2009	ORP	YSI 556	-8.6	mV	
Pond Inlet	PI	10/13/2009	pH	YSI 556	8.2	su	
Pond Inlet	PI	10/13/2009	Specific Conductivity	YSI 556	366	uS/cm	
Pond Inlet	PI	10/13/2009	Temperature	YSI 556	7.4	C	
Pond Inlet	PI	10/13/2009	Turbidity	HACH 2100P	14.6	NTU	

Station	Sample ID	Date	Analyte	Method	Result	Units	Qualifier
Pond Outlet	PO	10/13/2009	Dissolved Oxygen	YSI 556	7.12	mg/L	
Pond Outlet	PO	10/13/2009	ORP	YSI 556	14.9	mV	
Pond Outlet	PO	10/13/2009	pH	YSI 556	8.2	su	
Pond Outlet	PO	10/13/2009	Specific Conductivity	YSI 556	367	uS/cm	
Pond Outlet	PO	10/13/2009	Temperature	YSI 556	8	C	
Pond Outlet	PO	10/13/2009	Turbidity	HACH 2100P	9.27	NTU	
Discharge	EF	10/14/2009	Dissolved Oxygen	YSI 556	7.77	mg/L	
Discharge	EF	10/14/2009	Iron, Ferrous	HACH Colorimeter	0.28	mg/L	
Discharge	EF	10/14/2009	Iron, Total	HACH Colorimeter	0.36	mg/L	
Discharge	EF	10/14/2009	ORP	YSI 556	-39.4	mV	
Discharge	EF	10/14/2009	pH	YSI 556	7.93	su	
Discharge	EF	10/14/2009	Specific Conductivity	YSI 556	347	uS/cm	
Discharge	EF	10/14/2009	Temperature	YSI 556	7.5	C	
Discharge	EF	10/14/2009	Turbidity	HACH 2100P	55.8	NTU	
Effluent-Tote 1	E1	10/14/2009	Dissolved Oxygen	YSI 556	0.39	mg/L	
Effluent-Tote 1	E1	10/14/2009	Flow	Visual flow meter	3	gpm	
Effluent-Tote 1	E1	10/14/2009	ORP	YSI 556	-273.6	mV	
Effluent-Tote 1	E1	10/14/2009	pH	YSI 556	8.37	su	
Effluent-Tote 1	E1	10/14/2009	Specific Conductivity	YSI 556	383	uS/cm	
Effluent-Tote 1	E1	10/14/2009	Temperature	YSI 556	9.75	C	
Effluent-Tote 1	E1	10/14/2009	Turbidity	HACH 2100P	3.97	NTU	
Effluent-Tote 2	E2	10/14/2009	Flow	Visual flow meter	3	gpm	
Influent	LSS-SP-N	10/14/2009	Dissolved Oxygen	YSI 556	8.7	mg/L	
Influent	LSS-SP-N	10/14/2009	ORP	YSI 556	31.8	mV	
Influent	LSS-SP-N	10/14/2009	pH	YSI 556	7.64	su	
Influent	LSS-SP-N	10/14/2009	Specific Conductivity	YSI 556	383	uS/cm	
Influent	LSS-SP-N	10/14/2009	Temperature	YSI 556	9.89	C	
Influent	LSS-SP-N	10/14/2009	Turbidity	HACH 2100P	0.6	NTU	
Pond	PD	10/14/2009	Dissolved Oxygen	YSI 556	5.28	mg/L	
Pond	PD	10/14/2009	ORP	YSI 556	-94.3	mV	
Pond	PD	10/14/2009	pH	YSI 556	7.82	su	
Pond	PD	10/14/2009	Specific Conductivity	YSI 556	358	uS/cm	
Pond	PD	10/14/2009	Temperature	YSI 556	7.9	C	
Pond	PD	10/14/2009	Turbidity	HACH 2100P	50.4	NTU	
Pond Inlet	PI	10/14/2009	Dissolved Oxygen	YSI 556	4.79	mg/L	
Pond Inlet	PI	10/14/2009	ORP	YSI 556	-142.7	mV	
Pond Inlet	PI	10/14/2009	pH	YSI 556	8.06	su	
Pond Inlet	PI	10/14/2009	Specific Conductivity	YSI 556	354	uS/cm	
Pond Inlet	PI	10/14/2009	Temperature	YSI 556	8.52	C	
Pond Inlet	PI	10/14/2009	Turbidity	HACH 2100P	53.8	NTU	
Pond Outlet	PO	10/14/2009	Dissolved Oxygen	YSI 556	5.74	mg/L	
Pond Outlet	PO	10/14/2009	ORP	YSI 556	-55.2	mV	
Pond Outlet	PO	10/14/2009	pH	YSI 556	7.84	su	
Pond Outlet	PO	10/14/2009	Specific Conductivity	YSI 556	357	uS/cm	
Pond Outlet	PO	10/14/2009	Temperature	YSI 556	7.95	C	
Pond Outlet	PO	10/14/2009	Turbidity	HACH 2100P	44	NTU	
Discharge	EF	10/15/2009	Dissolved Oxygen	YSI 556	6.81	mg/L	
Discharge	EF	10/15/2009	Iron, Ferrous	HACH Colorimeter	0.19	mg/L	
Discharge	EF	10/15/2009	Iron, Total	HACH Colorimeter	0.19	mg/L	
Discharge	EF	10/15/2009	ORP	YSI 556	-22.5	mV	
Discharge	EF	10/15/2009	pH	YSI 556	8.06	su	
Discharge	EF	10/15/2009	Specific Conductivity	YSI 556	358	uS/cm	
Discharge	EF	10/15/2009	Temperature	YSI 556	10.82	C	
Discharge	EF	10/15/2009	Turbidity	HACH 2100P	15.9	NTU	
Effluent-Tote 1	E1	10/15/2009	Dissolved Oxygen	YSI 556	0.36	mg/L	
Effluent-Tote 1	E1	10/15/2009	Flow	Visual flow meter	3	gpm	
Effluent-Tote 1	E1	10/15/2009	ORP	YSI 556	-277.3	mV	
Effluent-Tote 1	E1	10/15/2009	pH	YSI 556	8.43	su	
Effluent-Tote 1	E1	10/15/2009	Specific Conductivity	YSI 556	383	uS/cm	
Effluent-Tote 1	E1	10/15/2009	Temperature	YSI 556	9.97	C	

Station	Sample ID	Date	Analyte	Method	Result	Units	Qualifier
Effluent-Tote 1	E1	10/15/2009	Turbidity	HACH 2100P	7.13	NTU	
Effluent-Tote 2	E2	10/15/2009	Flow	Visual flow meter	2	gpm	
Effluent-Tote 2	E2	10/15/2009	Turbidity	HACH 2100P	15.2	NTU	
Influent	LSS-SP-N	10/15/2009	Dissolved Oxygen	YSI 556	8.87	mg/L	
Influent	LSS-SP-N	10/15/2009	ORP	YSI 556	10.9	mV	
Influent	LSS-SP-N	10/15/2009	pH	YSI 556	7.63	su	
Influent	LSS-SP-N	10/15/2009	Specific Conductivity	YSI 556	383	uS/cm	
Influent	LSS-SP-N	10/15/2009	Temperature	YSI 556	9.99	C	
Influent	LSS-SP-N	10/15/2009	Turbidity	HACH 2100P	1.17	NTU	
Pond	PD	10/15/2009	Dissolved Oxygen	YSI 556	5.29	mg/L	
Pond	PD	10/15/2009	ORP	YSI 556	-54.5	mV	
Pond	PD	10/15/2009	Specific Conductivity	YSI 556	359	uS/cm	
Pond	PD	10/15/2009	Temperature	YSI 556	8.79	C	
Pond	PD	10/15/2009	Turbidity	HACH 2100P	11.4	NTU	
Pond Inlet	PI	10/15/2009	Dissolved Oxygen	YSI 556	4.8	mg/L	
Pond Inlet	PI	10/15/2009	ORP	YSI 556	-95	mV	
Pond Inlet	PI	10/15/2009	pH	YSI 556	8.17	su	
Pond Inlet	PI	10/15/2009	Specific Conductivity	YSI 556	362	uS/cm	
Pond Inlet	PI	10/15/2009	Temperature	YSI 556	8.93	C	
Pond Inlet	PI	10/15/2009	Turbidity	HACH 2100P	18.3	NTU	
Pond Outlet	PO	10/15/2009	Dissolved Oxygen	YSI 556	5.52	mg/L	
Pond Outlet	PO	10/15/2009	ORP	YSI 556	-39.2	mV	
Pond Outlet	PO	10/15/2009	pH	YSI 556	7.96	su	
Pond Outlet	PO	10/15/2009	Specific Conductivity	YSI 556	359	uS/cm	
Pond Outlet	PO	10/15/2009	Temperature	YSI 556	8.96	C	
Pond Outlet	PO	10/15/2009	Turbidity	HACH 2100P	12	NTU	
Discharge	EF	10/16/2009	Dissolved Oxygen	YSI 556	6.46	mg/L	
Discharge	EF	10/16/2009	Iron, Ferrous	HACH Colorimeter	0.09	mg/L	
Discharge	EF	10/16/2009	Iron, Total	HACH Colorimeter	0.05	mg/L	
Discharge	EF	10/16/2009	ORP	YSI 556	-21	mV	
Discharge	EF	10/16/2009	pH	YSI 556	8.19	su	
Discharge	EF	10/16/2009	Specific Conductivity	YSI 556	364	uS/cm	
Discharge	EF	10/16/2009	Temperature	YSI 556	10.49	C	
Discharge	EF	10/16/2009	Turbidity	HACH 2100P	8.15	NTU	
Effluent-Tote 1	E1	10/16/2009	Dissolved Oxygen	YSI 556	0.33	mg/L	
Effluent-Tote 1	E1	10/16/2009	Flow	Visual flow meter	3	gpm	
Effluent-Tote 1	E1	10/16/2009	ORP	YSI 556	-290.3	mV	
Effluent-Tote 1	E1	10/16/2009	pH	YSI 556	8.51	su	
Effluent-Tote 1	E1	10/16/2009	Specific Conductivity	YSI 556	382	uS/cm	
Effluent-Tote 1	E1	10/16/2009	Temperature	YSI 556	10.79	C	
Effluent-Tote 1	E1	10/16/2009	Turbidity	HACH 2100P	9.69	NTU	
Effluent-Tote 2	E2	10/16/2009	Flow	Visual flow meter	3	gpm	
Effluent-Tote 2	E2	10/16/2009	Turbidity	HACH 2100P	16	NTU	
Influent	LSS-SP-N	10/16/2009	Dissolved Oxygen	YSI 556	8.83	mg/L	
Influent	LSS-SP-N	10/16/2009	ORP	YSI 556	52	mV	
Influent	LSS-SP-N	10/16/2009	pH	YSI 556	7.64	su	
Influent	LSS-SP-N	10/16/2009	Specific Conductivity	YSI 556	384	uS/cm	
Influent	LSS-SP-N	10/16/2009	Temperature	YSI 556	10.21	C	
Influent	LSS-SP-N	10/16/2009	Turbidity	HACH 2100P	1.44	NTU	
Pond	PD	10/16/2009	Dissolved Oxygen	YSI 556	5.34	mg/L	
Pond	PD	10/16/2009	ORP	YSI 556	-61.3	mV	
Pond	PD	10/16/2009	Specific Conductivity	YSI 556	365	uS/cm	
Pond	PD	10/16/2009	Temperature	YSI 556	11.5	C	
Pond	PD	10/16/2009	Turbidity	HACH 2100P	10.07	NTU	
Pond Inlet	PI	10/16/2009	Dissolved Oxygen	YSI 556	4.49	mg/L	
Pond Inlet	PI	10/16/2009	ORP	YSI 556	-97.2	mV	
Pond Inlet	PI	10/16/2009	pH	YSI 556	8.14	su	
Pond Inlet	PI	10/16/2009	Specific Conductivity	YSI 556	366	uS/cm	
Pond Inlet	PI	10/16/2009	Temperature	YSI 556	11.2	C	
Pond Inlet	PI	10/16/2009	Turbidity	HACH 2100P	14.9	NTU	

Station	Sample ID	Date	Analyte	Method	Result	Units	Qualifier
Pond Outlet	PO	10/16/2009	Dissolved Oxygen	YSI 556	5.67	mg/L	
Pond Outlet	PO	10/16/2009	ORP	YSI 556	-46.5	mV	
Pond Outlet	PO	10/16/2009	pH	YSI 556	8.16	su	
Pond Outlet	PO	10/16/2009	Specific Conductivity	YSI 556	363	uS/cm	
Pond Outlet	PO	10/16/2009	Temperature	YSI 556	11.44	C	
Pond Outlet	PO	10/16/2009	Turbidity	HACH 2100P	10.1	NTU	
Discharge	EF	10/17/2009	Dissolved Oxygen	YSI 556	6.14	mg/L	
Discharge	EF	10/17/2009	Iron, Ferrous	HACH Colorimeter	0	mg/L	
Discharge	EF	10/17/2009	Iron, Total	HACH Colorimeter	0.47	mg/L	
Discharge	EF	10/17/2009	ORP	YSI 556	-38.3	mV	
Discharge	EF	10/17/2009	pH	YSI 556	8.18	su	
Discharge	EF	10/17/2009	Specific Conductivity	YSI 556	370	uS/cm	
Discharge	EF	10/17/2009	Temperature	YSI 556	13.25	C	
Discharge	EF	10/17/2009	Turbidity	HACH 2100P	10	NTU	
Effluent-Tote 1	E1	10/17/2009	Dissolved Oxygen	YSI 556	0.05	mg/L	
Effluent-Tote 1	E1	10/17/2009	Flow	Visual flow meter	3	gpm	
Effluent-Tote 1	E1	10/17/2009	Iron, Ferrous	HACH Colorimeter	1.14	mg/L	
Effluent-Tote 1	E1	10/17/2009	Iron, Total	HACH Colorimeter	2.78	mg/L	
Effluent-Tote 1	E1	10/17/2009	ORP	YSI 556	-341	mV	
Effluent-Tote 1	E1	10/17/2009	pH	YSI 556	8.68	su	
Effluent-Tote 1	E1	10/17/2009	Specific Conductivity	YSI 556	380	uS/cm	
Effluent-Tote 1	E1	10/17/2009	Temperature	YSI 556	10.49	C	
Effluent-Tote 1	E1	10/17/2009	Turbidity	HACH 2100P	14.6	NTU	
Effluent-Tote 2	E2	10/17/2009	Flow	Visual flow meter	3	gpm	
Effluent-Tote 2	E2	10/17/2009	Turbidity	HACH 2100P	17.1	NTU	
Influent	LSS-SP-N	10/17/2009	Dissolved Oxygen	YSI 556	8.87	mg/L	
Influent	LSS-SP-N	10/17/2009	ORP	YSI 556	-1.2	mV	
Influent	LSS-SP-N	10/17/2009	pH	YSI 556	7.54	su	
Influent	LSS-SP-N	10/17/2009	Specific Conductivity	YSI 556	384	uS/cm	
Influent	LSS-SP-N	10/17/2009	Temperature	YSI 556	10.25	C	
Influent	LSS-SP-N	10/17/2009	Turbidity	HACH 2100P	1.53	NTU	
Pond	PD	10/17/2009	Dissolved Oxygen	YSI 556	4.67	mg/L	
Pond	PD	10/17/2009	ORP	YSI 556	-22.2	mV	
Pond	PD	10/17/2009	Specific Conductivity	YSI 556	370	uS/cm	
Pond	PD	10/17/2009	Temperature	YSI 556	12.8	C	
Pond	PD	10/17/2009	Turbidity	HACH 2100P	11	NTU	
Pond Inlet	PI	10/17/2009	Dissolved Oxygen	YSI 556	5.21	mg/L	
Pond Inlet	PI	10/17/2009	ORP	YSI 556	-105.1	mV	
Pond Inlet	PI	10/17/2009	pH	YSI 556	8.17	su	
Pond Inlet	PI	10/17/2009	Specific Conductivity	YSI 556	378	uS/cm	
Pond Inlet	PI	10/17/2009	Temperature	YSI 556	12	C	
Pond Inlet	PI	10/17/2009	Turbidity	HACH 2100P	10.1	NTU	
Pond Outlet	PO	10/17/2009	Dissolved Oxygen	YSI 556	4.3	mg/L	
Pond Outlet	PO	10/17/2009	ORP	YSI 556	-6.1	mV	
Pond Outlet	PO	10/17/2009	pH	YSI 556	8.17	su	
Pond Outlet	PO	10/17/2009	Specific Conductivity	YSI 556	370	uS/cm	
Pond Outlet	PO	10/17/2009	Temperature	YSI 556	12.22	C	
Pond Outlet	PO	10/17/2009	Turbidity	HACH 2100P	12	NTU	
Discharge	EF	10/18/2009	Dissolved Oxygen	YSI 556	6.64	mg/L	
Discharge	EF	10/18/2009	Iron, Ferrous	HACH Colorimeter	0	mg/L	
Discharge	EF	10/18/2009	Iron, Total	HACH Colorimeter	0.4	mg/L	
Discharge	EF	10/18/2009	ORP	YSI 556	-61.8	mV	
Discharge	EF	10/18/2009	pH	YSI 556	8.19	su	
Discharge	EF	10/18/2009	Specific Conductivity	YSI 556	249	uS/cm	
Discharge	EF	10/18/2009	Temperature	YSI 556	12.25	C	
Discharge	EF	10/18/2009	Turbidity	HACH 2100P	9.22	NTU	
Effluent-Tote 1	E1	10/18/2009	Dissolved Oxygen	YSI 556	0.27	mg/L	
Effluent-Tote 1	E1	10/18/2009	Flow	Visual flow meter	3	gpm	
Effluent-Tote 1	E1	10/18/2009	ORP	YSI 556	-258.2	mV	
Effluent-Tote 1	E1	10/18/2009	pH	YSI 556	8.45	su	

Station	Sample ID	Date	Analyte	Method	Result	Units	Qualifier
Effluent-Tote 1	E1	10/18/2009	Specific Conductivity	YSI 556	254	uS/cm	
Effluent-Tote 1	E1	10/18/2009	Temperature	YSI 556	10.73	C	
Effluent-Tote 1	E1	10/18/2009	Turbidity	HACH 2100P	6.16	NTU	
Effluent-Tote 2	E2	10/18/2009	Flow	Visual flow meter	3	gpm	
Influent	LSS-SP-N	10/18/2009	Dissolved Oxygen	YSI 556	9.86	mg/L	
Influent	LSS-SP-N	10/18/2009	ORP	YSI 556	-7.1	mV	
Influent	LSS-SP-N	10/18/2009	pH	YSI 556	7.43	su	
Influent	LSS-SP-N	10/18/2009	Specific Conductivity	YSI 556	257	uS/cm	
Influent	LSS-SP-N	10/18/2009	Temperature	YSI 556	10.33	C	
Influent	LSS-SP-N	10/18/2009	Turbidity	HACH 2100P	0.58	NTU	
Pond	PD	10/18/2009	Dissolved Oxygen	YSI 556	5.09	mg/L	
Pond	PD	10/18/2009	ORP	YSI 556	-50.1	mV	
Pond	PD	10/18/2009	Specific Conductivity	YSI 556	249	uS/cm	
Pond	PD	10/18/2009	Temperature	YSI 556	11.82	C	
Pond	PD	10/18/2009	Turbidity	HACH 2100P	12.4	NTU	
Pond Inlet	PI	10/18/2009	Dissolved Oxygen	YSI 556	4.93	mg/L	
Pond Inlet	PI	10/18/2009	ORP	YSI 556	-30.7	mV	
Pond Inlet	PI	10/18/2009	pH	YSI 556	8.17	su	
Pond Inlet	PI	10/18/2009	Specific Conductivity	YSI 556	250	uS/cm	
Pond Inlet	PI	10/18/2009	Temperature	YSI 556	12.15	C	
Pond Inlet	PI	10/18/2009	Turbidity	HACH 2100P	11.9	NTU	
Pond Outlet	PO	10/18/2009	Dissolved Oxygen	YSI 556	4.91	mg/L	
Pond Outlet	PO	10/18/2009	ORP	YSI 556	-47.7	mV	
Pond Outlet	PO	10/18/2009	pH	YSI 556	8.16	su	
Pond Outlet	PO	10/18/2009	Specific Conductivity	YSI 556	249	uS/cm	
Pond Outlet	PO	10/18/2009	Temperature	YSI 556	11.63	C	
Pond Outlet	PO	10/18/2009	Turbidity	HACH 2100P	12.3	NTU	
Discharge	EF	10/19/2009	Dissolved Oxygen	YSI 556	6.85	mg/L	
Discharge	EF	10/19/2009	Iron, Ferrous	HACH Colorimeter	0.03	mg/L	
Discharge	EF	10/19/2009	Iron, Total	HACH Colorimeter	0.04	mg/L	
Discharge	EF	10/19/2009	ORP	YSI 556	3.3	mV	
Discharge	EF	10/19/2009	pH	YSI 556	8.13	su	
Discharge	EF	10/19/2009	Specific Conductivity	YSI 556	366	uS/cm	
Discharge	EF	10/19/2009	Temperature	YSI 556	9.42	C	
Discharge	EF	10/19/2009	Turbidity	HACH 2100P	10.3	NTU	
Effluent-Tote 1	E1	10/19/2009	Dissolved Oxygen	YSI 556	0.22	mg/L	
Effluent-Tote 1	E1	10/19/2009	Flow	Visual flow meter	3	gpm	
Effluent-Tote 1	E1	10/19/2009	ORP	YSI 556	-239.7	mV	
Effluent-Tote 1	E1	10/19/2009	pH	YSI 556	8.51	su	
Effluent-Tote 1	E1	10/19/2009	Specific Conductivity	YSI 556	375	uS/cm	
Effluent-Tote 1	E1	10/19/2009	Temperature	YSI 556	10.29	C	
Effluent-Tote 1	E1	10/19/2009	Turbidity	HACH 2100P	11.6	NTU	
Effluent-Tote 2	E2	10/19/2009	Flow	Visual flow meter	3	gpm	
Effluent-Tote 3	E3	10/19/2009	Flow	Visual flow meter	1	gpm	
Influent	LSS-SP-N	10/19/2009	Dissolved Oxygen	YSI 556	9.05	mg/L	
Influent	LSS-SP-N	10/19/2009	ORP	YSI 556	-37.8	mV	
Influent	LSS-SP-N	10/19/2009	pH	YSI 556	7.73	su	
Influent	LSS-SP-N	10/19/2009	Specific Conductivity	YSI 556	379	uS/cm	
Influent	LSS-SP-N	10/19/2009	Temperature	YSI 556	10.1	C	
Influent	LSS-SP-N	10/19/2009	Turbidity	HACH 2100P	0.45	NTU	
Pond	PD	10/19/2009	Dissolved Oxygen	YSI 556	5	mg/L	
Pond	PD	10/19/2009	ORP	YSI 556	-15	mV	
Pond	PD	10/19/2009	Specific Conductivity	YSI 556	367	uS/cm	
Pond	PD	10/19/2009	Temperature	YSI 556	8.84	C	
Pond	PD	10/19/2009	Turbidity	HACH 2100P	14.8	NTU	
Pond Inlet	PI	10/19/2009	Dissolved Oxygen	YSI 556	4.22	mg/L	
Pond Inlet	PI	10/19/2009	ORP	YSI 556	-30.3	mV	
Pond Inlet	PI	10/19/2009	pH	YSI 556	8.14	su	
Pond Inlet	PI	10/19/2009	Specific Conductivity	YSI 556	367	uS/cm	
Pond Inlet	PI	10/19/2009	Temperature	YSI 556	8.63	C	

Station	Sample ID	Date	Analyte	Method	Result	Units	Qualifier
Pond Inlet	PI	10/19/2009	Turbidity	HACH 2100P	21.5	NTU	
Pond Outlet	PO	10/19/2009	Dissolved Oxygen	YSI 556	4.97	mg/L	
Pond Outlet	PO	10/19/2009	ORP	YSI 556	-4.1	mV	
Pond Outlet	PO	10/19/2009	pH	YSI 556	8.12	su	
Pond Outlet	PO	10/19/2009	Specific Conductivity	YSI 556	366	uS/cm	
Pond Outlet	PO	10/19/2009	Temperature	YSI 556	8.91	C	
Pond Outlet	PO	10/19/2009	Turbidity	HACH 2100P	11.9	NTU	
Discharge	EF	10/20/2009	Dissolved Oxygen	YSI 556	5.6	mg/L	
Discharge	EF	10/20/2009	Iron, Ferrous	HACH Colorimeter	0.13	mg/L	
Discharge	EF	10/20/2009	Iron, Total	HACH Colorimeter	0.21	mg/L	
Discharge	EF	10/20/2009	ORP	YSI 556	80.7	mV	
Discharge	EF	10/20/2009	pH	YSI 556	7.95	su	
Discharge	EF	10/20/2009	Specific Conductivity	YSI 556	366	uS/cm	
Discharge	EF	10/20/2009	Temperature	YSI 556	10.09	C	
Discharge	EF	10/20/2009	Turbidity	HACH 2100P	15.9	NTU	
Effluent-Tote 1	E1	10/20/2009	Dissolved Oxygen	YSI 556	0.36	mg/L	
Effluent-Tote 1	E1	10/20/2009	Flow	Visual flow meter	3	gpm	
Effluent-Tote 1	E1	10/20/2009	ORP	YSI 556	-260.1	mV	
Effluent-Tote 1	E1	10/20/2009	pH	YSI 556	8.58	su	
Effluent-Tote 1	E1	10/20/2009	Specific Conductivity	YSI 556	366	uS/cm	
Effluent-Tote 1	E1	10/20/2009	Temperature	YSI 556	9.98	C	
Effluent-Tote 1	E1	10/20/2009	Turbidity	HACH 2100P	9.72	NTU	
Effluent-Tote 2	E2	10/20/2009	Flow	Visual flow meter	3	gpm	
Effluent-Tote 3	E3	10/20/2009	Flow	Visual flow meter	1	gpm	
Influent	LSS-SP-N	10/20/2009	Dissolved Oxygen	YSI 556	8.65	mg/L	
Influent	LSS-SP-N	10/20/2009	ORP	YSI 556	25.3	mV	
Influent	LSS-SP-N	10/20/2009	pH	YSI 556	7.68	su	
Influent	LSS-SP-N	10/20/2009	Specific Conductivity	YSI 556	379	uS/cm	
Influent	LSS-SP-N	10/20/2009	Temperature	YSI 556	9.96	C	
Influent	LSS-SP-N	10/20/2009	Turbidity	HACH 2100P	0.45	NTU	
Pond	PD	10/20/2009	Dissolved Oxygen	YSI 556	3.82	mg/L	
Pond	PD	10/20/2009	ORP	YSI 556	38.3	mV	
Pond	PD	10/20/2009	pH	YSI 556	7.9	su	
Pond	PD	10/20/2009	Specific Conductivity	YSI 556	365	uS/cm	
Pond	PD	10/20/2009	Temperature	YSI 556	9.28	C	
Pond	PD	10/20/2009	Turbidity	HACH 2100P	19.6	NTU	
Pond Inlet	PI	10/20/2009	Dissolved Oxygen	YSI 556	3.78	mg/L	
Pond Inlet	PI	10/20/2009	ORP	YSI 556	-1.5	mV	
Pond Inlet	PI	10/20/2009	pH	YSI 556	7.89	su	
Pond Inlet	PI	10/20/2009	Specific Conductivity	YSI 556	363	uS/cm	
Pond Inlet	PI	10/20/2009	Temperature	YSI 556	9.07	C	
Pond Inlet	PI	10/20/2009	Turbidity	HACH 2100P	24.4	NTU	
Pond Outlet	PO	10/20/2009	Dissolved Oxygen	YSI 556	4.46	mg/L	
Pond Outlet	PO	10/20/2009	Iron, Ferrous	HACH Colorimeter	0.01	mg/L	
Pond Outlet	PO	10/20/2009	Iron, Total	HACH Colorimeter	0.05	mg/L	
Pond Outlet	PO	10/20/2009	ORP	YSI 556	49.8	mV	
Pond Outlet	PO	10/20/2009	pH	YSI 556	7.91	su	
Pond Outlet	PO	10/20/2009	Specific Conductivity	YSI 556	367	uS/cm	
Pond Outlet	PO	10/20/2009	Temperature	YSI 556	9.53	C	
Pond Outlet	PO	10/20/2009	Turbidity	HACH 2100P	18.6	NTU	
Discharge	EF	10/21/2009	Dissolved Oxygen	YSI 556	5.72	mg/L	
Discharge	EF	10/21/2009	Iron, Ferrous	HACH Colorimeter	0	mg/L	
Discharge	EF	10/21/2009	Iron, Total	HACH Colorimeter	0.1	mg/L	
Discharge	EF	10/21/2009	ORP	YSI 556	99.9	mV	
Discharge	EF	10/21/2009	pH	YSI 556	7.84	su	
Discharge	EF	10/21/2009	Specific Conductivity	YSI 556	381	uS/cm	
Discharge	EF	10/21/2009	Temperature	YSI 556	5.73	C	
Discharge	EF	10/21/2009	Turbidity	HACH 2100P	8.15	NTU	
Effluent-Tote 1	E1	10/21/2009	Dissolved Oxygen	YSI 556	0.12	mg/L	
Effluent-Tote 1	E1	10/21/2009	Flow	Visual flow meter	3	gpm	

Station	Sample ID	Date	Analyte	Method	Result	Units	Qualifier
Effluent-Tote 1	E1	10/21/2009	ORP	YSI 556	-277.2	mV	
Effluent-Tote 1	E1	10/21/2009	pH	YSI 556	8.55	su	
Effluent-Tote 1	E1	10/21/2009	Specific Conductivity	YSI 556	369	uS/cm	
Effluent-Tote 1	E1	10/21/2009	Temperature	YSI 556	10	C	
Effluent-Tote 1	E1	10/21/2009	Turbidity	HACH 2100P	14.7	NTU	
Effluent-Tote 2	E2	10/21/2009	Flow	Visual flow meter	2	gpm	
Effluent-Tote 3	E3	10/21/2009	Flow	Visual flow meter	1	gpm	
Influent	LSS-SP-N	10/21/2009	Dissolved Oxygen	YSI 556	9.37	mg/L	
Influent	LSS-SP-N	10/21/2009	ORP	YSI 556	19.6	mV	
Influent	LSS-SP-N	10/21/2009	pH	YSI 556	7.65	su	
Influent	LSS-SP-N	10/21/2009	Specific Conductivity	YSI 556	377	uS/cm	
Influent	LSS-SP-N	10/21/2009	Temperature	YSI 556	10.04	C	
Influent	LSS-SP-N	10/21/2009	Turbidity	HACH 2100P	0.78	NTU	
Pond	PD	10/21/2009	Dissolved Oxygen	YSI 556	3.97	mg/L	
Pond	PD	10/21/2009	ORP	YSI 556	46.2	mV	
Pond	PD	10/21/2009	pH	YSI 556	7.98	su	
Pond	PD	10/21/2009	Specific Conductivity	YSI 556	383	uS/cm	
Pond	PD	10/21/2009	Temperature	YSI 556	6.73	C	
Pond	PD	10/21/2009	Turbidity	HACH 2100P	18.7	NTU	
Pond Inlet	PI	10/21/2009	Dissolved Oxygen	YSI 556	4.09	mg/L	
Pond Inlet	PI	10/21/2009	ORP	YSI 556	0	mV	
Pond Inlet	PI	10/21/2009	pH	YSI 556	7.96	su	
Pond Inlet	PI	10/21/2009	Specific Conductivity	YSI 556	382	uS/cm	
Pond Inlet	PI	10/21/2009	Temperature	YSI 556	6.87	C	
Pond Inlet	PI	10/21/2009	Turbidity	HACH 2100P	22.1	NTU	
Pond Outlet	PO	10/21/2009	Dissolved Oxygen	YSI 556	4.14	mg/L	
Pond Outlet	PO	10/21/2009	ORP	YSI 556	71.4	mV	
Pond Outlet	PO	10/21/2009	pH	YSI 556	7.88	su	
Pond Outlet	PO	10/21/2009	Specific Conductivity	YSI 556	382	uS/cm	
Pond Outlet	PO	10/21/2009	Temperature	YSI 556	6.23	C	
Pond Outlet	PO	10/21/2009	Turbidity	HACH 2100P	13.9	NTU	
Discharge	EF	10/22/2009	Dissolved Oxygen	YSI 556	4.78	mg/L	
Discharge	EF	10/22/2009	Iron, Ferrous	HACH Colorimeter	0.02	mg/L	
Discharge	EF	10/22/2009	Iron, Total	HACH Colorimeter	0.07	mg/L	
Discharge	EF	10/22/2009	ORP	YSI 556	125.7	mV	
Discharge	EF	10/22/2009	pH	YSI 556	8.04	su	
Discharge	EF	10/22/2009	Specific Conductivity	YSI 556	384	uS/cm	
Discharge	EF	10/22/2009	Temperature	YSI 556	6.14	C	
Discharge	EF	10/22/2009	Turbidity	HACH 2100P	10.9	NTU	
Effluent-Tote 1	E1	10/22/2009	Dissolved Oxygen	YSI 556	0.14	mg/L	
Effluent-Tote 1	E1	10/22/2009	Flow	Visual flow meter	3	gpm	
Effluent-Tote 1	E1	10/22/2009	ORP	YSI 556	-311	mV	
Effluent-Tote 1	E1	10/22/2009	pH	YSI 556	8.62	su	
Effluent-Tote 1	E1	10/22/2009	Specific Conductivity	YSI 556	376	uS/cm	
Effluent-Tote 1	E1	10/22/2009	Temperature	YSI 556	9.83	C	
Effluent-Tote 1	E1	10/22/2009	Turbidity	HACH 2100P	10.7	NTU	
Effluent-Tote 2	E2	10/22/2009	Dissolved Oxygen	YSI 556	2.66	mg/L	
Effluent-Tote 2	E2	10/22/2009	Flow	Visual flow meter	1	gpm	
Effluent-Tote 2	E2	10/22/2009	ORP	YSI 556	-204.1	mV	
Effluent-Tote 2	E2	10/22/2009	pH	YSI 556	8.61	su	
Effluent-Tote 2	E2	10/22/2009	Specific Conductivity	YSI 556	368	uS/cm	
Effluent-Tote 2	E2	10/22/2009	Temperature	YSI 556	9.45	C	
Effluent-Tote 2	E2	10/22/2009	Turbidity	HACH 2100P	44.9	NTU	
Effluent-Tote 3	E3	10/22/2009	Dissolved Oxygen	YSI 556	1.34	mg/L	
Effluent-Tote 3	E3	10/22/2009	Flow	Visual flow meter	1	gpm	
Effluent-Tote 3	E3	10/22/2009	ORP	YSI 556	-198.5	mV	
Effluent-Tote 3	E3	10/22/2009	pH	YSI 556	9.12	su	
Effluent-Tote 3	E3	10/22/2009	Specific Conductivity	YSI 556	335	uS/cm	
Effluent-Tote 3	E3	10/22/2009	Temperature	YSI 556	9.6	C	
Effluent-Tote 3	E3	10/22/2009	Turbidity	HACH 2100P	8.98	NTU	

Station	Sample ID	Date	Analyte	Method	Result	Units	Qualifier
Influent	LSS-SP-N	10/22/2009	Dissolved Oxygen	YSI 556	9.14	mg/L	
Influent	LSS-SP-N	10/22/2009	ORP	YSI 556	42.3	mV	
Influent	LSS-SP-N	10/22/2009	pH	YSI 556	7.65	su	
Influent	LSS-SP-N	10/22/2009	Specific Conductivity	YSI 556	383	uS/cm	
Influent	LSS-SP-N	10/22/2009	Temperature	YSI 556	9.9	C	
Influent	LSS-SP-N	10/22/2009	Turbidity	HACH 2100P	0.71	NTU	
Pond	PD	10/22/2009	Dissolved Oxygen	YSI 556	3.35	mg/L	
Pond	PD	10/22/2009	ORP	YSI 556	61.2	mV	
Pond	PD	10/22/2009	pH	YSI 556	8.06	su	
Pond	PD	10/22/2009	Specific Conductivity	YSI 556	382	uS/cm	
Pond	PD	10/22/2009	Temperature	YSI 556	6.76	C	
Pond	PD	10/22/2009	Turbidity	HACH 2100P	17	NTU	
Discharge	EF	10/23/2009	Dissolved Oxygen	YSI 556	4.18	mg/L	
Discharge	EF	10/23/2009	Iron, Ferrous	HACH Colorimeter	0.01	mg/L	
Discharge	EF	10/23/2009	Iron, Total	HACH Colorimeter	0.04	mg/L	
Discharge	EF	10/23/2009	ORP	YSI 556	54.3	mV	
Discharge	EF	10/23/2009	pH	YSI 556	7.74	su	
Discharge	EF	10/23/2009	Specific Conductivity	YSI 556	379	uS/cm	
Discharge	EF	10/23/2009	Temperature	YSI 556	5.17	C	
Discharge	EF	10/23/2009	Turbidity	HACH 2100P	10.08	NTU	
Effluent-Tote 1	E1	10/23/2009	Dissolved Oxygen	YSI 556	1.43	mg/L	
Effluent-Tote 1	E1	10/23/2009	Flow	Visual flow meter	2	gpm	
Effluent-Tote 1	E1	10/23/2009	ORP	YSI 556	-175	mV	
Effluent-Tote 1	E1	10/23/2009	pH	YSI 556	8.47	su	
Effluent-Tote 1	E1	10/23/2009	Specific Conductivity	YSI 556	363	uS/cm	
Effluent-Tote 1	E1	10/23/2009	Temperature	YSI 556	9.57	C	
Effluent-Tote 1	E1	10/23/2009	Turbidity	HACH 2100P	12.3	NTU	
Effluent-Tote 2	E2	10/23/2009	Dissolved Oxygen	YSI 556	1.34	mg/L	
Effluent-Tote 2	E2	10/23/2009	Flow	Visual flow meter	1	gpm	
Effluent-Tote 2	E2	10/23/2009	ORP	YSI 556	-187.2	mV	
Effluent-Tote 2	E2	10/23/2009	pH	YSI 556	8.64	su	
Effluent-Tote 2	E2	10/23/2009	Specific Conductivity	YSI 556	366	uS/cm	
Effluent-Tote 2	E2	10/23/2009	Temperature	YSI 556	9.21	C	
Effluent-Tote 3	E3	10/23/2009	Dissolved Oxygen	YSI 556	1.56	mg/L	
Effluent-Tote 3	E3	10/23/2009	Flow	Visual flow meter	1	gpm	
Effluent-Tote 3	E3	10/23/2009	ORP	YSI 556	-162.8	mV	
Effluent-Tote 3	E3	10/23/2009	pH	YSI 556	8.98	su	
Effluent-Tote 3	E3	10/23/2009	Specific Conductivity	YSI 556	346	uS/cm	
Effluent-Tote 3	E3	10/23/2009	Temperature	YSI 556	8.99	C	
Effluent-Tote 3	E3	10/23/2009	Turbidity	HACH 2100P	9.67	NTU	
Influent	LSS-SP-N	10/23/2009	Dissolved Oxygen	YSI 556	8.88	mg/L	
Influent	LSS-SP-N	10/23/2009	ORP	YSI 556	36.7	mV	
Influent	LSS-SP-N	10/23/2009	pH	YSI 556	7.65	su	
Influent	LSS-SP-N	10/23/2009	Specific Conductivity	YSI 556	383	uS/cm	
Influent	LSS-SP-N	10/23/2009	Temperature	YSI 556	9.85	C	
Influent	LSS-SP-N	10/23/2009	Turbidity	HACH 2100P	0.3	NTU	
Pond	PD	10/23/2009	Dissolved Oxygen	YSI 556	2.55	mg/L	
Pond	PD	10/23/2009	ORP	YSI 556	23.9	mV	
Pond	PD	10/23/2009	pH	YSI 556	7.99	su	
Pond	PD	10/23/2009	Specific Conductivity	YSI 556	379	uS/cm	
Pond	PD	10/23/2009	Temperature	YSI 556	5.96	C	
Pond	PD	10/23/2009	Turbidity	HACH 2100P	18.3	NTU	
Discharge	EF	10/25/2009	Dissolved Oxygen	YSI 556	6.93	mg/L	
Discharge	EF	10/25/2009	Iron, Ferrous	HACH Colorimeter	0.08	mg/L	
Discharge	EF	10/25/2009	Iron, Total	HACH Colorimeter	0.25	mg/L	
Discharge	EF	10/25/2009	ORP	YSI 556	50.7	mV	
Discharge	EF	10/25/2009	pH	YSI 556	8.11	su	
Discharge	EF	10/25/2009	Specific Conductivity	YSI 556	376	uS/cm	
Discharge	EF	10/25/2009	Temperature	YSI 556	4.26	C	
Discharge	EF	10/25/2009	Turbidity	HACH 2100P	7.45	NTU	

Station	Sample ID	Date	Analyte	Method	Result	Units	Qualifier
Effluent-Tote 1	E1	10/25/2009	Dissolved Oxygen	YSI 556	1.53	mg/L	
Effluent-Tote 1	E1	10/25/2009	Flow	Visual flow meter	2	gpm	
Effluent-Tote 1	E1	10/25/2009	ORP	YSI 556	-123	mV	
Effluent-Tote 1	E1	10/25/2009	pH	YSI 556	8.54	su	
Effluent-Tote 1	E1	10/25/2009	Specific Conductivity	YSI 556	376	uS/cm	
Effluent-Tote 1	E1	10/25/2009	Temperature	YSI 556	9.31	C	
Effluent-Tote 1	E1	10/25/2009	Turbidity	HACH 2100P	10.3	NTU	
Effluent-Tote 2	E2	10/25/2009	Dissolved Oxygen	YSI 556	2.54	mg/L	
Effluent-Tote 2	E2	10/25/2009	Flow	Visual flow meter	1	gpm	
Effluent-Tote 3	E3	10/25/2009	Dissolved Oxygen	YSI 556	1.08	mg/L	
Effluent-Tote 3	E3	10/25/2009	Flow	Visual flow meter	1	gpm	
Influent	LSS-SP-N	10/25/2009	Dissolved Oxygen	YSI 556	8.76	mg/L	
Influent	LSS-SP-N	10/25/2009	ORP	YSI 556	64	mV	
Influent	LSS-SP-N	10/25/2009	pH	YSI 556	7.77	su	
Influent	LSS-SP-N	10/25/2009	Specific Conductivity	YSI 556	382	uS/cm	
Influent	LSS-SP-N	10/25/2009	Temperature	YSI 556	9.47	C	
Influent	LSS-SP-N	10/25/2009	Turbidity	HACH 2100P	0.61	NTU	
Pond	PD	10/25/2009	Dissolved Oxygen	YSI 556	4.64	mg/L	
Pond	PD	10/25/2009	ORP	YSI 556	18.4	mV	
Pond	PD	10/25/2009	pH	YSI 556	8.36	su	
Pond	PD	10/25/2009	Specific Conductivity	YSI 556	380	uS/cm	
Pond	PD	10/25/2009	Temperature	YSI 556	4.9	C	
Pond	PD	10/25/2009	Turbidity	HACH 2100P	11.9	NTU	
Discharge	EF	10/26/2009	Dissolved Oxygen	YSI 556	7.52	mg/L	
Discharge	EF	10/26/2009	Iron, Ferrous	HACH Colorimeter	0.07	mg/L	
Discharge	EF	10/26/2009	Iron, Total	HACH Colorimeter	0.23	mg/L	
Discharge	EF	10/26/2009	ORP	YSI 556	166.6	mV	
Discharge	EF	10/26/2009	pH	YSI 556	7.8	su	
Discharge	EF	10/26/2009	Specific Conductivity	YSI 556	362	uS/cm	
Discharge	EF	10/26/2009	Temperature	YSI 556	3.35	C	
Discharge	EF	10/26/2009	Turbidity	HACH 2100P	14.1	NTU	
Effluent-Tote 1	E1	10/26/2009	Dissolved Oxygen	YSI 556	1.4	mg/L	
Effluent-Tote 1	E1	10/26/2009	Flow	Visual flow meter	2	gpm	
Effluent-Tote 1	E1	10/26/2009	Temperature	YSI 556	8.2	C	
Effluent-Tote 2	E2	10/26/2009	Dissolved Oxygen	YSI 556	1.83	mg/L	
Effluent-Tote 2	E2	10/26/2009	Flow	Visual flow meter	1	gpm	
Effluent-Tote 2	E2	10/26/2009	Temperature	YSI 556	8.2	C	
Effluent-Tote 2	E2	10/26/2009	Turbidity	HACH 2100P	19.1	NTU	
Effluent-Tote 3	E3	10/26/2009	Dissolved Oxygen	YSI 556	1.34	mg/L	
Effluent-Tote 3	E3	10/26/2009	Flow	Visual flow meter	2	gpm	
Effluent-Tote 3	E3	10/26/2009	Temperature	YSI 556	8	C	
Effluent-Tote 3	E3	10/26/2009	Turbidity	HACH 2100P	7.66	NTU	
Influent	LSS-SP-N	10/26/2009	Dissolved Oxygen	YSI 556	8.92	mg/L	
Influent	LSS-SP-N	10/26/2009	ORP	YSI 556	142.3	mV	
Influent	LSS-SP-N	10/26/2009	pH	YSI 556	7.53	su	
Influent	LSS-SP-N	10/26/2009	Specific Conductivity	YSI 556	371	uS/cm	
Influent	LSS-SP-N	10/26/2009	Temperature	YSI 556	9.76	C	
Influent	LSS-SP-N	10/26/2009	Turbidity	HACH 2100P	0.75	NTU	
Pond	PD	10/26/2009	Dissolved Oxygen	YSI 556	4.61	mg/L	
Pond	PD	10/26/2009	ORP	YSI 556	141.6	mV	
Pond	PD	10/26/2009	pH	YSI 556	7.9	su	
Pond	PD	10/26/2009	Specific Conductivity	YSI 556	359	uS/cm	
Pond	PD	10/26/2009	Temperature	YSI 556	4.52	C	
Pond	PD	10/26/2009	Turbidity	HACH 2100P	11.1	NTU	
Discharge	EF	10/28/2009	Dissolved Oxygen	YSI 556	8.01	mg/L	
Discharge	EF	10/28/2009	Iron, Ferrous	HACH Colorimeter	0.07	mg/L	
Discharge	EF	10/28/2009	Iron, Total	HACH Colorimeter	0.18	mg/L	
Discharge	EF	10/28/2009	ORP	YSI 556	9.5	mV	
Discharge	EF	10/28/2009	pH	YSI 556	8.17	su	
Discharge	EF	10/28/2009	Specific Conductivity	YSI 556	350	uS/cm	

Station	Sample ID	Date	Analyte	Method	Result	Units	Qualifier
Discharge	EF	10/28/2009	Temperature	YSI 556	4.98	C	
Discharge	EF	10/28/2009	Turbidity	HACH 2100P	13.1	NTU	
Effluent-Tote 1	E1	10/28/2009	Dissolved Oxygen	YSI 556	0.26	mg/L	
Effluent-Tote 1	E1	10/28/2009	Flow	Visual flow meter	3	gpm	
Effluent-Tote 1	E1	10/28/2009	ORP	YSI 556	-261	mV	
Effluent-Tote 1	E1	10/28/2009	pH	YSI 556	8.49	su	
Effluent-Tote 1	E1	10/28/2009	Specific Conductivity	YSI 556	350	uS/cm	
Effluent-Tote 1	E1	10/28/2009	Temperature	YSI 556	9.53	C	
Effluent-Tote 1	E1	10/28/2009	Turbidity	HACH 2100P	5.71	NTU	
Influent	LSS-SP-N	10/28/2009	Dissolved Oxygen	YSI 556	8.08	mg/L	
Influent	LSS-SP-N	10/28/2009	ORP	YSI 556	-18.5	mV	
Influent	LSS-SP-N	10/28/2009	pH	YSI 556	7.67	su	
Influent	LSS-SP-N	10/28/2009	Specific Conductivity	YSI 556	363	uS/cm	
Influent	LSS-SP-N	10/28/2009	Temperature	YSI 556	9.72	C	
Influent	LSS-SP-N	10/28/2009	Turbidity	HACH 2100P	0.72	NTU	
Pond	PD	10/28/2009	Dissolved Oxygen	YSI 556	5.27	mg/L	
Pond	PD	10/28/2009	ORP	YSI 556	-76.2	mV	
Pond	PD	10/28/2009	pH	YSI 556	8.19	su	
Pond	PD	10/28/2009	Specific Conductivity	YSI 556	348	uS/cm	
Pond	PD	10/28/2009	Temperature	YSI 556	5.38	C	
Pond	PD	10/28/2009	Turbidity	HACH 2100P	14.8	NTU	
Discharge	EF	10/29/2009	Dissolved Oxygen	YSI 556	9.27	mg/L	
Discharge	EF	10/29/2009	Iron, Ferrous	HACH Colorimeter	0.11	mg/L	
Discharge	EF	10/29/2009	ORP	YSI 556	102.9	mV	
Discharge	EF	10/29/2009	pH	YSI 556	8.04	su	
Discharge	EF	10/29/2009	Specific Conductivity	YSI 556	355	uS/cm	
Discharge	EF	10/29/2009	Temperature	YSI 556	3.85	C	
Discharge	EF	10/29/2009	Turbidity	HACH 2100P	11.4	NTU	
Effluent-Tote 1	E1	10/29/2009	Dissolved Oxygen	YSI 556	0.49	mg/L	
Effluent-Tote 1	E1	10/29/2009	Flow	Visual flow meter	3	gpm	
Effluent-Tote 1	E1	10/29/2009	ORP	YSI 556	-250.9	mV	
Effluent-Tote 1	E1	10/29/2009	pH	YSI 556	8.31	su	
Effluent-Tote 1	E1	10/29/2009	Specific Conductivity	YSI 556	349	uS/cm	
Effluent-Tote 1	E1	10/29/2009	Temperature	YSI 556	9.53	C	
Effluent-Tote 1	E1	10/29/2009	Turbidity	HACH 2100P	7.32	NTU	
Influent	LSS-SP-N	10/29/2009	Dissolved Oxygen	YSI 556	8.32	mg/L	
Influent	LSS-SP-N	10/29/2009	ORP	YSI 556	-15	mV	
Influent	LSS-SP-N	10/29/2009	pH	YSI 556	7.71	su	
Influent	LSS-SP-N	10/29/2009	Specific Conductivity	YSI 556	362	uS/cm	
Influent	LSS-SP-N	10/29/2009	Temperature	YSI 556	9.89	C	
Influent	LSS-SP-N	10/29/2009	Turbidity	HACH 2100P	1.75	NTU	
Pond	PD	10/29/2009	Dissolved Oxygen	YSI 556	5.2	mg/L	
Pond	PD	10/29/2009	ORP	YSI 556	-91.9	mV	
Pond	PD	10/29/2009	pH	YSI 556	8.01	su	
Pond	PD	10/29/2009	Specific Conductivity	YSI 556	354	uS/cm	
Pond	PD	10/29/2009	Temperature	YSI 556	5.31	C	
Pond	PD	10/29/2009	Turbidity	HACH 2100P	22.1	NTU	
Tote Effluent	TEF	10/29/2009	Dissolved Oxygen	YSI 556	1.05	mg/L	
Tote Effluent	TEF	10/29/2009	Flow	Visual flow meter	9	gpm	
Tote Effluent	TEF	10/29/2009	ORP	YSI 556	-207	mV	
Tote Effluent	TEF	10/29/2009	pH	YSI 556	8.15	su	
Tote Effluent	TEF	10/29/2009	Specific Conductivity	YSI 556	356	uS/cm	
Tote Effluent	TEF	10/29/2009	Temperature	YSI 556	10.7	C	
Tote Effluent	TEF	10/29/2009	Turbidity	HACH 2100P	14.2	NTU	
Discharge	EF	10/30/2009	Dissolved Oxygen	YSI 556	7.4	mg/L	
Discharge	EF	10/30/2009	Iron, Ferrous	HACH Colorimeter	0.32	mg/L	
Discharge	EF	10/30/2009	Iron, Total	HACH Colorimeter	0.14	mg/L	
Discharge	EF	10/30/2009	ORP	YSI 556	32.5	mV	
Discharge	EF	10/30/2009	pH	YSI 556	7.71	su	
Discharge	EF	10/30/2009	Specific Conductivity	YSI 556	343	uS/cm	

Station	Sample ID	Date	Analyte	Method	Result	Units	Qualifier
Discharge	EF	10/30/2009	Temperature	YSI 556	3.18	C	
Discharge	EF	10/30/2009	Turbidity	HACH 2100P	16.5	NTU	
Effluent-Tote 1	E1	10/30/2009	Dissolved Oxygen	YSI 556	0.42	mg/L	
Effluent-Tote 1	E1	10/30/2009	Flow	Visual flow meter	3	gpm	
Effluent-Tote 1	E1	10/30/2009	ORP	YSI 556	-242.3	mV	
Effluent-Tote 1	E1	10/30/2009	pH	YSI 556	8.29	su	
Effluent-Tote 1	E1	10/30/2009	Specific Conductivity	YSI 556	351	uS/cm	
Effluent-Tote 1	E1	10/30/2009	Temperature	YSI 556	9.8	C	
Effluent-Tote 1	E1	10/30/2009	Turbidity	HACH 2100P	8.1	NTU	
Influent	LSS-SP-N	10/30/2009	Dissolved Oxygen	YSI 556	8.42	mg/L	
Influent	LSS-SP-N	10/30/2009	ORP	YSI 556	19.3	mV	
Influent	LSS-SP-N	10/30/2009	pH	YSI 556	7.64	su	
Influent	LSS-SP-N	10/30/2009	Specific Conductivity	YSI 556	361	uS/cm	
Influent	LSS-SP-N	10/30/2009	Temperature	YSI 556	9.77	C	
Influent	LSS-SP-N	10/30/2009	Turbidity	HACH 2100P	0.37	NTU	
Pond	PD	10/30/2009	Dissolved Oxygen	YSI 556	4.52	mg/L	
Pond	PD	10/30/2009	ORP	YSI 556	-77.8	mV	
Pond	PD	10/30/2009	pH	YSI 556	7.71	su	
Pond	PD	10/30/2009	Specific Conductivity	YSI 556	347	uS/cm	
Pond	PD	10/30/2009	Temperature	YSI 556	5.02	C	
Pond	PD	10/30/2009	Turbidity	HACH 2100P	30.2	NTU	
Tote Effluent	TEF	10/30/2009	Dissolved Oxygen	YSI 556	0.84	mg/L	
Tote Effluent	TEF	10/30/2009	Flow	Visual flow meter	12	gpm	
Tote Effluent	TEF	10/30/2009	Iron, Ferrous	HACH Colorimeter	2.27	mg/L	
Tote Effluent	TEF	10/30/2009	Iron, Total	HACH Colorimeter	1.69	mg/L	
Tote Effluent	TEF	10/30/2009	ORP	YSI 556	-250.9	mV	
Tote Effluent	TEF	10/30/2009	pH	YSI 556	8.31	su	
Tote Effluent	TEF	10/30/2009	Specific Conductivity	YSI 556	348	uS/cm	
Tote Effluent	TEF	10/30/2009	Temperature	YSI 556	9.12	C	
Tote Effluent	TEF	10/30/2009	Turbidity	HACH 2100P	15.9	NTU	
Discharge	EF	11/2/2009	Dissolved Oxygen	YSI 556	7.62	mg/L	
Discharge	EF	11/2/2009	Iron, Ferrous	HACH Colorimeter	0.01	mg/L	
Discharge	EF	11/2/2009	Iron, Total	HACH Colorimeter	0.03	mg/L	
Discharge	EF	11/2/2009	ORP	YSI 556	87.2	mV	
Discharge	EF	11/2/2009	pH	YSI 556	8.06	su	
Discharge	EF	11/2/2009	Specific Conductivity	YSI 556	347	uS/cm	
Discharge	EF	11/2/2009	Temperature	YSI 556	6.74	C	
Discharge	EF	11/2/2009	Turbidity	HACH 2100P	8.43	NTU	
Effluent-Tote 1	E1	11/2/2009	Dissolved Oxygen	YSI 556	0.78	mg/L	
Effluent-Tote 1	E1	11/2/2009	Flow	Visual flow meter	3	gpm	
Effluent-Tote 1	E1	11/2/2009	ORP	YSI 556	-256.9	mV	
Effluent-Tote 1	E1	11/2/2009	pH	YSI 556	8.07	su	
Effluent-Tote 1	E1	11/2/2009	Specific Conductivity	YSI 556	346	uS/cm	
Effluent-Tote 1	E1	11/2/2009	Temperature	YSI 556	10.56	C	
Effluent-Tote 1	E1	11/2/2009	Turbidity	HACH 2100P	6.45	NTU	
Influent	LSS-SP-N	11/2/2009	Dissolved Oxygen	YSI 556	8.29	mg/L	
Influent	LSS-SP-N	11/2/2009	pH	YSI 556	7.77	su	
Influent	LSS-SP-N	11/2/2009	Specific Conductivity	YSI 556	361	uS/cm	
Influent	LSS-SP-N	11/2/2009	Temperature	YSI 556	9.66	C	
Influent	LSS-SP-N	11/2/2009	Turbidity	HACH 2100P	0.53	NTU	
Pond	PD	11/2/2009	Dissolved Oxygen	YSI 556	4.4	mg/L	
Pond	PD	11/2/2009	ORP	YSI 556	-52.9	mV	
Pond	PD	11/2/2009	pH	YSI 556	8.07	su	
Pond	PD	11/2/2009	Specific Conductivity	YSI 556	349	uS/cm	
Pond	PD	11/2/2009	Temperature	YSI 556	7.71	C	
Pond	PD	11/2/2009	Turbidity	HACH 2100P	18.7	NTU	
Tote Effluent	TEF	11/2/2009	Dissolved Oxygen	YSI 556	0.7	mg/L	
Tote Effluent	TEF	11/2/2009	Flow	Visual flow meter	12	gpm	
Tote Effluent	TEF	11/2/2009	ORP	YSI 556	-249.8	mV	
Tote Effluent	TEF	11/2/2009	pH	YSI 556	8.3	su	

Station	Sample ID	Date	Analyte	Method	Result	Units	Qualifier
Tote Effluent	TEF	11/2/2009	Specific Conductivity	YSI 556	353	uS/cm	
Tote Effluent	TEF	11/2/2009	Temperature	YSI 556	10.43	C	
Tote Effluent	TEF	11/2/2009	Turbidity	HACH 2100P	11.8	NTU	
Discharge	EF	11/3/2009	Dissolved Oxygen	YSI 556	6.41	mg/L	
Discharge	EF	11/3/2009	Iron, Ferrous	HACH Colorimeter	0	mg/L	
Discharge	EF	11/3/2009	Iron, Total	HACH Colorimeter	0.04	mg/L	
Discharge	EF	11/3/2009	ORP	YSI 556	-43.7	mV	
Discharge	EF	11/3/2009	pH	YSI 556	7.84	su	
Discharge	EF	11/3/2009	Specific Conductivity	YSI 556	345	uS/cm	
Discharge	EF	11/3/2009	Temperature	YSI 556	7.44	C	
Discharge	EF	11/3/2009	Turbidity	HACH 2100P	18.5	NTU	
Effluent-Tote 1	E1	11/3/2009	Dissolved Oxygen	YSI 556	0.42	mg/L	
Effluent-Tote 1	E1	11/3/2009	Flow	Visual flow meter	3	gpm	
Effluent-Tote 1	E1	11/3/2009	ORP	YSI 556	-260.6	mV	
Effluent-Tote 1	E1	11/3/2009	pH	YSI 556	8.3	su	
Effluent-Tote 1	E1	11/3/2009	Specific Conductivity	YSI 556	348	uS/cm	
Effluent-Tote 1	E1	11/3/2009	Temperature	YSI 556	10.3	C	
Influent	LSS-SP-N	11/3/2009	Dissolved Oxygen	YSI 556	8.25	mg/L	
Influent	LSS-SP-N	11/3/2009	ORP	YSI 556	-58.6	mV	
Influent	LSS-SP-N	11/3/2009	pH	YSI 556	7.67	su	
Influent	LSS-SP-N	11/3/2009	Specific Conductivity	YSI 556	362	uS/cm	
Influent	LSS-SP-N	11/3/2009	Temperature	YSI 556	9.97	C	
Influent	LSS-SP-N	11/3/2009	Turbidity	HACH 2100P	1.57	NTU	
Pond	PD	11/3/2009	Dissolved Oxygen	YSI 556	4.68	mg/L	
Pond	PD	11/3/2009	ORP	YSI 556	-75.8	mV	
Pond	PD	11/3/2009	pH	YSI 556	7.81	su	
Pond	PD	11/3/2009	Specific Conductivity	YSI 556	348	uS/cm	
Pond	PD	11/3/2009	Temperature	YSI 556	8.06	C	
Pond	PD	11/3/2009	Turbidity	HACH 2100P	20.1	NTU	
Tote Effluent	TEF	11/3/2009	Dissolved Oxygen	YSI 556	0.74	mg/L	
Tote Effluent	TEF	11/3/2009	Flow	Visual flow meter	15	gpm	
Tote Effluent	TEF	11/3/2009	ORP	YSI 556	-241	mV	
Tote Effluent	TEF	11/3/2009	pH	YSI 556	8.37	su	
Tote Effluent	TEF	11/3/2009	Specific Conductivity	YSI 556	347	uS/cm	
Tote Effluent	TEF	11/3/2009	Temperature	YSI 556	10.57	C	
Tote Effluent	TEF	11/3/2009	Turbidity	HACH 2100P	16.2	NTU	
Discharge	EF	11/4/2009	Dissolved Oxygen	YSI 556	5.38	mg/L	
Discharge	EF	11/4/2009	Iron, Ferrous	HACH Colorimeter	0.09	mg/L	
Discharge	EF	11/4/2009	Iron, Total	HACH Colorimeter	0.16	mg/L	
Discharge	EF	11/4/2009	ORP	YSI 556	-30.8	mV	
Discharge	EF	11/4/2009	pH	YSI 556	7.79	su	
Discharge	EF	11/4/2009	Specific Conductivity	YSI 556	342	uS/cm	
Discharge	EF	11/4/2009	Temperature	YSI 556	6.98	C	
Discharge	EF	11/4/2009	Turbidity	HACH 2100P	18.4	NTU	
Pond	PD	11/4/2009	Dissolved Oxygen	YSI 556	3.7	mg/L	
Pond	PD	11/4/2009	ORP	YSI 556	-58.9	mV	
Pond	PD	11/4/2009	pH	YSI 556	7.75	su	
Pond	PD	11/4/2009	Specific Conductivity	YSI 556	342	uS/cm	
Pond	PD	11/4/2009	Temperature	YSI 556	7.62	C	
Pond	PD	11/4/2009	Turbidity	HACH 2100P	28.2	NTU	
Discharge	EF	11/5/2009	Dissolved Oxygen	YSI 556	5.69	mg/L	
Discharge	EF	11/5/2009	Iron, Ferrous	HACH Colorimeter	0.03	mg/L	
Discharge	EF	11/5/2009	Iron, Total	HACH Colorimeter	0.08	mg/L	
Discharge	EF	11/5/2009	ORP	YSI 556	-17	mV	
Discharge	EF	11/5/2009	pH	YSI 556	8.04	su	
Discharge	EF	11/5/2009	Specific Conductivity	YSI 556	350	uS/cm	
Discharge	EF	11/5/2009	Temperature	YSI 556	9.87	C	
Discharge	EF	11/5/2009	Turbidity	HACH 2100P	13	NTU	
Effluent-Tote 1	E1	11/5/2009	Dissolved Oxygen	YSI 556	0.1	mg/L	
Effluent-Tote 1	E1	11/5/2009	Flow	Visual flow meter	3	gpm	

Station	Sample ID	Date	Analyte	Method	Result	Units	Qualifier
Effluent-Tote 1	E1	11/5/2009	ORP	YSI 556	-213	mV	
Effluent-Tote 1	E1	11/5/2009	pH	YSI 556	8.32	su	
Effluent-Tote 1	E1	11/5/2009	Specific Conductivity	YSI 556	355	uS/cm	
Effluent-Tote 1	E1	11/5/2009	Temperature	YSI 556	10.78	C	
Effluent-Tote 1	E1	11/5/2009	Turbidity	HACH 2100P	3.58	NTU	
Influent	LSS-SP-N	11/5/2009	Dissolved Oxygen	YSI 556	8.6	mg/L	
Influent	LSS-SP-N	11/5/2009	ORP	YSI 556	-90.6	mV	
Influent	LSS-SP-N	11/5/2009	pH	YSI 556	7.81	su	
Influent	LSS-SP-N	11/5/2009	Specific Conductivity	YSI 556	369	uS/cm	
Influent	LSS-SP-N	11/5/2009	Temperature	YSI 556	10.3	C	
Influent	LSS-SP-N	11/5/2009	Turbidity	HACH 2100P	0.48	NTU	
Pond	PD	11/5/2009	Dissolved Oxygen	YSI 556	4.86	mg/L	
Pond	PD	11/5/2009	ORP	YSI 556	-58.4	mV	
Pond	PD	11/5/2009	pH	YSI 556	8.07	su	
Pond	PD	11/5/2009	Specific Conductivity	YSI 556	352	uS/cm	
Pond	PD	11/5/2009	Temperature	YSI 556	9.2	C	
Pond	PD	11/5/2009	Turbidity	HACH 2100P	15.7	NTU	
Tote Effluent	TEF	11/5/2009	Dissolved Oxygen	YSI 556	0.84	mg/L	
Tote Effluent	TEF	11/5/2009	Flow	Visual flow meter	18	gpm	
Tote Effluent	TEF	11/5/2009	ORP	YSI 556	-213.3	mV	
Tote Effluent	TEF	11/5/2009	pH	YSI 556	8.32	su	
Tote Effluent	TEF	11/5/2009	Specific Conductivity	YSI 556	352	uS/cm	
Tote Effluent	TEF	11/5/2009	Temperature	YSI 556	11.45	C	
Tote Effluent	TEF	11/5/2009	Turbidity	HACH 2100P	3.58	NTU	
Discharge	EF	11/6/2009	Dissolved Oxygen	YSI 556	5.23	mg/L	
Discharge	EF	11/6/2009	Iron, Ferrous	HACH Colorimeter	0.03	mg/L	
Discharge	EF	11/6/2009	Iron, Total	HACH Colorimeter	0.04	mg/L	
Discharge	EF	11/6/2009	ORP	YSI 556	36.6	mV	
Discharge	EF	11/6/2009	pH	YSI 556	8.04	su	
Discharge	EF	11/6/2009	Specific Conductivity	YSI 556	352	uS/cm	
Discharge	EF	11/6/2009	Temperature	YSI 556	8.18	C	
Discharge	EF	11/6/2009	Turbidity	HACH 2100P	10.1	NTU	
Effluent-Tote 1	E1	11/6/2009	Dissolved Oxygen	YSI 556	0.08	mg/L	
Effluent-Tote 1	E1	11/6/2009	Flow	Visual flow meter	3	gpm	
Effluent-Tote 1	E1	11/6/2009	ORP	YSI 556	-299.7	mV	
Effluent-Tote 1	E1	11/6/2009	pH	YSI 556	8.63	su	
Effluent-Tote 1	E1	11/6/2009	Specific Conductivity	YSI 556	355	uS/cm	
Effluent-Tote 1	E1	11/6/2009	Temperature	YSI 556	10.51	C	
Effluent-Tote 1	E1	11/6/2009	Turbidity	HACH 2100P	2	NTU	
Influent	LSS-SP-N	11/6/2009	Dissolved Oxygen	YSI 556	8.51	mg/L	
Influent	LSS-SP-N	11/6/2009	ORP	YSI 556	-75.5	mV	
Influent	LSS-SP-N	11/6/2009	pH	YSI 556	7.77	su	
Influent	LSS-SP-N	11/6/2009	Specific Conductivity	YSI 556	369	uS/cm	
Influent	LSS-SP-N	11/6/2009	Temperature	YSI 556	10	C	
Influent	LSS-SP-N	11/6/2009	Turbidity	HACH 2100P	0.52	NTU	
Pond	PD	11/6/2009	Dissolved Oxygen	YSI 556	4.4	mg/L	
Pond	PD	11/6/2009	ORP	YSI 556	3	mV	
Pond	PD	11/6/2009	pH	YSI 556	8.01	su	
Pond	PD	11/6/2009	Specific Conductivity	YSI 556	352	uS/cm	
Pond	PD	11/6/2009	Temperature	YSI 556	8.43	C	
Pond	PD	11/6/2009	Turbidity	HACH 2100P	17.1	NTU	
Tote Effluent	TEF	11/6/2009	Dissolved Oxygen	YSI 556	0.84	mg/L	
Tote Effluent	TEF	11/6/2009	Flow	Visual flow meter	21	gpm	
Tote Effluent	TEF	11/6/2009	ORP	YSI 556	-235	mV	
Tote Effluent	TEF	11/6/2009	pH	YSI 556	8.48	su	
Tote Effluent	TEF	11/6/2009	Specific Conductivity	YSI 556	356	uS/cm	
Tote Effluent	TEF	11/6/2009	Temperature	YSI 556	10.94	C	
Tote Effluent	TEF	11/6/2009	Turbidity	HACH 2100P	16.2	NTU	
Discharge	EF	11/9/2009	Dissolved Oxygen	YSI 556	7.32	mg/L	
Discharge	EF	11/9/2009	Iron, Ferrous	HACH Colorimeter	0.04	mg/L	

Station	Sample ID	Date	Analyte	Method	Result	Units	Qualifier
Discharge	EF	11/9/2009	Iron, Total	HACH Colorimeter	0.06	mg/L	
Discharge	EF	11/9/2009	ORP	YSI 556	17.4	mV	
Discharge	EF	11/9/2009	pH	YSI 556	8.26	su	
Discharge	EF	11/9/2009	Specific Conductivity	YSI 556	352	uS/cm	
Discharge	EF	11/9/2009	Temperature	YSI 556	8.43	C	
Discharge	EF	11/9/2009	Turbidity	HACH 2100P	8.32	NTU	
Effluent-Tote 1	E1	11/9/2009	Dissolved Oxygen	YSI 556	0.18	mg/L	
Effluent-Tote 1	E1	11/9/2009	Flow	Visual flow meter	3	gpm	
Effluent-Tote 1	E1	11/9/2009	ORP	YSI 556	-267.7	mV	
Effluent-Tote 1	E1	11/9/2009	pH	YSI 556	8.41	su	
Effluent-Tote 1	E1	11/9/2009	Specific Conductivity	YSI 556	354	uS/cm	
Effluent-Tote 1	E1	11/9/2009	Temperature	YSI 556	10.55	C	
Effluent-Tote 1	E1	11/9/2009	Turbidity	HACH 2100P	4.47	NTU	
Influent	LSS-SP-N	11/9/2009	Dissolved Oxygen	YSI 556	8.77	mg/L	
Influent	LSS-SP-N	11/9/2009	ORP	YSI 556	64	mV	
Influent	LSS-SP-N	11/9/2009	pH	YSI 556	7.7	su	
Influent	LSS-SP-N	11/9/2009	Specific Conductivity	YSI 556	368	uS/cm	
Influent	LSS-SP-N	11/9/2009	Temperature	YSI 556	9.95	C	
Influent	LSS-SP-N	11/9/2009	Turbidity	HACH 2100P	0.74	NTU	
Pond	PD	11/9/2009	Dissolved Oxygen	YSI 556	4.9	mg/L	
Pond	PD	11/9/2009	ORP	YSI 556	-0.3	mV	
Pond	PD	11/9/2009	pH	YSI 556	8.26	su	
Pond	PD	11/9/2009	Specific Conductivity	YSI 556	353	uS/cm	
Pond	PD	11/9/2009	Temperature	YSI 556	8.64	C	
Pond	PD	11/9/2009	Turbidity	HACH 2100P	14.7	NTU	
Tote Effluent	TEF	11/9/2009	Dissolved Oxygen	YSI 556	0.66	mg/L	
Tote Effluent	TEF	11/9/2009	Flow	Visual flow meter	21	gpm	
Tote Effluent	TEF	11/9/2009	ORP	YSI 556	-217.8	mV	
Tote Effluent	TEF	11/9/2009	pH	YSI 556	8.38	su	
Tote Effluent	TEF	11/9/2009	Specific Conductivity	YSI 556	355	uS/cm	
Tote Effluent	TEF	11/9/2009	Temperature	YSI 556	10.39	C	
Tote Effluent	TEF	11/9/2009	Turbidity	HACH 2100P	11.7	NTU	
Discharge	EF	11/11/2009	Dissolved Oxygen	YSI 556	5.93	mg/L	
Discharge	EF	11/11/2009	Iron, Ferrous	HACH Colorimeter	0.12	mg/L	
Discharge	EF	11/11/2009	Iron, Total	HACH Colorimeter	0.09	mg/L	
Discharge	EF	11/11/2009	pH	YSI 556	8.2	su	
Discharge	EF	11/11/2009	Specific Conductivity	YSI 556	349	uS/cm	
Discharge	EF	11/11/2009	Temperature	YSI 556	5.62	C	
Discharge	EF	11/11/2009	Turbidity	HACH 2100P	8.56	NTU	
Effluent-Tote 1	E1	11/11/2009	Dissolved Oxygen	YSI 556	0.39	mg/L	
Effluent-Tote 1	E1	11/11/2009	Flow	Visual flow meter	3	gpm	
Effluent-Tote 1	E1	11/11/2009	ORP	YSI 556	252.7	mV	
Effluent-Tote 1	E1	11/11/2009	pH	YSI 556	8.41	su	
Effluent-Tote 1	E1	11/11/2009	Specific Conductivity	YSI 556	355	uS/cm	
Effluent-Tote 1	E1	11/11/2009	Temperature	YSI 556	10	C	
Effluent-Tote 1	E1	11/11/2009	Turbidity	HACH 2100P	2.9	NTU	
Influent	LSS-SP-N	11/11/2009	Dissolved Oxygen	YSI 556	8.37	mg/L	
Influent	LSS-SP-N	11/11/2009	pH	YSI 556	7.85	su	
Influent	LSS-SP-N	11/11/2009	Specific Conductivity	YSI 556	368	uS/cm	
Influent	LSS-SP-N	11/11/2009	Temperature	YSI 556	9.89	C	
Influent	LSS-SP-N	11/11/2009	Turbidity	HACH 2100P	0.47	NTU	
Pond	PD	11/11/2009	Dissolved Oxygen	YSI 556	4.33	mg/L	
Pond	PD	11/11/2009	pH	YSI 556	8.2	su	
Pond	PD	11/11/2009	Specific Conductivity	YSI 556	344	uS/cm	
Pond	PD	11/11/2009	Temperature	YSI 556	6.87	C	
Pond	PD	11/11/2009	Turbidity	HACH 2100P	11.8	NTU	
Tote Effluent	TEF	11/11/2009	Dissolved Oxygen	YSI 556	1.36	mg/L	
Tote Effluent	TEF	11/11/2009	Flow	Visual flow meter	24	gpm	
Tote Effluent	TEF	11/11/2009	ORP	YSI 556	-203.4	mV	
Tote Effluent	TEF	11/11/2009	pH	YSI 556	8.53	su	

Station	Sample ID	Date	Analyte	Method	Result	Units	Qualifier
Tote Effluent	TEF	11/11/2009	Specific Conductivity	YSI 556	350	uS/cm	
Tote Effluent	TEF	11/11/2009	Temperature	YSI 556	10.14	C	
Tote Effluent	TEF	11/11/2009	Turbidity	HACH 2100P	14.1	NTU	
Discharge	EF	11/22/2009	Dissolved Oxygen	YSI 556	9.92	mg/L	
Discharge	EF	11/22/2009	Iron, Ferrous	HACH Colorimeter	0.04	mg/L	
Discharge	EF	11/22/2009	Iron, Total	HACH Colorimeter	0.07	mg/L	
Discharge	EF	11/22/2009	ORP	YSI 556	-15.9	mV	
Discharge	EF	11/22/2009	pH	YSI 556	8.54	su	
Discharge	EF	11/22/2009	Specific Conductivity	YSI 556	349	uS/cm	
Discharge	EF	11/22/2009	Temperature	YSI 556	2.15	C	
Discharge	EF	11/22/2009	Turbidity	HACH 2100P	3.2	NTU	
Effluent-Tote 1	E1	11/22/2009	Dissolved Oxygen	YSI 556	0.57	mg/L	
Effluent-Tote 1	E1	11/22/2009	Flow	Visual flow meter	3	gpm	
Effluent-Tote 1	E1	11/22/2009	ORP	YSI 556	-226.9	mV	
Effluent-Tote 1	E1	11/22/2009	pH	YSI 556	8.34	su	
Effluent-Tote 1	E1	11/22/2009	Specific Conductivity	YSI 556	356	uS/cm	
Effluent-Tote 1	E1	11/22/2009	Temperature	YSI 556	8.87	C	
Effluent-Tote 1	E1	11/22/2009	Turbidity	HACH 2100P	2.87	NTU	
Influent	LSS-SP-N	11/22/2009	Dissolved Oxygen	YSI 556	7.97	mg/L	
Influent	LSS-SP-N	11/22/2009	ORP	YSI 556	-62.7	mV	
Influent	LSS-SP-N	11/22/2009	pH	YSI 556	7.81	su	
Influent	LSS-SP-N	11/22/2009	Specific Conductivity	YSI 556	372	uS/cm	
Influent	LSS-SP-N	11/22/2009	Temperature	YSI 556	9.33	C	
Influent	LSS-SP-N	11/22/2009	Turbidity	HACH 2100P	0.52	NTU	
Pond	PD	11/22/2009	Dissolved Oxygen	YSI 556	6.25	mg/L	
Pond	PD	11/22/2009	ORP	YSI 556	-25.4	mV	
Pond	PD	11/22/2009	pH	YSI 556	8.4	su	
Pond	PD	11/22/2009	Specific Conductivity	YSI 556	344	uS/cm	
Pond	PD	11/22/2009	Temperature	YSI 556	4.34	C	
Pond	PD	11/22/2009	Turbidity	HACH 2100P	10.5	NTU	
Tote Effluent	TEF	11/22/2009	Dissolved Oxygen	YSI 556	1.37	mg/L	
Tote Effluent	TEF	11/22/2009	Flow	Visual flow meter	24	gpm	
Tote Effluent	TEF	11/22/2009	ORP	YSI 556	-199.7	mV	
Tote Effluent	TEF	11/22/2009	pH	YSI 556	8.42	su	
Tote Effluent	TEF	11/22/2009	Specific Conductivity	YSI 556	340	uS/cm	
Tote Effluent	TEF	11/22/2009	Temperature	YSI 556	8.19	C	
Tote Effluent	TEF	11/22/2009	Turbidity	HACH 2100P	10.7	NTU	
Discharge	EF	12/8/2009	Dissolved Oxygen	YSI 556	9.5	mg/L	
Discharge	EF	12/8/2009	ORP	YSI 556	154.4	mV	
Discharge	EF	12/8/2009	pH	YSI 556	8.27	su	
Discharge	EF	12/8/2009	Specific Conductivity	YSI 556	336	uS/cm	
Discharge	EF	12/8/2009	Temperature	YSI 556	2.24	C	
Pond	PD	12/8/2009	Dissolved Oxygen	YSI 556	6.15	mg/L	
Pond	PD	12/8/2009	ORP	YSI 556	-95.7	mV	
Pond	PD	12/8/2009	pH	YSI 556	8.27	su	
Pond	PD	12/8/2009	Specific Conductivity	YSI 556	339	uS/cm	
Pond	PD	12/8/2009	Temperature	YSI 556	6.02	C	
Discharge	EF	12/16/2009	Dissolved Oxygen	YSI 556	10.58	mg/L	
Discharge	EF	12/16/2009	Iron, Ferrous	HACH Colorimeter	0.05	mg/L	
Discharge	EF	12/16/2009	Iron, Total	HACH Colorimeter	0.11	mg/L	
Discharge	EF	12/16/2009	ORP	YSI 556	114.2	mV	
Discharge	EF	12/16/2009	pH	YSI 556	8.32	su	
Discharge	EF	12/16/2009	Specific Conductivity	YSI 556	312	uS/cm	
Discharge	EF	12/16/2009	Temperature	YSI 556	2.62	C	
Discharge	EF	12/16/2009	Turbidity	HACH 2100P	9.2	NTU	
Pond	PD	12/16/2009	Dissolved Oxygen	YSI 556	5.66	mg/L	
Pond	PD	12/16/2009	ORP	YSI 556	-112.7	mV	
Pond	PD	12/16/2009	pH	YSI 556	8.32	su	
Pond	PD	12/16/2009	Specific Conductivity	YSI 556	322	uS/cm	
Pond	PD	12/16/2009	Temperature	YSI 556	6.71	C	

Station	Sample ID	Date	Analyte	Method	Result	Units	Qualifier
Pond	PD	12/16/2009	Turbidity	HACH 2100P	24.1	NTU	
Tote Effluent	TEF	12/16/2009	Dissolved Oxygen	YSI 556	1.48	mg/L	
Tote Effluent	TEF	12/16/2009	Flow	Visual flow meter	24	gpm	
Tote Effluent	TEF	12/16/2009	ORP	YSI 556	-203.2	mV	
Tote Effluent	TEF	12/16/2009	pH	YSI 556	8.15	su	
Tote Effluent	TEF	12/16/2009	Specific Conductivity	YSI 556	329	uS/cm	
Tote Effluent	TEF	12/16/2009	Temperature	YSI 556	8.44	C	
Tote Effluent	TEF	12/16/2009	Turbidity	HACH 2100P	11.1	NTU	
Discharge	EF	1/11/2010	Dissolved Oxygen	YSI 556	13.14	mg/L	
Discharge	EF	1/11/2010	Iron, Ferrous	HACH Colorimeter	0.07	mg/L	
Discharge	EF	1/11/2010	Iron, Total	HACH Colorimeter	0.1	mg/L	
Discharge	EF	1/11/2010	ORP	YSI 556	158.6	mV	
Discharge	EF	1/11/2010	pH	YSI 556	8.27	su	
Discharge	EF	1/11/2010	Specific Conductivity	YSI 556	348	uS/cm	
Discharge	EF	1/11/2010	Temperature	YSI 556	4.85	C	
Discharge	EF	1/11/2010	Turbidity	HACH 2100P	6.6	NTU	
Influent	LSS-SP-N	1/11/2010	Dissolved Oxygen	YSI 556	9.43	mg/L	
Influent	LSS-SP-N	1/11/2010	ORP	YSI 556	28.7	mV	
Influent	LSS-SP-N	1/11/2010	pH	YSI 556	7.82	su	
Influent	LSS-SP-N	1/11/2010	Specific Conductivity	YSI 556	378	uS/cm	
Influent	LSS-SP-N	1/11/2010	Temperature	YSI 556	9.43	C	
Influent	LSS-SP-N	1/11/2010	Turbidity	HACH 2100P	0.74	NTU	
Pond	PD	1/11/2010	Dissolved Oxygen	YSI 556	7.58	mg/L	
Pond	PD	1/11/2010	ORP	YSI 556	-87	mV	
Pond	PD	1/11/2010	pH	YSI 556	8.12	su	
Pond	PD	1/11/2010	Specific Conductivity	YSI 556	352	uS/cm	
Pond	PD	1/11/2010	Temperature	YSI 556	7.51	C	
Pond	PD	1/11/2010	Turbidity	HACH 2100P	37.4	NTU	
Tote Effluent	TEF	1/11/2010	Dissolved Oxygen	YSI 556	1.65	mg/L	
Tote Effluent	TEF	1/11/2010	Flow	Visual flow meter	24	gpm	
Tote Effluent	TEF	1/11/2010	ORP	YSI 556	-211.3	mV	
Tote Effluent	TEF	1/11/2010	pH	YSI 556	8.17	su	
Tote Effluent	TEF	1/11/2010	Specific Conductivity	YSI 556	357	uS/cm	
Tote Effluent	TEF	1/11/2010	Temperature	YSI 556	9.14	C	
Tote Effluent	TEF	1/11/2010	Turbidity	HACH 2100P	6.37	NTU	
Discharge	EF	2/10/2010	Dissolved Oxygen	YSI 556	13.17	mg/L	
Discharge	EF	2/10/2010	ORP	YSI 556	131.2	mV	
Discharge	EF	2/10/2010	pH	YSI 556	8.48	su	
Discharge	EF	2/10/2010	Specific Conductivity	YSI 556	335	uS/cm	
Discharge	EF	2/10/2010	Temperature	YSI 556	2.35	C	
Discharge	EF	2/10/2010	Turbidity	HACH 2100P	5.3	NTU	
Influent	LSS-SP-N	2/10/2010	Dissolved Oxygen	YSI 556	9.2	mg/L	
Influent	LSS-SP-N	2/10/2010	ORP	YSI 556	12.5	mV	
Influent	LSS-SP-N	2/10/2010	pH	YSI 556	7.78	su	
Influent	LSS-SP-N	2/10/2010	Specific Conductivity	YSI 556	378	uS/cm	
Influent	LSS-SP-N	2/10/2010	Temperature	YSI 556	9.23	C	
Pond	PD	2/10/2010	Dissolved Oxygen	YSI 556	7.2	mg/L	
Pond	PD	2/10/2010	ORP	YSI 556	-143.3	mV	
Pond	PD	2/10/2010	pH	YSI 556	8.2	su	
Pond	PD	2/10/2010	Specific Conductivity	YSI 556	333	uS/cm	
Pond	PD	2/10/2010	Temperature	YSI 556	6.34	C	
Tote Effluent	TEF	2/10/2010	Dissolved Oxygen	YSI 556	2.28	mg/L	
Tote Effluent	TEF	2/10/2010	Flow	Visual flow meter	24	gpm	
Tote Effluent	TEF	2/10/2010	ORP	YSI 556	-265.5	mV	
Tote Effluent	TEF	2/10/2010	pH	YSI 556	8.54	su	
Tote Effluent	TEF	2/10/2010	Specific Conductivity	YSI 556	308	uS/cm	
Tote Effluent	TEF	2/10/2010	Temperature	YSI 556	8.11	C	
Discharge	EF	3/2/2010	Dissolved Oxygen	YSI 556	14.43	mg/L	
Discharge	EF	3/2/2010	ORP	YSI 556	156	mV	
Discharge	EF	3/2/2010	pH	YSI 556	8.44	su	

Station	Sample ID	Date	Analyte	Method	Result	Units	Qualifier
Discharge	EF	3/2/2010	Specific Conductivity	YSI 556	348	uS/cm	
Discharge	EF	3/2/2010	Temperature	YSI 556	6.13	C	
Discharge	EF	3/2/2010	Turbidity	HACH 2100P	18.4	NTU	
Influent	LSS-SP-N	3/2/2010	Dissolved Oxygen	YSI 556	9.7	mg/L	
Influent	LSS-SP-N	3/2/2010	ORP	YSI 556	48.9	mV	
Influent	LSS-SP-N	3/2/2010	pH	YSI 556	7.71	su	
Influent	LSS-SP-N	3/2/2010	Specific Conductivity	YSI 556	380	uS/cm	
Influent	LSS-SP-N	3/2/2010	Temperature	YSI 556	9.55	C	
Pond	PD	3/2/2010	Dissolved Oxygen	YSI 556	8.53	mg/L	
Pond	PD	3/2/2010	ORP	YSI 556	-2.4	mV	
Pond	PD	3/2/2010	pH	YSI 556	8.22	su	
Pond	PD	3/2/2010	Specific Conductivity	YSI 556	355	uS/cm	
Pond	PD	3/2/2010	Temperature	YSI 556	7.69	C	
Tote Effluent	TEF	3/2/2010	Dissolved Oxygen	YSI 556	2.66	mg/L	
Tote Effluent	TEF	3/2/2010	Flow	Visual flow meter	21	gpm	
Tote Effluent	TEF	3/2/2010	ORP	YSI 556	-246.7	mV	
Tote Effluent	TEF	3/2/2010	pH	YSI 556	8.24	su	
Tote Effluent	TEF	3/2/2010	Specific Conductivity	YSI 556	340	uS/cm	
Tote Effluent	TEF	3/2/2010	Temperature	YSI 556	9.15	C	
Tote Effluent	TEF	6/23/2010	Dissolved Oxygen	YSI 556	4.72	mg/L	
Tote Effluent	TEF	6/23/2010	Dissolved Oxygen	YSI 556	3.6	mg/L	
Tote Effluent	TEF	6/23/2010	Dissolved Oxygen	YSI 556	3.78	mg/L	
Tote Effluent	TEF	6/23/2010	Dissolved Oxygen	YSI 556	3.54	mg/L	
Tote Effluent	TEF	6/23/2010	Dissolved Oxygen	YSI 556	2.83	mg/L	
Tote Effluent	TEF	6/23/2010	Dissolved Oxygen	YSI 556	268	mg/L	
Tote Effluent	TEF	6/23/2010	Dissolved Oxygen	YSI 556	2.32	mg/L	
Tote Effluent	TEF	6/23/2010	Dissolved Oxygen	YSI 556	2.25	mg/L	
Tote Effluent	TEF	6/23/2010	Dissolved Oxygen	YSI 556	2.74	mg/L	
Tote Effluent	TEF	6/23/2010	Dissolved Oxygen	YSI 556	2.35	mg/L	
Tote Effluent	TEF	6/23/2010	Dissolved Oxygen	YSI 556	2.11	mg/L	
Tote Effluent	TEF	6/23/2010	Dissolved Oxygen	YSI 556	2.03	mg/L	
Tote Effluent	TEF	6/23/2010	Dissolved Oxygen	YSI 556	1.84	mg/L	
Tote Effluent	TEF	6/23/2010	Dissolved Oxygen	YSI 556	1.8	mg/L	
Tote Effluent	TEF	6/23/2010	Dissolved Oxygen	YSI 556	1.78	mg/L	
Tote Effluent	TEF	6/23/2010	Dissolved Oxygen	YSI 556	1.78	mg/L	
Tote Effluent	TEF	6/23/2010	Dissolved Oxygen	YSI 556	1.81	mg/L	
Tote Effluent	TEF	6/23/2010	Dissolved Oxygen	YSI 556	1.75	mg/L	
Tote Effluent	TEF	6/23/2010	Dissolved Oxygen	YSI 556	1.81	mg/L	
Tote Effluent	TEF	6/23/2010	Dissolved Oxygen	YSI 556	1.8	mg/L	
Tote Effluent	TEF	6/23/2010	Dissolved Oxygen	YSI 556	1.77	mg/L	
Tote Effluent	TEF	6/23/2010	Dissolved Oxygen	YSI 556	1.81	mg/L	
Tote Effluent	TEF	6/23/2010	Dissolved Oxygen	YSI 556	1.89	mg/L	
Tote Effluent	TEF	6/23/2010	Dissolved Oxygen	YSI 556	1.9	mg/L	
Tote Effluent	TEF	6/23/2010	Flow	Visual flow meter	3	gpm	
Tote Effluent	TEF	6/23/2010	Flow	Visual flow meter	3	gpm	
Tote Effluent	TEF	6/23/2010	Flow	Visual flow meter	6	gpm	
Tote Effluent	TEF	6/23/2010	Flow	Visual flow meter	6	gpm	
Tote Effluent	TEF	6/23/2010	Flow	Visual flow meter	9	gpm	
Tote Effluent	TEF	6/23/2010	Flow	Visual flow meter	9	gpm	
Tote Effluent	TEF	6/23/2010	Flow	Visual flow meter	9	gpm	
Tote Effluent	TEF	6/23/2010	Flow	Visual flow meter	12	gpm	
Tote Effluent	TEF	6/23/2010	Flow	Visual flow meter	12	gpm	
Tote Effluent	TEF	6/23/2010	Flow	Visual flow meter	12	gpm	
Tote Effluent	TEF	6/23/2010	Flow	Visual flow meter	15	gpm	
Tote Effluent	TEF	6/23/2010	Flow	Visual flow meter	15	gpm	
Tote Effluent	TEF	6/23/2010	Flow	Visual flow meter	18	gpm	
Tote Effluent	TEF	6/23/2010	Flow	Visual flow meter	18	gpm	
Tote Effluent	TEF	6/23/2010	Flow	Visual flow meter	21	gpm	
Tote Effluent	TEF	6/23/2010	Flow	Visual flow meter	21	gpm	
Tote Effluent	TEF	6/23/2010	Flow	Visual flow meter	24	gpm	

Station	Sample ID	Date	Analyte	Method	Result	Units	Qualifier
Tote Effluent	TEF	6/23/2010	Flow	Visual flow meter	24	gpm	
Tote Effluent	TEF	6/23/2010	Flow	Visual flow meter	24	gpm	
Tote Effluent	TEF	6/23/2010	Flow	Visual flow meter	24	gpm	
Tote Effluent	TEF	6/23/2010	Flow	Visual flow meter	24	gpm	
Tote Effluent	TEF	6/23/2010	Flow	Visual flow meter	24	gpm	
Tote Effluent	TEF	6/23/2010	Flow	Visual flow meter	24	gpm	
Tote Effluent	TEF	6/23/2010	Flow	Visual flow meter	24	gpm	
Tote Effluent	TEF	6/23/2010	Iron, Ferrous	HACH Colorimeter	0.07	mg/L	
Tote Effluent	TEF	6/23/2010	Iron, Total	HACH Colorimeter	0.19	mg/L	
Tote Effluent	TEF	6/23/2010	ORP	YSI 556	-196.8	mV	
Tote Effluent	TEF	6/23/2010	ORP	YSI 556	-202.5	mV	
Tote Effluent	TEF	6/23/2010	ORP	YSI 556	-202.8	mV	
Tote Effluent	TEF	6/23/2010	ORP	YSI 556	-208.5	mV	
Tote Effluent	TEF	6/23/2010	ORP	YSI 556	-228.5	mV	
Tote Effluent	TEF	6/23/2010	ORP	YSI 556	-232	mV	
Tote Effluent	TEF	6/23/2010	ORP	YSI 556	-242.2	mV	
Tote Effluent	TEF	6/23/2010	ORP	YSI 556	-251.6	mV	
Tote Effluent	TEF	6/23/2010	ORP	YSI 556	-253.2	mV	
Tote Effluent	TEF	6/23/2010	ORP	YSI 556	-247.7	mV	
Tote Effluent	TEF	6/23/2010	ORP	YSI 556	-255.9	mV	
Tote Effluent	TEF	6/23/2010	ORP	YSI 556	-256.1	mV	
Tote Effluent	TEF	6/23/2010	ORP	YSI 556	-263.1	mV	
Tote Effluent	TEF	6/23/2010	ORP	YSI 556	-251.5	mV	
Tote Effluent	TEF	6/23/2010	ORP	YSI 556	-256.6	mV	
Tote Effluent	TEF	6/23/2010	ORP	YSI 556	-254.1	mV	
Tote Effluent	TEF	6/23/2010	ORP	YSI 556	-258.7	mV	
Tote Effluent	TEF	6/23/2010	ORP	YSI 556	-248.1	mV	
Tote Effluent	TEF	6/23/2010	ORP	YSI 556	-244.5	mV	
Tote Effluent	TEF	6/23/2010	ORP	YSI 556	-240.3	mV	
Tote Effluent	TEF	6/23/2010	ORP	YSI 556	-226.6	mV	
Tote Effluent	TEF	6/23/2010	ORP	YSI 556	-227.1	mV	
Tote Effluent	TEF	6/23/2010	ORP	YSI 556	-215.3	mV	
Tote Effluent	TEF	6/23/2010	ORP	YSI 556	-220.7	mV	
Tote Effluent	TEF	6/23/2010	pH	YSI 556	9.27	su	
Tote Effluent	TEF	6/23/2010	pH	YSI 556	8.89	su	
Tote Effluent	TEF	6/23/2010	pH	YSI 556	8.78	su	
Tote Effluent	TEF	6/23/2010	pH	YSI 556	8.79	su	
Tote Effluent	TEF	6/23/2010	pH	YSI 556	9.06	su	
Tote Effluent	TEF	6/23/2010	pH	YSI 556	9.11	su	
Tote Effluent	TEF	6/23/2010	pH	YSI 556	9.18	su	
Tote Effluent	TEF	6/23/2010	pH	YSI 556	9.29	su	
Tote Effluent	TEF	6/23/2010	pH	YSI 556	9.22	su	
Tote Effluent	TEF	6/23/2010	pH	YSI 556	9.2	su	
Tote Effluent	TEF	6/23/2010	pH	YSI 556	9.29	su	
Tote Effluent	TEF	6/23/2010	pH	YSI 556	9.33	su	
Tote Effluent	TEF	6/23/2010	pH	YSI 556	9.5	su	
Tote Effluent	TEF	6/23/2010	pH	YSI 556	9.16	su	
Tote Effluent	TEF	6/23/2010	pH	YSI 556	9.35	su	
Tote Effluent	TEF	6/23/2010	pH	YSI 556	9.26	su	
Tote Effluent	TEF	6/23/2010	pH	YSI 556	9.39	su	
Tote Effluent	TEF	6/23/2010	pH	YSI 556	9.2	su	
Tote Effluent	TEF	6/23/2010	pH	YSI 556	9.18	su	
Tote Effluent	TEF	6/23/2010	pH	YSI 556	9.25	su	
Tote Effluent	TEF	6/23/2010	pH	YSI 556	9	su	
Tote Effluent	TEF	6/23/2010	pH	YSI 556	9.12	su	
Tote Effluent	TEF	6/23/2010	pH	YSI 556	8.98	su	
Tote Effluent	TEF	6/23/2010	pH	YSI 556	8.98	su	
Tote Effluent	TEF	6/23/2010	Specific Conductivity	YSI 556	132	uS/cm	
Tote Effluent	TEF	6/23/2010	Specific Conductivity	YSI 556	183	uS/cm	
Tote Effluent	TEF	6/23/2010	Specific Conductivity	YSI 556	206	uS/cm	

Station	Sample ID	Date	Analyte	Method	Result	Units	Qualifier
Tote Effluent	TEF	6/23/2010	Specific Conductivity	YSI 556	209	uS/cm	
Tote Effluent	TEF	6/23/2010	Specific Conductivity	YSI 556	190	uS/cm	
Tote Effluent	TEF	6/23/2010	Specific Conductivity	YSI 556	198	uS/cm	
Tote Effluent	TEF	6/23/2010	Specific Conductivity	YSI 556	180	uS/cm	
Tote Effluent	TEF	6/23/2010	Specific Conductivity	YSI 556	170	uS/cm	
Tote Effluent	TEF	6/23/2010	Specific Conductivity	YSI 556	182	uS/cm	
Tote Effluent	TEF	6/23/2010	Specific Conductivity	YSI 556	194	uS/cm	
Tote Effluent	TEF	6/23/2010	Specific Conductivity	YSI 556	186	uS/cm	
Tote Effluent	TEF	6/23/2010	Specific Conductivity	YSI 556	193	uS/cm	
Tote Effluent	TEF	6/23/2010	Specific Conductivity	YSI 556	186	uS/cm	
Tote Effluent	TEF	6/23/2010	Specific Conductivity	YSI 556	195	uS/cm	
Tote Effluent	TEF	6/23/2010	Specific Conductivity	YSI 556	197	uS/cm	
Tote Effluent	TEF	6/23/2010	Specific Conductivity	YSI 556	208	uS/cm	
Tote Effluent	TEF	6/23/2010	Specific Conductivity	YSI 556	203	uS/cm	
Tote Effluent	TEF	6/23/2010	Specific Conductivity	YSI 556	207	uS/cm	
Tote Effluent	TEF	6/23/2010	Specific Conductivity	YSI 556	215	uS/cm	
Tote Effluent	TEF	6/23/2010	Specific Conductivity	YSI 556	225	uS/cm	
Tote Effluent	TEF	6/23/2010	Specific Conductivity	YSI 556	235	uS/cm	
Tote Effluent	TEF	6/23/2010	Specific Conductivity	YSI 556	242	uS/cm	
Tote Effluent	TEF	6/23/2010	Specific Conductivity	YSI 556	256	uS/cm	
Tote Effluent	TEF	6/23/2010	Specific Conductivity	YSI 556	262	uS/cm	
Tote Effluent	TEF	6/23/2010	Temperature	YSI 556	10.63	C	
Tote Effluent	TEF	6/23/2010	Temperature	YSI 556	11.35	C	
Tote Effluent	TEF	6/23/2010	Temperature	YSI 556	11.48	C	
Tote Effluent	TEF	6/23/2010	Temperature	YSI 556	12	C	
Tote Effluent	TEF	6/23/2010	Temperature	YSI 556	12.17	C	
Tote Effluent	TEF	6/23/2010	Temperature	YSI 556	12.25	C	
Tote Effluent	TEF	6/23/2010	Temperature	YSI 556	12.31	C	
Tote Effluent	TEF	6/23/2010	Temperature	YSI 556	12.19	C	
Tote Effluent	TEF	6/23/2010	Temperature	YSI 556	12.17	C	
Tote Effluent	TEF	6/23/2010	Temperature	YSI 556	12.1	C	
Tote Effluent	TEF	6/23/2010	Temperature	YSI 556	11.96	C	
Tote Effluent	TEF	6/23/2010	Temperature	YSI 556	11.9	C	
Tote Effluent	TEF	6/23/2010	Temperature	YSI 556	11.78	C	
Tote Effluent	TEF	6/23/2010	Temperature	YSI 556	11.73	C	
Tote Effluent	TEF	6/23/2010	Temperature	YSI 556	11.64	C	
Tote Effluent	TEF	6/23/2010	Temperature	YSI 556	11.58	C	
Tote Effluent	TEF	6/23/2010	Temperature	YSI 556	11.48	C	
Tote Effluent	TEF	6/23/2010	Temperature	YSI 556	11.53	C	
Tote Effluent	TEF	6/23/2010	Temperature	YSI 556	11.54	C	
Tote Effluent	TEF	6/23/2010	Temperature	YSI 556	11.44	C	
Tote Effluent	TEF	6/23/2010	Temperature	YSI 556	11.41	C	
Tote Effluent	TEF	6/23/2010	Temperature	YSI 556	11.36	C	
Tote Effluent	TEF	6/23/2010	Temperature	YSI 556	11.43	C	
Tote Effluent	TEF	6/23/2010	Temperature	YSI 556	11.11	C	
Tote Effluent	TEF	6/23/2010	Turbidity	HACH 2100P	7.14	NTU	
Tote Effluent	TEF	6/23/2010	Turbidity	HACH 2100P	2.69	NTU	
Tote Effluent	TEF	6/23/2010	Turbidity	HACH 2100P	3.68	NTU	
Tote Effluent	TEF	6/23/2010	Turbidity	HACH 2100P	17.8	NTU	
Tote Effluent	TEF	6/23/2010	Turbidity	HACH 2100P	4.1	NTU	
Tote Effluent	TEF	6/23/2010	Turbidity	HACH 2100P	2.38	NTU	
Tote Effluent	TEF	6/23/2010	Turbidity	HACH 2100P	5.64	NTU	
Tote Effluent	TEF	6/23/2010	Turbidity	HACH 2100P	4.38	NTU	
Tote Effluent	TEF	6/23/2010	Turbidity	HACH 2100P	31.6	NTU	
Tote Effluent	TEF	6/23/2010	Turbidity	HACH 2100P	4.12	NTU	
Tote Effluent	TEF	6/23/2010	Turbidity	HACH 2100P	4.43	NTU	
Tote Effluent	TEF	6/23/2010	Turbidity	HACH 2100P	3.6	NTU	
Tote Effluent	TEF	6/23/2010	Turbidity	HACH 2100P	8.1	NTU	
Tote Effluent	TEF	6/23/2010	Turbidity	HACH 2100P	6.65	NTU	
Tote Effluent	TEF	6/23/2010	Turbidity	HACH 2100P	8.65	NTU	

Station	Sample ID	Date	Analyte	Method	Result	Units	Qualifier
Tote Effluent	TEF	6/23/2010	Turbidity	HACH 2100P	1.51	NTU	
Tote Effluent	TEF	6/23/2010	Turbidity	HACH 2100P	7.76	NTU	
Tote Effluent	TEF	6/23/2010	Turbidity	HACH 2100P	4.8	NTU	
Tote Effluent	TEF	6/23/2010	Turbidity	HACH 2100P	4	NTU	
Tote Effluent	TEF	6/23/2010	Turbidity	HACH 2100P	3.23	NTU	
Tote Effluent	TEF	6/23/2010	Turbidity	HACH 2100P	8.57	NTU	
Tote Effluent	TEF	6/23/2010	Turbidity	HACH 2100P	2.49	NTU	
Tote Effluent	TEF	6/23/2010	Turbidity	HACH 2100P	2.62	NTU	
Tote Effluent	TEF	6/23/2010	Turbidity	HACH 2100P	2.73	NTU	
Discharge	EF	6/24/2010	Dissolved Oxygen	YSI 556	8.11	mg/L	
Discharge	EF	6/24/2010	Iron, Ferrous	HACH Colorimeter	0.12	mg/L	
Discharge	EF	6/24/2010	Iron, Total	HACH Colorimeter	0	mg/L	
Discharge	EF	6/24/2010	ORP	YSI 556	-44	mV	
Discharge	EF	6/24/2010	pH	YSI 556	8.64	su	
Discharge	EF	6/24/2010	Specific Conductivity	YSI 556	258	uS/cm	
Discharge	EF	6/24/2010	Temperature	YSI 556	15.23	C	
Discharge	EF	6/24/2010	Turbidity	HACH 2100P	4.2	NTU	
Influent	LSS-IN	6/24/2010	Dissolved Oxygen	YSI 556	8.59	mg/L	
Influent	LSS-IN	6/24/2010	Iron, Ferrous	HACH Colorimeter	0	mg/L	
Influent	LSS-IN	6/24/2010	Iron, Total	HACH Colorimeter	0	mg/L	
Influent	LSS-IN	6/24/2010	ORP	YSI 556	-46.5	mV	
Influent	LSS-IN	6/24/2010	pH	YSI 556	7.88	su	
Influent	LSS-IN	6/24/2010	Specific Conductivity	YSI 556	362	uS/cm	
Influent	LSS-IN	6/24/2010	Temperature	YSI 556	10.33	C	
Influent	LSS-IN	6/24/2010	Turbidity	HACH 2100P	0.85	NTU	
Pond	PD	6/24/2010	Dissolved Oxygen	YSI 556	6.84	mg/L	
Pond	PD	6/24/2010	Iron, Ferrous	HACH Colorimeter	0	mg/L	
Pond	PD	6/24/2010	Iron, Total	HACH Colorimeter	0.04	mg/L	
Pond	PD	6/24/2010	ORP	YSI 556	-102.9	mV	
Pond	PD	6/24/2010	pH	YSI 556	8.69	su	
Pond	PD	6/24/2010	Specific Conductivity	YSI 556	274	uS/cm	
Pond	PD	6/24/2010	Temperature	YSI 556	12.82	C	
Pond	PD	6/24/2010	Turbidity	HACH 2100P	4.69	NTU	
Tote Effluent	TEF	6/24/2010	Dissolved Oxygen	YSI 556	1.72	mg/L	
Tote Effluent	TEF	6/24/2010	Flow	Visual flow meter	24	gpm	
Tote Effluent	TEF	6/24/2010	Iron, Ferrous	HACH Colorimeter	0.81	mg/L	
Tote Effluent	TEF	6/24/2010	Iron, Total	HACH Colorimeter	0.82	mg/L	
Tote Effluent	TEF	6/24/2010	ORP	YSI 556	-210.9	mV	
Tote Effluent	TEF	6/24/2010	pH	YSI 556	8.57	su	
Tote Effluent	TEF	6/24/2010	Specific Conductivity	YSI 556	328	uS/cm	
Tote Effluent	TEF	6/24/2010	Temperature	YSI 556	11.13	C	
Tote Effluent	TEF	6/24/2010	Turbidity	HACH 2100P	5.26	NTU	
Discharge	EF	6/25/2010	Dissolved Oxygen	YSI 556	8.12	mg/L	
Discharge	EF	6/25/2010	Iron, Ferrous	HACH Colorimeter	0.12	mg/L	
Discharge	EF	6/25/2010	Iron, Total	HACH Colorimeter	0.09	mg/L	
Discharge	EF	6/25/2010	ORP	YSI 556	-64.9	mV	
Discharge	EF	6/25/2010	pH	YSI 556	8.43	su	
Discharge	EF	6/25/2010	Specific Conductivity	YSI 556	314	uS/cm	
Discharge	EF	6/25/2010	Temperature	YSI 556	15.14	C	
Discharge	EF	6/25/2010	Turbidity	HACH 2100P	1.36	NTU	
Influent	LSS-IN	6/25/2010	Dissolved Oxygen	YSI 556	8.77	mg/L	
Influent	LSS-IN	6/25/2010	ORP	YSI 556	-49.2	mV	
Influent	LSS-IN	6/25/2010	pH	YSI 556	7.97	su	
Influent	LSS-IN	6/25/2010	Specific Conductivity	YSI 556	362	uS/cm	
Influent	LSS-IN	6/25/2010	Temperature	YSI 556	10.22	C	
Influent	LSS-IN	6/25/2010	Turbidity	HACH 2100P	1.82	NTU	
Pond	PD	6/25/2010	Dissolved Oxygen	YSI 556	6.71	mg/L	
Pond	PD	6/25/2010	ORP	YSI 556	-118.9	mV	
Pond	PD	6/25/2010	pH	YSI 556	8.55	su	
Pond	PD	6/25/2010	Specific Conductivity	YSI 556	326	uS/cm	

Station	Sample ID	Date	Analyte	Method	Result	Units	Qualifier
Pond	PD	6/25/2010	Temperature	YSI 556	13.55	C	
Pond	PD	6/25/2010	Turbidity	HACH 2100P	12.5	NTU	
Tote Effluent	TEF	6/25/2010	Dissolved Oxygen	YSI 556	1.81	mg/L	
Tote Effluent	TEF	6/25/2010	Flow	Visual flow meter	24	gpm	
Tote Effluent	TEF	6/25/2010	ORP	YSI 556	-198.8	mV	
Tote Effluent	TEF	6/25/2010	pH	YSI 556	8.49	su	
Tote Effluent	TEF	6/25/2010	Specific Conductivity	YSI 556	345	uS/cm	
Tote Effluent	TEF	6/25/2010	Temperature	YSI 556	11.22	C	
Tote Effluent	TEF	6/25/2010	Turbidity	HACH 2100P	1.3	NTU	
Discharge	EF	6/26/2010	Dissolved Oxygen	YSI 556	8.35	mg/L	
Discharge	EF	6/26/2010	Iron, Ferrous	HACH Colorimeter	0	mg/L	
Discharge	EF	6/26/2010	Iron, Total	HACH Colorimeter	0.05	mg/L	
Discharge	EF	6/26/2010	ORP	YSI 556	-51.8	mV	
Discharge	EF	6/26/2010	pH	YSI 556	8.35	su	
Discharge	EF	6/26/2010	Specific Conductivity	YSI 556	335	uS/cm	
Discharge	EF	6/26/2010	Temperature	YSI 556	13	C	
Discharge	EF	6/26/2010	Turbidity	HACH 2100P	0.88	NTU	
Influent	LSS-IN	6/26/2010	Dissolved Oxygen	YSI 556	8.69	mg/L	
Influent	LSS-IN	6/26/2010	ORP	YSI 556	-37.7	mV	
Influent	LSS-IN	6/26/2010	pH	YSI 556	7.83	su	
Influent	LSS-IN	6/26/2010	Specific Conductivity	YSI 556	362	uS/cm	
Influent	LSS-IN	6/26/2010	Temperature	YSI 556	10.3	C	
Influent	LSS-IN	6/26/2010	Turbidity	HACH 2100P	0.85	NTU	
Pond	PD	6/26/2010	Dissolved Oxygen	YSI 556	5.72	mg/L	
Pond	PD	6/26/2010	Iron, Ferrous	HACH Colorimeter	0.03	mg/L	
Pond	PD	6/26/2010	Iron, Total	HACH Colorimeter	0.05	mg/L	
Pond	PD	6/26/2010	ORP	YSI 556	-76.6	mV	
Pond	PD	6/26/2010	pH	YSI 556	8.14	su	
Pond	PD	6/26/2010	Specific Conductivity	YSI 556	341	uS/cm	
Pond	PD	6/26/2010	Temperature	YSI 556	11.13	C	
Pond	PD	6/26/2010	Turbidity	HACH 2100P	14.3	NTU	
Tote Effluent	TEF	6/26/2010	Dissolved Oxygen	YSI 556	1.73	mg/L	
Tote Effluent	TEF	6/26/2010	Flow	Visual flow meter	24	gpm	
Tote Effluent	TEF	6/26/2010	Iron, Ferrous	HACH Colorimeter	3.3	mg/L	>
Tote Effluent	TEF	6/26/2010	Iron, Total	HACH Colorimeter	3.3	mg/L	>
Tote Effluent	TEF	6/26/2010	ORP	YSI 556	-202	mV	
Tote Effluent	TEF	6/26/2010	pH	YSI 556	8.22	su	
Tote Effluent	TEF	6/26/2010	Specific Conductivity	YSI 556	352	uS/cm	
Tote Effluent	TEF	6/26/2010	Temperature	YSI 556	10.83	C	
Tote Effluent	TEF	6/26/2010	Turbidity	HACH 2100P	1.44	NTU	
Discharge	EF	6/27/2010	Dissolved Oxygen	YSI 556	8.82	mg/L	
Discharge	EF	6/27/2010	Iron, Ferrous	HACH Colorimeter	0	mg/L	
Discharge	EF	6/27/2010	Iron, Total	HACH Colorimeter	0	mg/L	
Discharge	EF	6/27/2010	ORP	YSI 556	-50.3	mV	
Discharge	EF	6/27/2010	pH	YSI 556	8.31	su	
Discharge	EF	6/27/2010	Specific Conductivity	YSI 556	342	uS/cm	
Discharge	EF	6/27/2010	Temperature	YSI 556	11.31	C	
Discharge	EF	6/27/2010	Turbidity	HACH 2100P	0.99	NTU	
Influent	LSS-IN	6/27/2010	Dissolved Oxygen	YSI 556	8.61	mg/L	
Influent	LSS-IN	6/27/2010	ORP	YSI 556	-36.8	mV	
Influent	LSS-IN	6/27/2010	pH	YSI 556	7.82	su	
Influent	LSS-IN	6/27/2010	Specific Conductivity	YSI 556	362	uS/cm	
Influent	LSS-IN	6/27/2010	Temperature	YSI 556	10.28	C	
Influent	LSS-IN	6/27/2010	Turbidity	HACH 2100P	0.48	NTU	
Pond	PD	6/27/2010	Dissolved Oxygen	YSI 556	5.7	mg/L	
Pond	PD	6/27/2010	Iron, Ferrous	HACH Colorimeter	0.01	mg/L	
Pond	PD	6/27/2010	Iron, Total	HACH Colorimeter	0.08	mg/L	
Pond	PD	6/27/2010	ORP	YSI 556	-63.3	mV	
Pond	PD	6/27/2010	pH	YSI 556	8.14	su	
Pond	PD	6/27/2010	Specific Conductivity	YSI 556	344	uS/cm	

Station	Sample ID	Date	Analyte	Method	Result	Units	Qualifier
Pond	PD	6/27/2010	Temperature	YSI 556	10.51	C	
Pond	PD	6/27/2010	Turbidity	HACH 2100P	22.4	NTU	
Tote Effluent	TEF	6/27/2010	Dissolved Oxygen	YSI 556	1.96	mg/L	
Tote Effluent	TEF	6/27/2010	Flow	Visual flow meter	24	gpm	
Tote Effluent	TEF	6/27/2010	Iron, Ferrous	HACH Colorimeter	3.3	mg/L	>
Tote Effluent	TEF	6/27/2010	Iron, Total	HACH Colorimeter	3.3	mg/L	>
Tote Effluent	TEF	6/27/2010	ORP	YSI 556	-169.1	mV	
Tote Effluent	TEF	6/27/2010	pH	YSI 556	8.13	su	
Tote Effluent	TEF	6/27/2010	Specific Conductivity	YSI 556	356	uS/cm	
Tote Effluent	TEF	6/27/2010	Temperature	YSI 556	11	C	
Tote Effluent	TEF	6/27/2010	Turbidity	HACH 2100P	1.11	NTU	
Discharge	EF	6/28/2010	Dissolved Oxygen	YSI 556	8.65	mg/L	
Discharge	EF	6/28/2010	Iron, Ferrous	HACH Colorimeter	0.04	mg/L	
Discharge	EF	6/28/2010	Iron, Total	HACH Colorimeter	0.05	mg/L	
Discharge	EF	6/28/2010	ORP	YSI 556	-46.2	mV	
Discharge	EF	6/28/2010	pH	YSI 556	8.28	su	
Discharge	EF	6/28/2010	Specific Conductivity	YSI 556	344	uS/cm	
Discharge	EF	6/28/2010	Temperature	YSI 556	12.99	C	
Discharge	EF	6/28/2010	Turbidity	HACH 2100P	0.61	NTU	
Influent	LSS-IN	6/28/2010	Dissolved Oxygen	YSI 556	8.44	mg/L	
Influent	LSS-IN	6/28/2010	ORP	YSI 556	-50.8	mV	
Influent	LSS-IN	6/28/2010	pH	YSI 556	7.99	su	
Influent	LSS-IN	6/28/2010	Specific Conductivity	YSI 556	362	uS/cm	
Influent	LSS-IN	6/28/2010	Temperature	YSI 556	10.48	C	
Influent	LSS-IN	6/28/2010	Turbidity	HACH 2100P	0.65	NTU	
Pond	PD	6/28/2010	Dissolved Oxygen	YSI 556	5.17	mg/L	
Pond	PD	6/28/2010	Iron, Ferrous	HACH Colorimeter	0.03	mg/L	
Pond	PD	6/28/2010	Iron, Total	HACH Colorimeter	0.27	mg/L	
Pond	PD	6/28/2010	ORP	YSI 556	-81.1	mV	
Pond	PD	6/28/2010	pH	YSI 556	8.17	su	
Pond	PD	6/28/2010	Specific Conductivity	YSI 556	347	uS/cm	
Pond	PD	6/28/2010	Temperature	YSI 556	10.67	C	
Pond	PD	6/28/2010	Turbidity	HACH 2100P	22.9	NTU	
Tote Effluent	TEF	6/28/2010	Dissolved Oxygen	YSI 556	1.97	mg/L	
Tote Effluent	TEF	6/28/2010	Flow	Visual flow meter	24	gpm	
Tote Effluent	TEF	6/28/2010	Iron, Ferrous	HACH Colorimeter	3.3	mg/L	>
Tote Effluent	TEF	6/28/2010	Iron, Total	HACH Colorimeter	3.3	mg/L	>
Tote Effluent	TEF	6/28/2010	ORP	YSI 556	-185	mV	
Tote Effluent	TEF	6/28/2010	pH	YSI 556	8.31	su	
Tote Effluent	TEF	6/28/2010	Specific Conductivity	YSI 556	357	uS/cm	
Tote Effluent	TEF	6/28/2010	Temperature	YSI 556	11.12	C	
Tote Effluent	TEF	6/28/2010	Turbidity	HACH 2100P	1.49	NTU	
Discharge	EF	6/29/2010	Dissolved Oxygen	YSI 556	8.5	mg/L	
Discharge	EF	6/29/2010	Iron, Ferrous	HACH Colorimeter	0	mg/L	
Discharge	EF	6/29/2010	Iron, Total	HACH Colorimeter	0	mg/L	
Discharge	EF	6/29/2010	ORP	YSI 556	-39	mV	
Discharge	EF	6/29/2010	pH	YSI 556	8.3	su	
Discharge	EF	6/29/2010	Specific Conductivity	YSI 556	346	uS/cm	
Discharge	EF	6/29/2010	Temperature	YSI 556	18.83	C	
Discharge	EF	6/29/2010	Turbidity	HACH 2100P	1.41	NTU	
Influent	LSS-IN	6/29/2010	Dissolved Oxygen	YSI 556	8.61	mg/L	
Influent	LSS-IN	6/29/2010	Iron, Ferrous	HACH Colorimeter	0	mg/L	
Influent	LSS-IN	6/29/2010	Iron, Total	HACH Colorimeter	0	mg/L	
Influent	LSS-IN	6/29/2010	ORP	YSI 556	-38.5	mV	
Influent	LSS-IN	6/29/2010	pH	YSI 556	7.92	su	
Influent	LSS-IN	6/29/2010	Specific Conductivity	YSI 556	362	uS/cm	
Influent	LSS-IN	6/29/2010	Temperature	YSI 556	10.48	C	
Influent	LSS-IN	6/29/2010	Turbidity	HACH 2100P	1.23	NTU	
Pond	PD	6/29/2010	Dissolved Oxygen	YSI 556	7.05	mg/L	
Pond	PD	6/29/2010	Iron, Ferrous	HACH Colorimeter	0.02	mg/L	

Station	Sample ID	Date	Analyte	Method	Result	Units	Qualifier
Pond	PD	6/29/2010	Iron, Total	HACH Colorimeter	0.16	mg/L	
Pond	PD	6/29/2010	ORP	YSI 556	-77.6	mV	
Pond	PD	6/29/2010	pH	YSI 556	8.18	su	
Pond	PD	6/29/2010	Specific Conductivity	YSI 556	350	uS/cm	
Pond	PD	6/29/2010	Temperature	YSI 556	14.54	C	
Pond	PD	6/29/2010	Turbidity	HACH 2100P	18.3	NTU	
Tote Effluent	TEF	6/29/2010	Dissolved Oxygen	YSI 556	2.16	mg/L	
Tote Effluent	TEF	6/29/2010	Flow	Visual flow meter	24	gpm	
Tote Effluent	TEF	6/29/2010	Iron, Ferrous	HACH Colorimeter	3.3	mg/L	>
Tote Effluent	TEF	6/29/2010	Iron, Total	HACH Colorimeter	3.3	mg/L	>
Tote Effluent	TEF	6/29/2010	ORP	YSI 556	-178	mV	
Tote Effluent	TEF	6/29/2010	pH	YSI 556	8.2	su	
Tote Effluent	TEF	6/29/2010	Specific Conductivity	YSI 556	355	uS/cm	
Tote Effluent	TEF	6/29/2010	Temperature	YSI 556	11.51	C	
Tote Effluent	TEF	6/29/2010	Turbidity	HACH 2100P	1.82	NTU	
Discharge	EF	6/30/2010	Dissolved Oxygen	YSI 556	8.54	mg/L	
Discharge	EF	6/30/2010	Iron, Ferrous	HACH Colorimeter	0	mg/L	
Discharge	EF	6/30/2010	Iron, Total	HACH Colorimeter	0.05	mg/L	
Discharge	EF	6/30/2010	ORP	YSI 556	-39.9	mV	
Discharge	EF	6/30/2010	pH	YSI 556	8.23	su	
Discharge	EF	6/30/2010	Specific Conductivity	YSI 556	346	uS/cm	
Discharge	EF	6/30/2010	Temperature	YSI 556	18.62	C	
Discharge	EF	6/30/2010	Turbidity	HACH 2100P	1.19	NTU	
Discharge	EF	7/1/2010	Dissolved Oxygen	YSI 556	9.14	mg/L	
Discharge	EF	7/1/2010	Iron, Ferrous	HACH Colorimeter	0	mg/L	
Discharge	EF	7/1/2010	Iron, Total	HACH Colorimeter	0	mg/L	
Discharge	EF	7/1/2010	ORP	YSI 556	-58.6	mV	
Discharge	EF	7/1/2010	pH	YSI 556	8.35	su	
Discharge	EF	7/1/2010	Specific Conductivity	YSI 556	345	uS/cm	
Discharge	EF	7/1/2010	Temperature	YSI 556	13.9	C	
Discharge	EF	7/1/2010	Turbidity	HACH 2100P	1.02	NTU	
Influent	LSS-IN	7/1/2010	Dissolved Oxygen	YSI 556	9.07	mg/L	
Influent	LSS-IN	7/1/2010	Iron, Ferrous	HACH Colorimeter	0	mg/L	
Influent	LSS-IN	7/1/2010	Iron, Total	HACH Colorimeter	0	mg/L	
Influent	LSS-IN	7/1/2010	ORP	YSI 556	-47.5	mV	
Influent	LSS-IN	7/1/2010	pH	YSI 556	7.91	su	
Influent	LSS-IN	7/1/2010	Specific Conductivity	YSI 556	362	uS/cm	
Influent	LSS-IN	7/1/2010	Temperature	YSI 556	10.46	C	
Influent	LSS-IN	7/1/2010	Turbidity	HACH 2100P	0.59	NTU	
Pond	PD	7/1/2010	Dissolved Oxygen	YSI 556	7.73	mg/L	
Pond	PD	7/1/2010	Iron, Ferrous	HACH Colorimeter	0	mg/L	
Pond	PD	7/1/2010	Iron, Total	HACH Colorimeter	0.02	mg/L	
Pond	PD	7/1/2010	ORP	YSI 556	-71.1	mV	
Pond	PD	7/1/2010	pH	YSI 556	8.15	su	
Pond	PD	7/1/2010	Specific Conductivity	YSI 556	346	uS/cm	
Pond	PD	7/1/2010	Temperature	YSI 556	13.1	C	
Pond	PD	7/1/2010	Turbidity	HACH 2100P	23.3	NTU	
Tote Effluent	TEF	7/1/2010	Dissolved Oxygen	YSI 556	2.26	mg/L	
Tote Effluent	TEF	7/1/2010	Flow	Visual flow meter	24	gpm	
Tote Effluent	TEF	7/1/2010	Iron, Ferrous	HACH Colorimeter	1.83	mg/L	
Tote Effluent	TEF	7/1/2010	Iron, Total	HACH Colorimeter	1.5	mg/L	
Tote Effluent	TEF	7/1/2010	ORP	YSI 556	-176.2	mV	
Tote Effluent	TEF	7/1/2010	pH	YSI 556	8.12	su	
Tote Effluent	TEF	7/1/2010	Specific Conductivity	YSI 556	357	uS/cm	
Tote Effluent	TEF	7/1/2010	Temperature	YSI 556	11.37	C	
Tote Effluent	TEF	7/1/2010	Turbidity	HACH 2100P	3.41	NTU	
Discharge	EF	7/13/2010	Dissolved Oxygen	YSI 556	9.58	mg/L	
Discharge	EF	7/13/2010	Iron, Ferrous	HACH Colorimeter	0.05	mg/L	
Discharge	EF	7/13/2010	Iron, Total	HACH Colorimeter	0.08	mg/L	
Discharge	EF	7/13/2010	ORP	YSI 556	26.6	mV	

Station	Sample ID	Date	Analyte	Method	Result	Units	Qualifier
Discharge	EF	7/13/2010	pH	YSI 556	8.09	su	
Discharge	EF	7/13/2010	Specific Conductivity	YSI 556	458	uS/cm	
Discharge	EF	7/13/2010	Temperature	YSI 556	19.12	C	
Discharge	EF	7/13/2010	Turbidity	HACH 2100P	1.45	NTU	
Influent	LSS-IN	7/13/2010	Dissolved Oxygen	YSI 556	9.78	mg/L	
Influent	LSS-IN	7/13/2010	Iron, Ferrous	HACH Colorimeter	0	mg/L	
Influent	LSS-IN	7/13/2010	Iron, Total	HACH Colorimeter	0	mg/L	
Influent	LSS-IN	7/13/2010	ORP	YSI 556	-8.9	mV	
Influent	LSS-IN	7/13/2010	pH	YSI 556	7.89	su	
Influent	LSS-IN	7/13/2010	Specific Conductivity	YSI 556	491	uS/cm	
Influent	LSS-IN	7/13/2010	Temperature	YSI 556	10.69	C	
Influent	LSS-IN	7/13/2010	Turbidity	HACH 2100P	1.66	NTU	
Pond	PD	7/13/2010	Dissolved Oxygen	YSI 556	7.05	mg/L	
Pond	PD	7/13/2010	ORP	YSI 556	-4.5	mV	
Pond	PD	7/13/2010	pH	YSI 556	7.95	su	
Pond	PD	7/13/2010	Specific Conductivity	YSI 556	472	uS/cm	
Pond	PD	7/13/2010	Temperature	YSI 556	14.21	C	
Pond	PD	7/13/2010	Turbidity	HACH 2100P	23.7	NTU	
Tote Effluent	TEF	7/13/2010	Dissolved Oxygen	YSI 556	2.67	mg/L	
Tote Effluent	TEF	7/13/2010	Flow	Visual flow meter	24	gpm	
Tote Effluent	TEF	7/13/2010	Iron, Ferrous	HACH Colorimeter	1.92	mg/L	
Tote Effluent	TEF	7/13/2010	Iron, Total	HACH Colorimeter	1.93	mg/L	
Tote Effluent	TEF	7/13/2010	ORP	YSI 556	-73.5	mV	
Tote Effluent	TEF	7/13/2010	pH	YSI 556	7.79	su	
Tote Effluent	TEF	7/13/2010	Specific Conductivity	YSI 556	479	uS/cm	
Tote Effluent	TEF	7/13/2010	Temperature	YSI 556	13.48	C	
Tote Effluent	TEF	7/13/2010	Turbidity	HACH 2100P	4.63	NTU	
Discharge	EF	8/10/2010	Dissolved Oxygen	YSI 556	9.71	mg/L	
Discharge	EF	8/10/2010	ORP	YSI 556	76.3	mV	
Discharge	EF	8/10/2010	pH	YSI 556	8.09	su	
Discharge	EF	8/10/2010	Specific Conductivity	YSI 556	350	uS/cm	
Discharge	EF	8/10/2010	Temperature	YSI 556	17.92	C	
Discharge	EF	8/10/2010	Turbidity	HACH 2100P	2.1	NTU	
Influent	LSS-IN	8/10/2010	Dissolved Oxygen	YSI 556	9	mg/L	
Influent	LSS-IN	8/10/2010	pH	YSI 556	7.69	su	
Influent	LSS-IN	8/10/2010	Specific Conductivity	YSI 556	368	uS/cm	
Influent	LSS-IN	8/10/2010	Temperature	YSI 556	10.57	C	
Influent	LSS-IN	8/10/2010	Turbidity	HACH 2100P	0.96	NTU	
Pond	PD	8/10/2010	Dissolved Oxygen	YSI 556	8.49	mg/L	
Pond	PD	8/10/2010	ORP	YSI 556	55.4	mV	
Pond	PD	8/10/2010	pH	YSI 556	7.95	su	
Pond	PD	8/10/2010	Specific Conductivity	YSI 556	354	uS/cm	
Pond	PD	8/10/2010	Temperature	YSI 556	12.47	C	
Pond	PD	8/10/2010	Turbidity	HACH 2100P	15	NTU	
Tote Effluent	TEF	8/10/2010	Dissolved Oxygen	YSI 556	5.63	mg/L	
Tote Effluent	TEF	8/10/2010	ORP	YSI 556	-77.2	mV	
Tote Effluent	TEF	8/10/2010	pH	YSI 556	7.77	su	
Tote Effluent	TEF	8/10/2010	Specific Conductivity	YSI 556	363	uS/cm	
Tote Effluent	TEF	8/10/2010	Temperature	YSI 556	11.8	C	
Tote Effluent	TEF	8/10/2010	Turbidity	HACH 2100P	10.4	NTU	
Discharge	EF	9/8/2010	Dissolved Oxygen	YSI 556	8.07	mg/L	
Discharge	EF	9/8/2010	Iron, Ferrous	HACH Colorimeter	0.06	mg/L	
Discharge	EF	9/8/2010	Iron, Total	HACH Colorimeter	0.06	mg/L	
Discharge	EF	9/8/2010	ORP	YSI 556	168.1	mV	
Discharge	EF	9/8/2010	pH	YSI 556	8.1	su	
Discharge	EF	9/8/2010	Specific Conductivity	YSI 556	406	uS/cm	
Discharge	EF	9/8/2010	Temperature	YSI 556	13.13	C	
Discharge	EF	9/8/2010	Turbidity	HACH 2100P	2.58	NTU	
Influent	LSS-IN	9/8/2010	Dissolved Oxygen	YSI 556	6.74	mg/L	
Influent	LSS-IN	9/8/2010	ORP	YSI 556	62.5	mV	

Station	Sample ID	Date	Analyte	Method	Result	Units	Qualifier
Influent	LSS-IN	9/8/2010	pH	YSI 556	7.74	su	
Influent	LSS-IN	9/8/2010	Specific Conductivity	YSI 556	427	uS/cm	
Influent	LSS-IN	9/8/2010	Temperature	YSI 556	10.35	C	
Influent	LSS-IN	9/8/2010	Turbidity	HACH 2100P	0.44	NTU	
Pond	PD	9/8/2010	Dissolved Oxygen	YSI 556	6.63	mg/L	
Pond	PD	9/8/2010	Iron, Ferrous	HACH Colorimeter	0.04	mg/L	
Pond	PD	9/8/2010	Iron, Total	HACH Colorimeter	0.16	mg/L	
Pond	PD	9/8/2010	ORP	YSI 556	-26	mV	
Pond	PD	9/8/2010	pH	YSI 556	7.93	su	
Pond	PD	9/8/2010	Specific Conductivity	YSI 556	417	uS/cm	
Pond	PD	9/8/2010	Temperature	YSI 556	12.07	C	
Pond	PD	9/8/2010	Turbidity	HACH 2100P	14.4	NTU	
Tote Effluent	TEF	9/8/2010	Dissolved Oxygen	YSI 556	5.06	mg/L	
Tote Effluent	TEF	9/8/2010	Iron, Ferrous	HACH Colorimeter	0.5	mg/L	
Tote Effluent	TEF	9/8/2010	Iron, Total	HACH Colorimeter	0.5	mg/L	
Tote Effluent	TEF	9/8/2010	ORP	YSI 556	-52.7	mV	
Tote Effluent	TEF	9/8/2010	pH	YSI 556	7.7	su	
Tote Effluent	TEF	9/8/2010	Specific Conductivity	YSI 556	425	uS/cm	
Tote Effluent	TEF	9/8/2010	Temperature	YSI 556	11.5	C	
Tote Effluent	TEF	9/8/2010	Turbidity	HACH 2100P	4.29	NTU	
Discharge	EF	10/18/2010	Dissolved Oxygen	YSI 556	10.02	mg/L	
Discharge	EF	10/18/2010	Iron, Ferrous	HACH Colorimeter	0.01	mg/L	
Discharge	EF	10/18/2010	Iron, Total	HACH Colorimeter	0.04	mg/L	
Discharge	EF	10/18/2010	ORP	YSI 556	146	mV	
Discharge	EF	10/18/2010	pH	YSI 556	8.3	su	
Discharge	EF	10/18/2010	Specific Conductivity	YSI 556	464	uS/cm	
Discharge	EF	10/18/2010	Temperature	YSI 556	9.26	C	
Discharge	EF	10/18/2010	Turbidity	HACH 2100P	2.16	NTU	
Influent	LSS-IN	10/18/2010	Dissolved Oxygen	YSI 556	9.5	mg/L	
Influent	LSS-IN	10/18/2010	ORP	YSI 556	38	mV	
Influent	LSS-IN	10/18/2010	pH	YSI 556	7.85	su	
Influent	LSS-IN	10/18/2010	Specific Conductivity	YSI 556	472	uS/cm	
Influent	LSS-IN	10/18/2010	Temperature	YSI 556	10.21	C	
Influent	LSS-IN	10/18/2010	Turbidity	HACH 2100P	1.07	NTU	
Pond	PD	10/18/2010	Dissolved Oxygen	YSI 556	9.86	mg/L	
Pond	PD	10/18/2010	Iron, Ferrous	HACH Colorimeter	0.07	mg/L	
Pond	PD	10/18/2010	Iron, Total	HACH Colorimeter	0.27	mg/L	
Pond	PD	10/18/2010	ORP	YSI 556	-39	mV	
Pond	PD	10/18/2010	pH	YSI 556	8.12	su	
Pond	PD	10/18/2010	Specific Conductivity	YSI 556	460	uS/cm	
Pond	PD	10/18/2010	Temperature	YSI 556	10.18	C	
Pond	PD	10/18/2010	Turbidity	HACH 2100P	11.2	NTU	
Tote Effluent	TEF	10/18/2010	Dissolved Oxygen	YSI 556	7.73	mg/L	
Tote Effluent	TEF	10/18/2010	Iron, Ferrous	HACH Colorimeter	0.47	mg/L	
Tote Effluent	TEF	10/18/2010	Iron, Total	HACH Colorimeter	0.49	mg/L	
Tote Effluent	TEF	10/18/2010	ORP	YSI 556	-78.9	mV	
Tote Effluent	TEF	10/18/2010	pH	YSI 556	7.9	su	
Tote Effluent	TEF	10/18/2010	Specific Conductivity	YSI 556	470	uS/cm	
Tote Effluent	TEF	10/18/2010	Temperature	YSI 556	11.06	C	
Tote Effluent	TEF	10/18/2010	Turbidity	HACH 2100P	1.32	NTU	
Drop Structure	LSS-DS	10/20/2010	Dissolved Oxygen	YSI 556	9.68	mg/L	
Drop Structure	LSS-DS	10/20/2010	ORP	YSI 556	-62.1	mV	
Drop Structure	LSS-DS	10/20/2010	pH	YSI 556	7.86	su	
Drop Structure	LSS-DS	10/20/2010	Specific Conductivity	YSI 556	470	uS/cm	
Drop Structure	LSS-DS	10/20/2010	Temperature	YSI 556	10.46	C	
Drop Structure	LSS-DS	12/1/2010	Dissolved Oxygen	YSI 556	11.2	mg/L	
Drop Structure	LSS-DS	12/1/2010	Iron, Ferrous	HACH Colorimeter	0	mg/L	
Drop Structure	LSS-DS	12/1/2010	Iron, Total	HACH Colorimeter	0.03	mg/L	
Drop Structure	LSS-DS	12/1/2010	ORP	YSI 556	-75.7	mV	
Drop Structure	LSS-DS	12/1/2010	pH	YSI 556	7.66	su	

Station	Sample ID	Date	Analyte	Method	Result	Units	Qualifier
Drop Structure	LSS-DS	12/1/2010	Specific Conductivity	YSI 556	350	uS/cm	
Drop Structure	LSS-DS	12/1/2010	Temperature	YSI 556	9.75	C	
Influent	LSS-IN	12/1/2010	Dissolved Oxygen	YSI 556	10.82	mg/L	
Influent	LSS-IN	12/1/2010	ORP	YSI 556	13	mV	
Influent	LSS-IN	12/1/2010	pH	YSI 556	7.67	su	
Influent	LSS-IN	12/1/2010	Specific Conductivity	YSI 556	353	uS/cm	
Influent	LSS-IN	12/1/2010	Temperature	YSI 556	9.8	C	
Tote Effluent	TEF	12/1/2010	Dissolved Oxygen	YSI 556	6.52	mg/L	
Tote Effluent	TEF	12/1/2010	Iron, Ferrous	HACH Colorimeter	0.01	mg/L	
Tote Effluent	TEF	12/1/2010	Iron, Total	HACH Colorimeter	0.03	mg/L	
Tote Effluent	TEF	12/1/2010	ORP	YSI 556	-131.1	mV	
Tote Effluent	TEF	12/1/2010	pH	YSI 556	7.83	su	
Tote Effluent	TEF	12/1/2010	Specific Conductivity	YSI 556	349	uS/cm	
Tote Effluent	TEF	12/1/2010	Temperature	YSI 556	9.42	C	
Discharge	EF	4/26/2011	Dissolved Oxygen	YSI 556	14.53	mg/L	
Discharge	EF	4/26/2011	Iron, Ferrous	HACH Colorimeter	0.04	mg/L	
Discharge	EF	4/26/2011	Iron, Total	HACH Colorimeter	0.02	mg/L	
Discharge	EF	4/26/2011	ORP	YSI 556	55.1	mV	
Discharge	EF	4/26/2011	pH	YSI 556	7.41	su	
Discharge	EF	4/26/2011	Specific Conductivity	YSI 556	324	uS/cm	
Discharge	EF	4/26/2011	Temperature	YSI 556	11.39	C	
Discharge	EF	4/26/2011	Turbidity	HACH 2100P	3.32	NTU	
Influent	LSS-IN	4/26/2011	Dissolved Oxygen	YSI 556	10.17	mg/L	
Influent	LSS-IN	4/26/2011	ORP	YSI 556	33.3	mV	
Influent	LSS-IN	4/26/2011	pH	YSI 556	7.25	su	
Influent	LSS-IN	4/26/2011	Specific Conductivity	YSI 556	337	uS/cm	
Influent	LSS-IN	4/26/2011	Temperature	YSI 556	9.87	C	
Influent	LSS-IN	4/26/2011	Turbidity	HACH 2100P	1.28	NTU	
Pond	PD	4/26/2011	Dissolved Oxygen	YSI 556	12.09	mg/L	
Pond	PD	4/26/2011	ORP	YSI 556	20.4	mV	
Pond	PD	4/26/2011	pH	YSI 556	7.32	su	
Pond	PD	4/26/2011	Specific Conductivity	YSI 556	328	uS/cm	
Pond	PD	4/26/2011	Temperature	YSI 556	10.93	C	
Pond	PD	4/26/2011	Turbidity	HACH 2100P	4.96	NTU	
Tote Effluent	TEF	4/26/2011	Dissolved Oxygen	YSI 556	9.01	mg/L	
Tote Effluent	TEF	4/26/2011	Iron, Ferrous	HACH Colorimeter	0.03	mg/L	
Tote Effluent	TEF	4/26/2011	Iron, Total	HACH Colorimeter	0	mg/L	
Tote Effluent	TEF	4/26/2011	ORP	YSI 556	-52.9	mV	
Tote Effluent	TEF	4/26/2011	pH	YSI 556	7.21	su	
Tote Effluent	TEF	4/26/2011	Specific Conductivity	YSI 556	334	uS/cm	
Tote Effluent	TEF	4/26/2011	Temperature	YSI 556	10.18	C	