Ex. 6 -- Personal Privcy

201.00-1,003.00,000.

Sample Date: 3/28/10 (Quantum)

Sample Date: 11/18/10(Quantum)

Sample Date: 12/1/11 (Quantum)

Sample Date: 2/8/12 (Moody)

Sample Date: 2/17/12 (Moody)

Sample Date: 2/27/12 (Moody)

Well 1-1: Pre-treatment
Well 1-2: Post treatment - Water Softner
Well 1-3: Post reverse omosis
Well 1-4: Post reverse omosis (after new membrane installed)

Analysis	Units	MCL	Well 1-1 3/28/10	Well 1-3 11/18/10	Well 1-1 12/1/11	Well 1-3 12/1/11	Well 1-1 2/8/12	Well 1-2 2/8/12	Well 1-1 2/17/12	Well 1-2 2/17/12	Well 1-3 2/17/12	Well 1-4 2/17/12	Well 1-1 2/27/12	Well 1-2 2/27/12	Well 1-3 2/27/12
Boron	mg/l	-	0.075				0.110	0.112	0.0567	0.0566	< 0.0500	< 0.0500			
Calcium	mg/l	-		<0.5	35.4	<0.50	22.7	< 0.200	26.3	< 0.200	< 0.200	< 0.200			
Lithium	mg/l	-					0.122	< 0.0200	0.0731	< 0.0200	< 0.0200	< 0.0200			
Magnesium	mg/l	-	4.75	<0.5	4.7	<0.50	3.75	< 0.100	4.42	< 0.100	< 0.100	< 0.100			
Potassium	mg/l	-		<1	1.3	<1.0	1.84	< 0.500	1.93	< 0.500	< 0.500	< 0.500			
Silver	mg/l	0.1**		<0.001	<0.0050	<0.0050	< 0.0050	< 0.0050	< 0.0050	< 0.0050	< 0.0050	< 0.0050			
Sodium	mg/l	-		4.1	9.3	5.0	51.1	88.0	43.6	92.6	6.45	4.46			
Tin	mg/l	-					< 0.0200	< 0.0200	< 0.0200	< 0.0200	< 0.0200	< 0.0200			
Titanium	mg/l	-					< 0.0100	< 0.0100	< 0.0100	< 0.0100	< 0.0100	< 0.0100			
Aluminum	mg/l	0.2**	<0.10	<0.10	<0.10	<0.10	< 0.100	< 0.100	< 0.100	< 0.100	< 0.100	< 0.100			
Antimony	mg/l	0.006*					< 0.0010	< 0.0010	< 0.0010	< 0.0010	< 0.0010	< 0.0010			
Arsenic	mg/l	0.010*	0.016	0.032	0.097	0.031	0.0819	0.0762	0.0987	0.0894	0.0426	0.0220	0.105	0.0991	0.171
Arsenate	mg/l												0.0220	0.0182	0.175
Inorganic Arsenic	mg/l												0.0965	0.106	0.185
Arsenite	mg/l												0.0744	0.0878	0.0109
Barium	mg/l	2*	0.549	<0.002	0.17	<0.010	0.458	< 0.0020	0.504	< 0.0020	< 0.0020	< 0.0020			
Beryllium	mg/l	0.004*					< 0.00050	< 0.00050	< 0.00050	< 0.00050	< 0.00050	< 0.00050			
Cadmium	mg/l	0.005*		<0.0001	<0.0010	<0.0010	< 0.00050	< 0.00050	< 0.00050	< 0.00050	< 0.00050	< 0.00050			
Chromium	mg/l	0.1*		<0.002	<0.0050	<0.0050	< 0.0020	< 0.0020	< 0.0020	< 0.0020	< 0.0020	< 0.0020			
Cobalt	mg/l	-					< 0.00050	< 0.00050	< 0.00050	< 0.00050	< 0.00050	< 0.00050			
Copper	mg/l	1.0**					0.0063	< 0.0020	0.0122	< 0.0020	0.0784	0.0030			
Iron	mg/l	0.3**	<0.05	<0.05	<0.040	<0.040	3.80	< 0.100	5.26	< 0.100	< 0.100	< 0.100			
Lead	mg/l	0.005*		<0.0003	<0.0010	<0.0010	< 0.0010	< 0.0010	< 0.0010	< 0.0010	< 0.0010	< 0.0010			
Manganese	mg/l	0.05**	0.0938	<0.0025	<0.0050	<0.0050	0.889	< 0.0010	1.13	< 0.0010	< 0.0010	< 0.0010			
Nickel	mg/l	-					< 0.0020	< 0.0020	< 0.0020	< 0.0020	< 0.0020	< 0.0020			
Selenium	mg/l	0.05*		<0.002	<0.0010	<0.0010	< 0.0020	< 0.0020	< 0.0020	< 0.0020	< 0.0020	< 0.0020			
Strontium	mg/l	-	0.859	0.00067	0.26	<0.010	0.701	< 0.0010	0.838	< 0.0010	< 0.0010	< 0.0010			
Thallium	mg/l	0.002*	<0.002				< 0.00050	< 0.00050	< 0.00050	< 0.00050	< 0.00050	< 0.00050			
Vanadium	mg/l	-	<0.01				< 0.00050	< 0.00050	< 0.00050	< 0.00050	< 0.00050	< 0.00050			
Zinc	mg/l	5**					< 0.0150	< 0.0150	< 0.0150	< 0.0150	0.0484	< 0.0150			
Mercury	mg/l	0.002*		<0.0002	<0.00020	<0.00020	< 0.00020	< 0.00020	< 0.00020	< 0.00020	< 0.00020	< 0.00020			
Total Dissolved Solids	mg/l	500**	224				205	225	210	235	11.0	141			
Total Suspended Solids	mg/l		9.2				8.44	< 3.27	11.1	< 3.15	< 3.12	< 3.09			
Conductivity (Field Measu	uS/cm		371	22	211	10	314	322	259			177	225	266	263
Turbidity (Field Measurem	NTU						2.28	0.84	5.57	3.24		1.60	6.44	2.16	3.50
pH (Field Measurement)	pH Unit	6.5-8.5**	6.93	6.93	7.81	7.82	7.57	7.58	7.31			7.05	7.12	7.19	7.37

* - USEPA National Primary Drinking Water Regulations

** - USEPA Natioanl Secondary Drinking Water Regulations (non-enforce

Exceeds USEPA Primary or Secondary Drinking Water Regualtions