12-13-88
12-3.8 v.4

Comm

Jim Long - Midland
Beau Ash - Close
Gene - Cascade

Electrical Walk Thru 12/13/88
If J Box @ Clinker Elev is spliced - This work should be an addn.

S&C gear has space heaters.

Take them off of ~~Sd~~ Breaker Panel in Coal Mill. to 120V space heaters. No addendum will be issued.

Remove boathouse conduit to where it goes under paved roadway.

8826# Sun Transformer.

Remove conductor Steel tanks to Coal mill sub.

USEPA SF
1261300