3-14-89
12.3.8 v.4

To. T.G. Wells
From K.J. Rowe
Subject. PCB

A) Of the PCB containing transformers, concentrations are as follows:

Transformer	PPM	Gal
# TC-12	646	30
→ # TC-13	507	981 Removed 3/14/89
F-963361	>50%	135
F-963295A	>50%	180
F-963295B	>50%	180
F-963294	>50%	140

B) Of the PCB contaminated transformers, concentrations are as follows:

Transformer	PPM	Gal
# TC-35	119	155
# TC-33	92	20

C) Of the non-PCB transformers, concentrations are as follows:

Transformer	PPM	Gal
# TC-32	38	20 (assume)
# TC-36	32	N.A.
# TC-37	2	89
# TC-38	3	N.A.
# TC-34	25	155

Definitions are referenced to the Fed. Register (Vol 44, #106, May 31, 1979 p 31537)

USEPA SF
1261486

LONE STAR INDUSTRIES
SEATTLE WASHINGTON

Subject _____ By _____ Date _____
Chkd By _____ Date _____
Sheet No _____ Of _____

AGC2F000144