709

RECORD OF COMMUNICATION

☒ PHONE CALL ☐ DISCUSSION ☐ FIELD TRIP ☐ CONFERENCE
☐ OTHER (SPECIFY)

(Record of item checked above)

30-33

TO: Karen Flournoy

FROM: John Ramsey returning my call KDHE 913/862-9360 ext 511

DATE 11-26-84

TIME

SUBJECT Reid Supply

SUMMARY OF COMMUNICATION

I called John with my comments on draft of final permit app. dated 11-17-84
Comments are:

1. owner certif. wording 270.11 (formerly 122.6) revised wording in 9-1-83 FR
2. provide containment system calculations - John has checked numbers are ok. (no need to incl. more detail)
3. could transfer tanks (transport trucks) be used to hold contents of leaking storage tanks?
4. Figure 42 (last pg.) 4500 gal. storage tanks frequency of inspection needs to be changed to be consistent with narrative on tanks.
5. inspection log sheets - recommend putting non-reg. tank info. on separate sheet because will attach log sheet to permit & do not want to attach info. on non-reg. tanks.
6. We need copy of Reid response to 10-17-84 letter from Fire Dept.

- We should send copy of draft permit to Fire Dept. so they can review & comment since they have been involved with contingency plan.

CONCLUSIONS, ACTION TAKEN OR REQUIRED

- We may also want to incl. more detail in some conditions to avoid possible compliance problems later. John & I discussed their proposed sampling methods. Told John language in SW-846 provides for some flexibility & since they have delineated methods to be used. I have no problems w/ what they have proposed. Will incl. this detail in permit condition.

INFORMATION COPIES
TO:

EPA Form 1300-6 (7-72) REPLACES EPA HQ FORM 5300-3 WHICH MAY BE USED UNTIL SUPPLY IS EXHAUSTED

R00001567
RCRA Records Center