Collector Main Inspection

Date: 6-28-09

Time: 3:20P

Battery: WILPUTTE

Are there any leaks? (yes/no) NO

If yes, what time was the leak temporarily sealed? _____

What time and date was it permanently repaired? _____

If a leak is observed, you must temporarily seal the leak within four (4) hours of detection. You must initiate repairs within five (5) days and complete the repair within 15 days.

Signature: _____

Collector Main Inspection

Date: 6-28-09

Time: 10pm

Battery: WILBUTTE

Are there any leaks? (yes/no) No

If yes, what time was the leak temporarily sealed? _____

What time and date was it permanently repaired? _____

If a leak is observed, you must temporarily seal the leak within four (4) hours of detection. You must initiate repairs within five (5) days and complete the repair within 15 days.

Signature: _____

Collector Main Inspection

Date: 6-27-09

Time: 6-2

Battery: WILPUTTE

Are there any leaks? (yes/no) NO

If yes, what time was the leak temporarily sealed? _____

What time and date was it permanently repaired? _____

If a leak is observed, you must temporarily seal the leak within four (4) hours of detection. You must initiate repairs within five (5) days and complete the repair within 15 days.

Signature: _____

Collector Main Inspection

Date: 6-29-05

Time: 4:15P

Battery: WILPUTTE

Are there any leaks? (yes/no) NO

If yes, what time was the leak temporarily sealed? _____

What time and date was it permanently repaired? _____

If a leak is observed, you must temporarily seal the leak within four (4) hours of detection. You must initiate repairs within five (5) days and complete the repair within 15 days.

Signature: _____